


**Newfoundland Labrador Hydro (NLH)  
Supply and Demand Status Report Filed Monday, April 13, 2026**

**Section 1  
Island Interconnected System - Supply, Demand & Exports  
Actual 24 Hour System Performance For Friday, April 10, 2026**



**Island Supply Notes For April 10, 2026**

- A As of 1326 hours, February 05, 2026, Cat Arm Unit 2 available at 57 MW due to forced derating (67 MW).
- B As of 2234 hours, March 20, 2026, Holyrood Unit 1 available at 166 MW due to forced derating (170 MW).
- C As of 1251 hours, March 26, 2026, St. Anthony Diesel Plant available at 7.7 MW due to forced derating (9.7 MW).
- D As of 0800 hours, March 29, 2026, Holyrood Unit 3 unavailable due to planned outage (150 MW).
- E As of 0730 hours, April 06, 2026, Bay d'Espoir Unit 5 unavailable due to planned outage (76.5 MW).
- F As of 0730 hours, April 06, 2026, Bay d'Espoir Unit 6 unavailable due to planned outage (76.5 MW).
- G As of 1525 hours, April 09, 2026, Holyrood Unit 2 available but not operating (170 MW).
- H As of 1940 hours, April 09, 2026, Stephenville Gas Turbine available at 25 MW due to forced derating (50 MW).

**Section 2  
Island Interconnected System - Supply, Demand & Outlook**

Sat, Apr 11, 2026	Island System Outlook <sup>2</sup>	Seven-Day Forecast	Island System Daily Peak Demand (MW)	
			Forecast <sup>8</sup>	Adjusted <sup>6</sup>
Island System Supply: <sup>4</sup>	1,653 MW	Saturday, April 11, 2026	1,115	1,022
NLH Island Generation: <sup>3,7</sup>	1,180 MW	Sunday, April 12, 2026	1,180	1,086
NLH Island Power Purchases: <sup>5</sup>	85 MW	Monday, April 13, 2026	1,280	1,185
NP and CBPP Owned Generation:	225 MW	Tuesday, April 14, 2026	1,175	1,081
LIL/ML Net Imports to Island: <sup>9</sup>	163 MW	Wednesday, April 15, 2026	1,160	1,067
7-Day Island Peak Demand Forecast:	1,280 MW	Thursday, April 16, 2026	1,230	1,136
		Friday, April 17, 2026	1,235	1,141

**Island Supply Notes For April 11, 2026**

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
  2. As of 0800 Hours.
  3. Gross continuous unit output.
  4. Gross output from all Island sources (including Note 3).
  5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
  6. Adjusted for interruptible load and the impact of voltage reduction when applicable.
  7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.
  8. Does not include ML Exports.
  9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

**Section 3  
Island Peak Demand and Exports Information  
Previous Day Actual Peak and Current Day Forecast Peak**

Fri, Apr 10, 2026	Island Peak Demand <sup>10</sup>	7:20	1,220 MW
	Exports at Peak		62 MW
	LIL Net Imports to Island		5,483 MWh
Sat, Apr 11, 2026	Forecast Island Peak Demand		1,115 MW

- Notes:
10. Island Demand is supplied by NLH generation and purchases, LIL Imports plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).