

# NEWFOUNDLAND AND LABRADOR HYDRO

*Generation and Reserve Planning*

March 2014



## Table of Contents

EXECUTIVE SUMMARY ..... 1

1 INTRODUCTION ..... 3

2 REVIEW PROCESS ..... 4

3 BACKGROUND ..... 6

4 VENTYX REVIEW ..... 14

5 KEY FINDINGS AND RECOMMENDATIONS..... 20

ACRONYMS ..... 22

Appendices:

Appendix 1    Ventyx, Inc. Report, 2014 Newfoundland and Labrador Hydro Planning Process  
                    Review

## EXECUTIVE SUMMARY

Newfoundland and Labrador Hydro (Hydro) has completed a comprehensive review of the events surrounding the supply disruptions on the Island Interconnected System during January 2-8, 2014. The review included investigation of the rotating outages that occurred between January 2-8, 2014<sup>1</sup> and the transmission/terminal station equipment failures that occurred on January 4 and 5, 2014.

This report details the findings of both internal and independent reviews of Hydro's generation and reserve planning processes. Hydro completed its own review and also commissioned Ventyx, an ABB company and leading supplier of enterprise software and services for asset intensive industries, to provide independent feedback and insight.

Both reviews found that generation and reserve planning processes were not contributing factors to the supply disruptions and rotating outages of January 2-8, 2014. Ventyx concluded that it had; "not found any evidence that either the generation-planning process or the load-forecasting process have contributed to the events of January." However, the reviews do recommend minor improvement.

Hydro's capacity and energy criterion are comparable with those of other utilities, differing only where appropriate, as Hydro's grid is not interconnected to North America at this time. Moving to a more stringent reliability criterion would require significantly more investment and therefore higher electricity rates. The generation planning modelling, the computer software system Strategist, as well as the values selected for the variables and the assumptions made in the modelling, are reasonable and appropriate.

Recommendations from the reviews are as follows:

GRP 1: Hydro should continue with its generation planning reserve criterion.

---

<sup>1</sup> Rotating outages occurred on January 2, 3, 5 and 8, 2014.

1 GRP 2: After interconnection in 2017, Hydro should revisit both its generation  
2 planning reserve criterion and its modeling of external markets.

3 GRP 3: Since Holyrood is scheduled to be retired in the next 4 to 5 years, Hydro should  
4 model its Equivalent Forced Outage Rate (EFOR) close to the actuals currently  
5 being experienced with sensitivities on either side of the expected value. With  
6 respect to all other thermal units in the Strategist model (existing and future)  
7 Hydro should continue its practice of modeling with a more conservative  
8 estimate of EFOR for the units.

9 GRP 4: Hydro should compute a break-even EFOR for each class of its generation to  
10 determine the point at which a generator's EFOR will result in the system  
11 exceeding the Loss of Load Hours (LOLH) criteria of 2.8 hours per year.

12 GRP 5: Hydro should develop a formal risk analysis process that utilizes scenarios and  
13 sensitivities to test the robustness of resource plans.  
14

15 Hydro has accepted these recommendations and they will be considered in the preparation of  
16 the Capital Budget Application currently being prepared to address the forecasted 2015  
17 capacity deficit described below.

## 1 INTRODUCTION

Hydro has completed an internal review of the supply disruptions on the Island Interconnected<sup>2</sup> System (System) during January 2014, with a view to improving its performance in meeting its mandate to provide least-cost, reliable power for Newfoundland and Labrador.

This report focuses on whether decisions made in Hydro's generation and reserve planning played a role in the capacity shortfalls experienced in January 2014. Included in the review are all generation and reserve planning criteria and processes used to predict when there will be a shortfall in energy on the System and, consequently, what generation sources should be added and when.

On December 14, 2013, Hydro supplied a record-high System demand of 1,501 megawatts (MW) (the Island peak served by both Hydro and non-Hydro generation was 1,663 MW). Prior to that date, the record was 1,405 MW, met in 2004. Due to persistently low temperatures and system operating factors, demand remained high for the next several weeks. As several major generating plants were unavailable or de-rated, Hydro implemented its Generation Loading Generation Shortage Protocol (System Operating Instruction T-001) several times.

On January 2, 2014, the system forecast exceeded the available supply, and all steps of the Generation Loading Generation Shortage protocol were implemented – the last of which was to request Newfoundland Power to shed load by feeder interruptions, at the same time as Hydro shed load by feeder interruptions in its service area. Further outages occurred as a result of equipment failures on January 4 and 5, 2014.

---

<sup>2</sup> In this context Interconnected means those parts of the island serviced from the grid (i.e. excluding the isolated communities using diesel power), not interconnection to North America. The Interconnected Island System includes generation by Newfoundland Power and Kruger.

## **2 REVIEW PROCESS**

### **2.1 Internal Review**

During, and immediately following the supply disruptions, Hydro personnel responsible for generation and reserve planning reviewed Hydro's processes and their inputs. From a planning perspective, the main issue for consideration was whether there was adequate capacity and reserve available on the System in December 2013 and January 2014. Hydro's review focused on three areas: the planning criteria; the planning processes; and the inputs to the processes to ensure they accurately represent Hydro's system.

Hydro uses the Strategist Model for generation planning. Strategist is a computer software system, developed by Ventyx, Inc., (Ventyx), which supports electric utility decision analysis and corporate strategic planning. More detail is available in the Ventyx report, included in Appendix 1. One of the main variables that influence the timing of new generation is the forced outage rates or availability of the existing generation. Selection of these rates for older equipment and significantly refurbished equipment is complex. The review considered the assumptions made in the current planning process, and also how those assumptions should change once planned changes are made to the system, including the refurbishments of Hydro's gas turbines, and interconnections to Labrador and Nova Scotia.

### **2.2 Prior Reviews**

In recent years, Hydro's planning processes have been reviewed as part of several comprehensive reviews of the Muskrat Falls Project:

- In 2011, Navigant Consulting Ltd undertook a document review of Nalcor's planning studies;
- In 2011, the Public Utilities Board (PUB) commissioned Manitoba Hydro International Ltd. (MHI) to review the Muskrat Falls Generating Station and Labrador-Island Link HVdc projects; and

- In 2012, the Government of Newfoundland and Labrador retained MHI to provide an independent assessment of the two generation supply options as prepared by Nalcor Energy.

### **2.3 Independent Review**

The internal review process highlighted several areas where Hydro staff felt the opinions of outside expertise would be valuable. Hydro determined that an independent, external, review was the best way to evaluate its generation and reserve planning processes.

Hydro commissioned Ventyx, an ABB company and leading supplier of enterprise software and services for asset intensive industries, to perform an independent assessment on Hydro's generation planning and load forecasting processes.

The focus of this work was to provide a review of both the generation planning processes that form the basis of Hydro's strategic plans and forecasts and a review of Hydro's long-term (planning) and medium-term (operating) load forecasting. The work was broken into four tasks:

- Task 1: Planning and Forecast Process Review - examination of prior independent reviews of Hydro's practices and comparison to standard practices in planning and forecasting.
- Task 2: Generation Planning Criteria - review of the overall planning process and assumptions used by Hydro to develop its current long-range, and strategic forward-looking plans and commentary on the processes and criteria including recommendations for improvements.
- Task 3: Load Forecasting Process - review of the process used by Hydro to develop its long-range load forecast and medium-term operational forecasts, as well as commentary on the processes, including recommendations for improvements.

- Task 4: Strategist Model Review<sup>3</sup> - review of the Strategist Model assumptions used by Hydro to develop its long-range and strategic forward-looking plans and commentary on the processes and criteria including recommendations for improvements. Ventyx reviewed the current database and commented on its appropriateness and how it is being used.

## **3 BACKGROUND**

### **3.1 Responsibilities**

Generation and reserve planning are the responsibility of the System Planning department within Hydro's System Operation and Planning Division.

### **3.2 Planning Criteria**

Hydro's System Planning group has established criteria related to the appropriate reliability for the System at the generation level, which sets the timing of generation source additions. These criteria set the minimum level of reserve capacity and energy installed in the System to ensure an adequate supply for firm demand. However, short-term deficiencies can be tolerated if the deficiencies are of minimal incremental risk. As a general rule to guide Hydro's planning activities, the following have been adopted:

- Capacity: The System should have sufficient generating capacity to satisfy an LOLH expectation target of not more than 2.8 hours per year. LOLH is a probabilistic assessment of the level of un-served load at time of peak, due to insufficient generation.
- Energy: The System should have sufficient generating capability to supply all of its firm energy requirements with firm system capability. Firm capability for the hydroelectric resources is the firm energy capability of those resources under the most adverse three-year sequence of reservoir inflows, occurring within the historical record. Firm capability for the thermal resources (Holyrood Generation) is based on energy capability adjusted for maintenance and forced outages.

---

<sup>3</sup> Strategist is a computer software system, developed by Ventyx, LLC, which supports electric utility decision analysis and corporate strategic planning. More detail is available in the Ventyx report, included in Appendix A.



These criteria have been in use by Hydro for many years and represent a balance between cost and reliability. They are consistent with established industry standards and practices.

It is predominantly the criteria for capacity which requires review at this time, because the conditions in January 2014 were affected by constraints on capacity, not energy, i.e. there was plenty of energy in storage on the system, but insufficient equipment available to generate power and meet the peak loads. The sources of firm and non-firm generation currently on the System are listed in Table 1.

**Table 1: Island Interconnected System Capacity.**

### Island Interconnected System Capacity (MW)

		Firm (Dependable)	Additional	Total
<u>Newfoundland and Labrador Hydro</u>				
Owned	Hydroelectric	927.3	-	927.3
Owned	Holyrood	465.5	-	465.5
Owned	Gas Turbine	100.0	-	100.0
Owned	Diesel	14.7	-	14.7
	Total Owned	1,507.5	-	1,507.5
Purchased	Hydroelectric	78.0	31.8	109.8
Purchased	Co-Generation	8.0	7.0	15.0
Purchased	Wind	-	54.0	54.0
	Total Purchased	86.0	92.8	178.8
Total NLH System		1,593.5	92.8	1,686.3
<u>Customer Owned</u>				
Corner Brook Pulp and Paper	Hydroelectric	99.1	22.3	121.4
Newfoundland Power	Hydroelectric	78.7	18.2	96.9
Newfoundland Power	Gas Turbine	36.5	-	36.5
Newfoundland Power	Diesel	5.0	-	5.0
	Total Customer Owned	219.3	40.5	259.8
<b>Total Island Interconnected System</b>		<b>1,812.8</b>	<b>133.3</b>	<b>1,946.1</b>

Hydro's generation source additions criteria have been in use for more than 35 years and in that period have been reviewed several times and found to provide a good balance of reliability and cost. It is not possible to design a 100% reliable system. All equipment has some possibility

1 of failure. In a regulated energy environment, the level of investment into reliability is limited –  
2 moving to a more stringent reliability criterion would require significantly more investment and  
3 therefore higher electricity rates.

4  
5 Initially, Hydro used a Loss of Load Probability (LOLP) criteria established at 0.2 days per year, or  
6 one day in five years, however, when Hydro replaced its original generation planning software  
7 in 1997, it was necessary to switch to a LOLH criterion. Benchmarking established that a LOLH  
8 of 2.8 hours per year was approximately equivalent to a LOLP of 0.2 days per year, for Hydro's  
9 system. From that point, Hydro established the capacity criterion that the System should have  
10 sufficient generating capacity to satisfy an LOLH target of not more than 2.8 hours per year.  
11 This does not mean customers can expect to lose generation for 2.8 hours each year, rather  
12 than over the long-term, system conditions may lead to an average loss of 2.8 hours per year in  
13 the period leading up to the next capacity addition. The capacity criterion is somewhat less  
14 stringent than that employed by large interconnected systems in the rest of North America  
15 because of the non-interconnected status of the island's electric utility system. In the isolated  
16 island system there is no ready market for acquiring additional capacity should a shortage  
17 occur; reserve can only be increased by the installation of additional and expensive generating  
18 equipment. Hydro's criterion is based on the premise that the cost of providing a higher  
19 reliability level is in excess of the benefits to be derived.

20  
21 When Hydro connects to the North American grid there will be a step change in reliability, as  
22 the interconnection will provide access to markets for reserve and reliability. At that time,  
23 Hydro will reconsider its criteria and bring them into alignment with other North American  
24 utilities.

### 25 26 **3.3 Operating Reserves**

27 From an operational perspective, Hydro manages generation resource availability on the  
28 System and schedules generating units out of service for planned maintenance in order to meet  
29 a (n-1) system contingency reserve criterion. In this manner, sufficient reserves are planned to

1 be available to meet the System load under a contingency of the largest (MW rating) available  
2 generating unit becoming unavailable. Hydro does not rely on capacity from wind and other  
3 non-dispatchable resources to provide reserve. The current level of non-dispatchable  
4 generation has not affected Hydro's ability to meet its peak load. Hydro's generation planning  
5 assessments take into account this non-dispatchable nature, and under most operating  
6 conditions, there is more than enough firm dispatchable generation available to meet peak  
7 loads. The non-dispatchable generation, when available, increases the level of generation  
8 potentially available as reserve.

9  
10 Following the (n-1) criterion requires that Hydro not allow any extended planned maintenance  
11 to be scheduled during the winter period. However, if the short-term load forecast permits,  
12 Hydro may take the opportunity to schedule a short-duration generating unit outage to address  
13 running or corrective maintenance issues.

### 14 15 **3.4 Hydro's Generation and Reserve Planning Process**

16 Hydro uses Ventyx's Strategist Model software to analyse and plan the generation  
17 requirements of the System. Strategist Model is an integrated strategic planning computer  
18 program that allows modeling of the current and future electric power system and which  
19 performs, among other functions, generation system reliability analysis, production costing  
20 simulation, and generation expansion planning analysis. It is the industry standard for  
21 generation planning and Hydro has been using the Strategist Model (or the versions of the  
22 software that preceded it) for many years. Inputs to the model include load-forecast  
23 information, information reflecting the characteristics of the hydroelectric and thermal  
24 generation on the system, lifecycle information and financial data.

25  
26 The current expansion plan is based on the 2012 Island Planning Load Forecast (PLF) as  
27 prepared by the Market Analysis section of the System Planning department. Hydro's load  
28 forecasting and its potential role in the January supply disruptions is the subject of a separate  
29 report (Load Forecasting).

1 In addition to the Muskrat Falls project, the portfolio used in this analysis was:

- 2 • Small hydro developments;
- 3 • 50 MW Combustion Turbine (CT);
- 4 • 170 MW Combined Cycle Combustion Turbine (CCCT);
- 5 • Wind farm replacement hydro-constructed; and
- 6 • Holyrood environmental improvements.

7  
8 All generation production units in the model have an associated forced-outage rate, which  
9 leads to the unavailability of a generating unit for a set time. The forced outage rates used in  
10 this analysis are based on Hydro's operations experience and/or industry norms from the  
11 Canadian Electricity Association.

12  
13 Currently, no cost of carbon atmospheric emissions has been included in the analyses because  
14 of uncertainties regarding the timing, scope, and design associated with possible future  
15 regulatory initiatives in this regard. Demand management initiatives are not explicitly included  
16 in Hydro's Strategist Model. Energy efficiency is integrated into Hydro's load forecast through  
17 the use of an efficiency trend variable. The success associated with utility-sponsored energy  
18 efficiency remains modest and is taken as a subset of efficiency trends in the load forecast  
19 process.

20  
21 Generation planning is an iterative process. An initial generation expansion analysis is carried  
22 out using a load forecast developed from preliminary rates, based on recent load forecasts, and  
23 current fuel costs. The output from the least-cost generation expansion plan is fed into the  
24 Hydro rates models. The rates that are generated in that model are fed back into the forecast  
25 model and the iterative process continues until the timing and choice of generation expansion  
26 options remains stable from one iteration to the next. The least-cost generation plan is the one  
27 with the lowest Cumulative Present Worth (CPW), which is the present value of all incremental  
28 utility capital and operating costs incurred by Hydro to reliably meet a specific load forecast  
29 given a prescribed set of reliability criteria. The outcome of the generation planning analysis is

the alternative supply future with the lowest CPW, which will be recommended by Hydro and is consistent with its mandate for least-cost electrical service.

Hydro is confident the selection of the Strategist Model, and the way it represents the island system overall, is reasonable. This has been confirmed by several external reviews over the last several years in connection to the Muskrat Falls project. One aspect, in particular, where Hydro determined that outside advice would be helpful, was forced outage rates/availability of existing thermal equipment used in the model. Ventyx's findings in this regard are discussed in Section 4.2. Strategist Model simulations to date would not have modelled as much of Hydro's generating equipment being forced out of service as occurred in January 2014. A summary of the forced outage rates, used in the current Strategist Model, is provided in Table 2. These values were derived in 2006 and have been reviewed annually to confirm they are still reasonable.

**Table 2: Strategist Forced Outage Rates (2012)**

<b>Unit/Class of Units</b>	<b>Forced Outage Rate, %</b>
Existing NLH Hydro Units	0.90
New Hydro	0.90
Gas Turbine	10.62
Holyrood	9.64
Standby Diesel	1.18
New CCCT	5.0
Labrador Island Link	0.89
NP Hydro Generation	3.19
DLP Hydro Generation	3.19
Exploits Generation	2.26

### 3.5 Current Generation and Reserve Plan

The most recent Hydro constructed increase in capacity on the System was the Granite Canal Hydroelectric Project, at 40 MW, in 2003. Since then, capacity has been added to the system by power purchases from the two wind farms at St. Lawrence and Fermeuse (27 MW each). However, energy from wind is non-dispatchable so the full capacity of these projects cannot be relied upon at peak times (the Strategist Models assume approximately 40% of the capacity is available at peak times).

Strategist Model results in 2008 projected an energy deficit to occur in 2012. This deficit moved out further into the future with subsequent Strategist Model analyses because of a reduction of load associated with the decline of paper production in the province. Residential and general service loads continued to grow, but the decline in industrial load meant that no new generation was required to meet the growing load. In addition, the construction date of the Vale processing facility at Long Harbour has been delayed several times, and that industrial load has yet to be added to the system. The most recent analysis in 2012 shows a capacity deficit occurring in 2015 and recommended the addition of a 50 MW combustion turbine by December 2015 as the least-cost solution to mitigate the anticipated deficit. The 2012 recommendation recognized that during early 2015, prior to the installation of the combustion turbine, the LOLH of the system would be greater than the 2.8 hour threshold. The short-term LOLH deficit was not inconsistent with some of Hydro's previous generation expansion decisions.

In the meantime, Hydro has been reconsidering the short-term LOLH deficit. There is a review ongoing to ensure the combustion turbine is still the best option given the system disruptions in January 2014, and to identify means to fully mitigate the 2015 deficit. Other options under consideration include the following (combination of two or more options may be developed to meet the potential deficit):

- Retain the diesel facility being installed at Holyrood for black start capability (presently under a lease-to-own arrangement for commissioning in March 2014).

1           Once installed, 10 MW can immediately be supplied to the system on a sustained  
2           basis. With some modifications, the facility can be made to deliver the full 14.6 MW  
3           peaking capacity to the grid;

- 4           • Enter into interruptible contracts with large Industrial Customers. Discussions with  
5           Industrial Customers (Corner Brook Pulp and Paper, Vale, and North Atlantic  
6           Refining) were initiated in fall 2013. These discussions are ongoing and options  
7           continue to be explored;
- 8           • Seek already built combustion turbines in the 50 to 100 MW range to supply deficit  
9           and black start at Holyrood. Preliminary discussions indicate these options may be  
10          able to meet the 2015 requirement. However, discussions with manufacturers,  
11          brokers, and owners are ongoing to determine the delivery times, operating  
12          experiences, the extent of modifications, and facilities required to connect to the  
13          Island Interconnected System;
- 14          • Initiate the supply of a new combustion turbine for the Holyrood site to supply  
15          deficit and black start functionality. All preliminary engineering is complete. With  
16          final approval by June 2014, this plant could be in-service by 2015/2016; and
- 17          • Continue and enhance conservation and demand management initiatives, with the  
18          focus on demand management. Work is being conducted to assess customer end-  
19          use options, with a view of providing demand management. This is considered a  
20          supplemental means of meeting the deficit and may provide further cost savings  
21          opportunities when combined with other options.

22  
23   The project or projects that will be implemented for the winter of 2015 are currently forecasted  
24   to be the last new island generation that will be required prior to the commissioning of Muskrat  
25   Falls and the Labrador Island Link in late 2017 or early 2018. Muskrat Falls and the  
26   interconnection with the North American grid will greatly enhance Hydro's capacity and  
27   reserve. It will be many years before Hydro has to again consider adding capacity to the System.

## **4 VENTYX REVIEW**

Hydro retained the services of Ventyx to provide an independent review of both the generation planning processes, which form the basis of Hydro's strategic plans and forecast, and Hydro's long and medium term load forecasting. The Ventyx report is included as Appendix 1 of this report.

In relation to generation planning processes, Ventyx was asked to:

- Review the overall planning process and assumptions used by Hydro in developing its current long-range and strategic forward looking plans;
- Provide commentary on existing planning processes and criteria and make recommendations as to specific improvements as required;
- Review the Strategist Model assumptions used by Hydro in developing its current long-range and strategic forward looking plans; and
- Provide commentary on the existing planning processes and criteria and make recommendations as to specific improvements as required.

Ventyx's review of the generation planning process included an examination of Nalcor Energy's documentation relating to the Muskrat Falls project, including the filings with the PUB and the various reviews, and Hydro's responses to Requests for Information from the PUB about the events this winter. Ventyx also conducted one-on-one interviews with Hydro staff.

### **4.1 LOLH Criterion**

Ventyx reviewed the results of Hydro's most recent capital planning study (2012) and the Strategist Model results, as shown in Table 3. Hydro currently uses an LOLH criteria of 2.80 hours per year.



**Table 3: Strategist Model LOLH Results**

<b>Year</b>	<b>Loss of Load Hours</b>	<b>Reserve Margin (Percent)</b>
2013	0.97	16.32
2014	2.59	12.28
2015	3.98	10.32
2016	2.73	12.21
2017	2.68	11.00

Ventyx indicates that the standard industry practice is to apply a LOLP of 0.1 days per year, or “one day in ten years.” However, it should be noted that the 0.1 days per year standard applies to interconnected utilities. For true “stand alone” utilities, the cost to achieve a 0.1 days per year standard is often cost prohibitive. In 1977, Hydro conducted a thorough analysis of system reserves and as a result recommended 0.2 days per year, or “one day in five years.” Hydro justified the 0.2 days per year over 0.1 days per year, based on the economics of meeting the more stringent requirement. For impact comparison, the incremental present value revenue requirements necessary to move from a reliability index of 1.0 days per year to 0.2 days per year was approximately \$24 billion and the incremental present value revenue requirements necessary to move from a reliability index of 0.2 days per year to 0.1 days per year was approximately \$17 billion. Simply stated, the cost to move from a reliability index of 0.2 days per year to 0.1 days per year was 71% of the cost to move from a reliability index of 1.0 days per year to 0.2 days per year. Ventyx concluded Hydro was justified in its decision to adopt a reliability index of 0.2 days per year at that time. For the purposes of Hydro’s planning criteria, it was necessary to translate the LOLP, which is based on the peak load of each of the 365 days, to an hourly equivalent LOLH. Benchmarking established that a LOLH of 2.8 hours per year was equivalent to a LOLP of 0.2 days per year, for Hydro’s system.

Ventyx concluded that, from a generation mix perspective, Hydro's system is "roughly" the same as it was in 1977 and, therefore, there is no reason to reassess its reliability standard of 0.2 days per year. The primary drivers which would prompt a utility to reassess its reliability standard include: resource mix, plant reliability and maintenance, and interconnections. In 1977, Hydro's system was 63% hydro and 37% thermal. Today, Hydro's system is 67% hydro and 33% thermal. In terms of plant reliability, the capacity weighted average effective forced outage rate in 1977 was 3.74% versus 4.05% today. From a system reliability standpoint, Hydro's current system is virtually equivalent to the system as it existed in 1977. However, Hydro expects to complete the Maritime Link to Nova Scotia in 2017. When Hydro interconnects with the North American grid, it should reassess its reliability standards in light of its access to new markets.

Ventyx concluded that Hydro's generation planning reserve criterion of a LOLH of 2.8 hours per year is prudent and consistent with standard industry practices. Hydro has consistently used the generation planning reserve criterion as an input to its capacity expansion optimization to ensure that all plans selected for comparison meet or exceed the minimum reliability threshold for a power system. Ventyx recommends that Hydro should continue with its generation planning reserve criterion.

Ventyx recommends that after completion of Hydro's interconnection with Nova Scotia and Muskrat Falls, Hydro should revisit its generation planning reserve criterion of 2.8 hours per year in light of the reliability benefits offered by the access to North American markets.

#### **4.2 Forced Outage Rates**

Ventyx reviewed Hydro's assumptions for forced-outage rates and concluded that they are consistent with industry standards.

For the purposes of this discussion, Ventyx focused on Hydro's largest aggregate resources that drive overall system reliability; Holyrood at 465.5 MW; and Bay d'Espoir at 592 MW. These two

plants comprise 1057.5 MW and represent 54.3% of Hydro's installed capacity. Hydro's CTs and other Hydro units have less impact upon reliability. The EFOR used in Hydro's generation planning and serving as an input to the Strategist Model is derived from the Canadian Electricity Association's (CEA) 2004 Report and is based on the period from January 1, 2000 through December 31, 2004. Ventyx compared these rates to current CEA data covering the period from January 1, 2008 through December 31, 2012. Table 4 lists the five year CEA capacity weighted average EFOR based on the most recent CEA data and the EFOR assumptions in Hydro's Strategist database.

**Table 4: Hydro EFOR Values**

<b>Unit Name</b>	<b>NLH Strategist Assumptions</b>	<b>NLH Average 2008 - 2012</b>
Holyrood	9.64%	10.69%
Bay d'Espoir	0.91%	0.41%

Hydro's overall assumptions are consistent with industry standards. While there might be some rationalization that a significant increased investment might improve Holyrood performance further, given the time until the infeed is realized, the age of the units and outage availability it appears that the time required to gain results will be longer than the relatively short timeframe to interconnection with the North American Grid.

Ventyx recommends that, since Holyrood is scheduled to be retired in the next 4 to 5 years, Hydro should model its EFOR close to the actuals currently being experienced with sensitivities on either side of the expected value. With respect to all other thermal units in the Strategist model (existing and future) Hydro should continue its practice of modeling with a more conservative estimate of EFOR for the units.

Ventyx also suggested that Hydro consider tying outage rates to typical maintenance cycles.

There is an inherent relationship between higher capital expenditures and maintenance corresponding to lower outage rates. However, it should be noted that a five-year rolling average will also account for these cycles. By ramping up the EFOR in the years leading up to a major maintenance cycle, Hydro would have a better picture of the near term, one to five year, view of system reliability. Alternatively, Hydro could also compute a break-even EFOR for each class of its generation. For example for the Holyrood Plant, the maximum EFOR would be between 9.7% and 9.8%. At this point, the unit's contribution to LOLH would exceed 2.80 hours per year.

### 4.3 Scenario Planning

Ventyx compared Hydro's planning process as a whole to the Ventyx Integrated Resource Planning (IRP) process as a measure of Hydro's conformance to accepted utilities practices and procedures. Ventyx's process is demonstrated in Figure 1.



Figure 1: Ventyx Integrated Resource Planning Process

1 A description of each step is included in the Ventyx report in Appendix 1.

2  
3 Ventyx found that Hydro's resource planning processes conform to the basic structure laid out  
4 in the Ventyx IRP process. All areas in Hydro's process were deemed as being acceptable, but  
5 some suggestions for improvement were offered in the areas of alternative development and  
6 risk assessment.

7  
8 In the development of alternatives, it was found that although existing demand-side programs  
9 were included in the development of the resource plan, there was a lack of additional demand-  
10 side alternatives. The use of demand-side alternative will not be effective to solve short term  
11 issues, but Ventyx recommends that the use of demand-side as alternatives be further explored  
12 post 2017, while there is ample capacity to cover requirements.

13  
14 In reviewing the documents, Ventyx noted that there is no formal risk assessment stage  
15 included in the planning process. Sensitivities were performed and included in the original  
16 documentation but focused mostly on commodity and costing assumptions. Ventyx  
17 recommended that the future scenario and sensitivity processes be expanded to include the  
18 impacts of extreme loads.

19  
20 Ventyx recommended that Hydro:

- 21 • Begin to explore the use of demand-side programs as a long-term alternative to future  
22 supply side alternatives post 2017; and
- 23 • Expand the risk analysis sensitivities to include several levels of load forecast  
24 uncertainty.

#### 25 26 **4.4 Generation Outlook 2014 to 2017**

27 Ventyx reviewed Hydro's current plans with respect to new generation to meet the deficiency  
28 in 2015. They consider the combustion turbine under consideration or other combustion  
29 options to be key resources for Hydro's near-term reliability. The current plan has the

1 combustion turbine commissioned in December of 2015. Without this unit, Ventyx calculates  
2 that Hydro would face LOLH reliability indices of 4.57 hours per year in 2015, 6.02 hours per  
3 year in 2016, and 5.71 hours per year in 2017 if the Labrador In-Feed is in service in December  
4 2017.

5  
6 Statistically, demand reduction is a slightly better alternative to generation additions, due to  
7 inherent uncertainty of generation forced outages. In order to reduce the expected 2015  
8 deficiency of 3.98 hours per year to 2.80 hours per year, Hydro would need to secure  
9 approximately 40 MW of either interruptible contracts with existing customers, or conservation  
10 and demand management initiatives, in addition to the nominal combustion turbine assumed.  
11 If that is not practical, then the difference can be made up from the remaining generation  
12 capacity options.

## 14 **5 KEY FINDINGS AND RECOMMENDATIONS**

15 This section describes the findings of Hydro's internal review and the independent reviews of  
16 Hydro's generation and reserve planning process.

### 18 **5.1 Internal Review**

19 The initial Hydro review concluded that the assumptions related to forced-outage rates in the  
20 Strategist Model were most likely to influence the results of the generation and reserve  
21 planning. Hydro determined that an independent, external review was the best way to  
22 evaluate the process.

### 24 **5.2 Prior Independent Reviews**

25 The 2011 Navigant Consulting Ltd review of Nalcor Energy's Gate 2 decision regarding the  
26 Muskrat Falls Project concluded that, "Nalcor's use of the Strategist Model in developing the  
27 two generation expansion alternatives is consistent with generally accepted utility practice."  
28 Available documentation for reliability assessment performed by Nalcor Energy was reviewed

by MHI in 2012. It concluded that the adequacy criteria of 2.8 hours per year of LOLH for resource planning, which considers both generation resource availability and economics, appears reasonable when compared to practices of other operating utilities.

### 5.3 Ventyx Review

The following table outlines the recommendations from the independent review by Ventyx.

**Table 4: Ventyx Recommendations**

Recommendation		Status
GRP1	Hydro should continue with its generation planning reserve criterion	No change required
GRP2	After interconnection in 2017, Hydro should revisit its generation-planning reserve criterion and its modelling of external markets.	In Hydro plans for post 2017
GRP3	Since Holyrood is scheduled to be retired in the next 4 to 5 years, Hydro should model its Equivalent Forced Outage Rate (EFOR) close to the actuals currently being experienced with sensitivities on either side of the expected value. With respect to all other thermal units in the Strategist model (existing and future) Hydro should continue its practice of modeling with a more conservative estimate of EFOR for the units.	No change required
GRP4	Hydro should compute a break-even EFOR for each class of its generation to determine the point at which a generator's EFOR will result in the system exceeding the LOLH criteria of 2.8 hours per year.	To be incorporated in capital submission addressing 2015 capacity deficit
GRP5	Hydro should develop a formal risk analysis process that utilizes scenarios and sensitivities to test the robustness of resource plans.	To be incorporated in capital submission addressing 2015 capacity deficit

## 1 **ACRONYMS**

2	CEA	-	Canadian Electricity Association
3	CDM	-	Conservation and Demand Management
4	CT	-	Combustion Turbine
5	CPW	-	Cumulative Present Worth
6	CCCT	-	Combined Cycle Combustion Turbines
7	DAFOR		De-rated Adjusted Forced Outage Rate
8	EFOR	-	Equivalent Forced Outage Rate
9	LOLH	-	Loss of Load Hours
10	LOLP	-	Loss of Load Probability
11	MW	-	Megawatts
12	n-1	-	measure of redundancy
13	O&M	-	Operation and Maintenance
14	PLF	-	Planning Load Forecast
15	PPA	-	Power Purchase Agreements
16	PETS		Project Execution and Technical Services
17	PUB	-	Board of Commissioners of Public Utilities



## Appendices

# 2014 Newfoundland and Labrador Hydro Planning Process Review

March 21, 2014

**Prepared for:**

Newfoundland and Labrador  
Hydro

**Prepared by:**

Ventyx, An ABB Company  
400 Perimeter Center Terrace, Suite 500  
Atlanta, GA 30346  
[www.ventyx.com](http://www.ventyx.com)

**Contact:**

Charles Adkins, Vice President  
(912) 228-4278

## Liability Note

Ventyx provides this document “as is” without warranty of any kind, either expressed or implied, including, but not limited to, the implied warranty of merchantability or fitness for a particular purpose. Ventyx may make changes or improvements in the equipment, software, or specifications described in this document at any time and without notice.

Ventyx has made every reasonable effort to ensure the accuracy of this document; however, it may contain technical inaccuracies or typographical errors. Ventyx disclaims all responsibility for any labor, materials, or costs incurred by any person or party as a result of their use or reliance upon the content of this document. Ventyx and its affiliated companies shall in no event be liable for any damages (including, but not limited to, consequential, indirect or incidental, special damages or loss of profits, use or data) arising out of or in connection with this document or its use, even if such damages were foreseeable or Ventyx has been informed of their potential occurrence.

## Contents

Executive Summary.....	3
Study Objective .....	6
VENTYX .....	7
Strategist® .....	8
Incident Description.....	8
Issues within Scope.....	9
Load Forecasting .....	9
Generation Planning Criteria.....	9
Scenario/Sensitivity Planning.....	10
Load Forecasting .....	10
Background .....	10
Conclusions.....	12
Recommendations.....	16
Generation Planning Reserve Criterion .....	17
Background .....	17
Conclusion .....	22
Recommendation .....	22
Generation Forced Outage Rates .....	23
Background .....	23
Conclusion .....	25
Recommendation .....	25
Scenario Planning.....	26
Background .....	26
Conclusions .....	28
Recommendations.....	29
Generation Outlook 2014 to 2017 .....	29
Summary of Recommendations .....	31
Appendices.....	34

## Executive Summary

Over the weekend of January 3<sup>rd</sup>, 2014, Newfoundland and Labrador Hydro (“NLH”) experienced a series of largely unrelated events that led to four days of rolling blackouts. On January 17<sup>th</sup>, The Board of Commissioners of Public Utilities (“the Board”) initiated a process to gather information from NLH and Newfoundland Power (“NP”) with a focus on whether load requirements on the Island Interconnected system can be met in the near term. Specific issues to be addressed include: asset readiness, maintenance practices, load forecasting, planning criteria and assumptions, equipment performance and reliability, emergency preparedness, system response, and restoration efforts.

NLH retained the services of Ventyx, Inc. to provide a review of both the generation planning processes that form the basis of NLH’s strategic plans and forecasts, and NLH’s long term (20 year) and medium-term (5 year) load forecasting. Ventyx has not found any evidence that either the generation planning process or the load forecasting process have contributed to the events of January.

In the near term, NLH’s current resource expansion plan is within the reliability criteria in all calendar years except 2015.

	Loss of Load Hours (Hours)	Reserve Margin (Percent)
2013	0.97	16.32
2014	2.59	12.28
2015	3.98	10.32
2016	2.73	12.21
2017	2.68	11.00

The previous table is based on the assumption that a new 50 MW CT, is in service December of 2015. If that unit does not achieve that commission date or an equivalent resource is not implemented the LOLH would increase to 4.57 in 2015 and 6.02 in 2016.

NLH is currently considering six options<sup>1</sup> for meeting the expected LOLH in 2015. Each of these options offers the possibility to reduce the system LOLH.

1. Retain the 16 MW (10 MW to the system) diesel facility at Holyrood;
2. Review what is needed to make the remaining 4.6 MW of diesel power at Holyrood available to the system by plant modifications to increase equipment ratings to deliver 14.6 MW capacity;
3. Enter into interruptible contracts with large Industrial customers;
4. Seek already built combustion turbines in the 50 to 100 MW range to supply deficit and blackstart;
5. Initiate the supply of a new 60 MW (nominal) combustion turbine for the Holyrood site to supply deficit and blackstart; and
6. Continue and possibly enhance conservation and demand management initiatives, with the focus on demand management.

The new 50 MW (nominal) combustion turbine or other combustion turbine options are key resources for NLH's near term reliability of supply. The current plan has this unit commissioned in December of 2015. Without this unit, NLH would face LOLH reliability indices of 4.57 hours/year in 2015, 6.02 hours/year in 2016, and 5.71 hours/year in 2017, the Labrador Infeed is in service in December of 2017.

Statistically, demand reduction is a slightly better alternative to generation additions due to inherent uncertainty of generation forced outages. In order to reduce the expected 2015 LOLH of 3.98 hours/year to 2.80 hours/year, in addition to the nominal combustion turbine assumed, NLH would need to secure approximately 40 MW of either interruptible contracts with existing

---

<sup>1</sup> Newfoundland and Labrador Hydro, *PUB-NLH-062* (Newfoundland and Labrador Hydro: Board Response, February 2014)

customers or conservation and demand management initiatives. If that is not practical, then the difference can be made up from the remaining generation capacity options.

Furthermore, NLH uses reasonable estimates for generation forced outage assumptions as compared to Canadian Electricity Association (CEA) five year averages and the five year averages for its own equipment. The assumptions in Strategist are based upon data collected between 2000 and 2004. The generation forced outage assumption for Holyrood and Bay D'Espoir are 9.64%<sup>2</sup> and 0.91%<sup>3</sup>, respectively, and they contributed to the forecast 2015 LOLH of 3.98 hours/year. Recent data from NLH operating data, from 2008 to 2012, indicates that the historical performance for Bay D'Espoir has improved to 0.41% and worsened for Holyrood to 10.69%. These figures are relatively consistent with current performance, however if the generation forced outage assumptions were improved for Bay D'Espoir, the 2015 LOLH would drop to 3.69 hours/year. If the generation forced outage assumptions were changed for Holyrood the contribution to the 2015 LOLH would increase to 4.49 hours/year.

The primary drivers are the Holyrood units. Focusing only on Holyrood, if the Holyrood units could achieve an annual forced outage rate of 8.48% or less then the system would achieve a LOLH of 2.8 hours/year. Recognizing the age of these assets, this may not be practical in the short term and continuing the current assumptions is prudent planning, particular for the near term. As well, there is merit in assessing some variation of this expected performance to gauge sensitivity on the LOLH result.

The current projected plan is based upon a normalized weather forecast. Weather normalization is an industry standard process that adjusts actual peak outcomes to what would have happened under normal weather conditions. Beyond the next seven days weather forecasting is complex and not always accurate. Therefore, NLH should look at a severe

---

<sup>2</sup> Source: CEA Typical 2000-2004. Table 6.2.2 100-199 MW Classification for Holyrood.

<sup>3</sup> Source: NLH Operating Experience between 2000-2004. Weighted Average based on Bay D'Espoir units & Hinds Lake, Upper Salmon, Cat Arm and Paradise River

weather sensitivity to gauge how the system might respond to greater than expected demand particularly in making near term investment decisions.

Specific process recommendations:

- Load Forecasting
  - Continued surveying of the customer base in terms of both average energy use and saturations of heating.
  - Develop alternative load forecasts in both the scenario development and the sensitivity analysis phases.
- Generation Planning
  - NLH should continue forward with its generation planning reserve criterion.
  - After NLH's interconnections are established in 2017, NLH should revisit both their generation planning reserve criterion and their modeling of external markets.
  - NLH should continue forward with its practice of maintaining a more conservative estimate of EFOR for the units.
  - Compute a break-even EFOR for each class of its generation to determine the point at which a generator's EFOR will result in the system exceeding the LOLH criteria of 2.8 hours/year
- Develop a formal risk analysis process that utilizes scenarios and sensitivities to test the robustness of resource plans.

## Study Objective

Over the weekend of January 3<sup>rd</sup>, 2014, NLH experienced a series of events that led to four days of rolling blackouts. On January 17<sup>th</sup>, The Board initiated a process to gather information from NLH and NP with a focus on whether load requirement on the Island Interconnected system can be met in the near term. Specific issues to be addressed include: asset readiness, maintenance practices, load forecasting, planning criteria and assumptions, equipment performance and reliability, emergency preparedness, system response, and restoration efforts.



NLH retained the services of Ventyx, Inc. to provide a review of both the generation planning processes that form the basis of NLH's strategic plans and forecast and NLH's long term (20 year) and medium term load (5 year) forecasting. Specifically, Ventyx was asked to review:

- The overall planning process and assumptions used by NLH in developing their current long range and strategic forward looking plans;
- Provide commentary on the existing planning processes and criteria and make recommendations as to specific improvements as required;
- Review of the process and assumptions used by NLH in developing their current long range load forecast and shorter term operational forecasts;
- Provide commentary on the load forecasting processes, criteria and assumptions and make recommendations as to specific improvements as required;
- Review of the Strategist model assumptions used by NLH in developing their current long range and strategic forward looking plans; and
- Provide commentary on the existing planning processes and criteria and make recommendations as to specific improvements as required.

## VENTYX

Ventyx brings a dedicated team of expert consultants that combines experience, industry knowledge, market knowledge, and software expertise to support consulting engagements. Ventyx provides professional consulting services to energy companies in the areas of integrated resource planning, market price forecasting, resource evaluation and planning, trading and settlement, and electric transmission economic analysis. Ventyx has worked with NLH both in support of Ventyx's Strategist software and .with analytical modeling to evaluate the economic and system impacts of the Muskrat Falls hydro project as well as the Maritime Link project with Nova Scotia. Ventyx conducted multiple analytical modeling studies of this pair of projects over a three year period that also included analytical modeling covering the provinces of New Brunswick, Prince Edward Island, Nova Scotia and Newfoundland Labrador as well as surrounding market areas in Quebec, New York and New England for the Atlantic Energy Gateway project

## Strategist®

Strategist is a computer software system, developed by Ventyx, LLC, which supports electric utility decision analysis and corporate strategic planning. Strategist is available as a demand-side management analysis system, as a least cost resource optimization system, as a comprehensive planning tool for quick evaluation of hundreds of alternatives, as a finance and rates planning system and as selected application modules that complement planning capabilities already in place. Strategist's advantage as an integrated planning system is its strength in all functional areas of utility planning. Strategist allows analysts to address all aspects of an integrated planning study at the depth and accuracy level required for informed decisions. Hourly chronological load patterns are recognized. Production cost simulations are comprehensive, yet fast. The production costing procedure consists of two stages. In the first stage, the operation of hydro generation and sale and purchase transactions are simulated. The pumped storage facilities, economic energy interchange, and direct load control programs are then economically dispatched based on the marginal cost curve of the system. The result of this first stage is the remaining annual or seasonal thermal load duration curve. In the second stage, the expected operation of the thermal generating units within the year is simulated by a probabilistic technique. The results are the production costs and system reliability indices. The PROVIEW (PRV) Module is a resource planning model which determines the least-cost balanced demand and supply plan for a utility system under prescribed sets of constraints and assumptions. PROVIEW incorporates a wide variety of expansion planning parameters including alternative technologies, unit conversions, cogenerators, unit capacity sizes, load management, marketing and conservation programs, fuel costs, reliability limits, emissions trading and environmental compliance options in order to develop a coordinated integrated plan which would be best suited for the utility. The PROVIEW module works in concert with the GAF Module to simulate the operation of a utility system. PROVIEW's optimization logic then determines the cost and reliability effects of adding resources to the system, or modifying the load through demand-side management (DSM) or marketing programs.

## Incident Description

Over the weekend of January 3<sup>rd</sup>, 2014, NLH experienced a series of events that led to four days of rolling blackouts.

## Issues within Scope

The Board initiated a process to gather information from NLH and NP with a focus on whether load requirement on the Island Interconnected system can be met in the near term. Specific issues to be addressed include: asset readiness, maintenance practices, load forecasting, planning criteria and assumptions, equipment performance and reliability, emergency preparedness, system response, and restoration efforts. The scope of this report is focused on the load forecasting and planning criteria and assumptions. With the NLH system setting record peaks during this unfortunate event, the question of load forecast accuracy is raised. The primary planning criteria that are related to an event of this nature are planning reserves and generation forced outage rates. Finally, the issue of load forecasting and planning criteria is enveloped in the overall process of sensitivity analysis to address the inherent risk of the NLH portfolio.

## Load Forecasting

Load Forecasting is the process of estimating the demand that customers will place on the system. The process for load forecasting is, generally, defined by the time horizon of a specific forecast. Short term forecasts are hourly in nature and cover the time horizon from next hour to seven days to support short term unit commitment and scheduling. Short term forecasts are focused on the most recent historical relationship of weather to load aligned with short term forecasts of weather conditions. As the load forecasting process passes from the short term to longer term, the reliability of forecasted weather drops dramatically. Longer term forecasts are typically represented as annual peaks and energies, with monthly detail, to support budgeting planning. Longer term forecasts rely on the historical relationships of weather to load along with seasonal patterns and economic drivers.

## Generation Planning Criteria

The generation planning criteria for planning reserves and generation forced outage rates combine to form a prediction of the expected LOLH reliability index. This reliability index forms the foundation of a minimum reliability threshold of 2.8 hours/year. For each year of the NLH planning horizon, the system is designed to maintain sufficient generation planning reserves to ensure the minimum reliability threshold is met. Generation planning reserves are the MW

difference between available capacity and normalized peak demand that are available to meet unforeseen increases in demand, such as extreme load, and unexpected outages of existing capacity. Forecasted trends in LOLH identify whether generation capacity additions are keeping pace with load growth.

## Scenario/Sensitivity Planning

Scenario planning is a strategic planning methodology used to identify and assess the inherent risks and benefits of a flexible long term plan. Scenario planning recognizes that many factors may combine in complex ways to create sometimes surprising futures. Scenario planning seeks to identify the causal relationship between factors and demonstrate a plans flexibility to adapt. Scenario planning develops an internally consistent story about the conditions in which the system might be operating in the future that differs from baseline assumptions in sometimes significant ways and usually involves alterations to all of the assumptions at one time. Sensitivity planning varies each of the assumptions either one at a time or in correlated groups to determine how sensitive the results are to changes in the assumptions. These planning techniques are important when there are variables such as weather that can potentially impact the reliability of the system.

## Load Forecasting

### Background

Load Forecasting is the process of estimating the demand that customers will place on the system. The process for load forecasting is, generally, defined by the time horizon of a specific forecast. Short term forecasts are hourly in nature and cover the time horizon from next hour to seven days to support short term unit commitment and scheduling. Short term forecasts are focused on the most recent historical relationship of weather to load aligned with short term forecasts of weather conditions. The short term forecasts prepared by NLH use a neural network forecasting approach using the Nostradamus modelling software.

A medium term forecast that covers a time horizon of five years is used for budgeting and near-term supply adequacy. The medium term forecasts are a combination of the NP forecast for

their service territory and NLH economic and regression processes for their rural customers and customer input for the industrial loads.

Longer term forecasts cover the time horizons of 20 years and are typically represented as annual peaks and energies, with monthly detail, to support long term generation planning. The long term forecast is performed by NLH using economic and regression techniques to forecast NP, NLH rural loads, and Industrial customer forecasts of their loads. The long term forecasts rely on the historical relationships of weather to load along with seasonal patterns and economic drivers.

The review of the load forecasting process included a review of the original filings with the Board concerning the Muskrat Falls Project, review of two independent, detailed reviews of the project, a review of the responses to the Board of questions concerning the incidents this winter, and one-on-one interviews with both NLH and NP forecasting staff. Since the independent review of the load forecast conducted by Manitoba Hydro International (“MHI”) was a detailed review of the assumptions, the review described in this report focused on the methodology and a look at the validity and accuracy of the forecast. Personal interviews were held with the staffs of NLH and NP to ascertain the sequencing and procedures of each company and the interfacing and integration of the individual component forecasts into a single product. Of particular interest was the accuracy of the winter peak as it applies to the incidents described above.

- The interviews with the NP load forecasting staff revealed the medium term forecast of NP service territory energy was performed for Domestic, General Services and Area and street light classes. Although the process was different for each class, the basic process is an average use methodology that applied econometric forecasting techniques to determine average use per consumer that was then applied to a customer growth forecast.
- The medium term peak demand for NP was developed using an average load factor methodology that calculates a 15 year average load factor that is then applied to the medium term energy forecast to determine the NP service territory Winter Peak demand. This is a standard utility practice.
- The NLH long term load forecasting process is a combination of econometric and regression analyses to determine the energy and peak demand for NP and the NLH rural

groups with industrial energy and demand requirements conditioned by individual customer input .

- The long term peak for NP is forecast by NLH using regression analyses that link NP peak demand to weather, domestic electric heat customer growth, general service sales growth and other economic factors. The peak for the NLH rural group is calculated using a long term historical load factor method that is applied to the forecasted energy. The industrial peak is developed through direct input of existing industrial customers. No forecast is made of potential new industries unless it is fairly certain that a change is going to be made either through government action or a committed industrial customer.

NLH uses historical hourly shapes to develop typical 168 hourly week shapes for each month of the year. These typical shapes are applied to each year of the study and are adjusted by the Strategist Load Forecast Adjustment (“LFA”) module to meet the data entered for peak and energy from the forecast. NLH has not updated the historical data since 2002 and is scheduled to perform the update in the next 12 months as part of the next generation expansion planning exercise. Since the system has had a fairly stable load factor and since the LFA continuously modifies the shape to meet the forecast this should not impact the results of the studies. This would only be a problem if NLH was evaluating new Conservation and Demand Management (“CDM”) or time dependent programs such as time-of-day rates.

NLH has elected to set the study period to 50 years so that it would cover the financing period of the Muskrat Falls project. This is typically performed using either Economic Carrying Charge calculations or infinite end-effects with a shorter study period of twenty years. However, after discussion with NLH planning staff Ventyx determined that the manner in which they performed the extension of the load forecast and other model data was consistent with the Strategist end-effects methodology.

## Conclusions

The methodology used by both NP and NLH are consistent with accepted utility practices. It has been noted by another independent review, by MHI, that the process could be improved by

changing to an end-use forecast. It is Ventyx's opinion, based on experience, the complexity and time to generate an end-use forecast would not significantly improve the demand forecast in the mid-term. This is also true since the existing methodology aligns with survey results of the major end-use on the system which is electric space heating.

The econometric methods being used by NLH are prudent and well validated. The regression equations all have statistical coefficients of determination ( $R^2$ ) that are in the very high range. The  $R^2$  can be interpreted as the percent of variation in the predicted value that is explained by the given variables. Table 1 enumerates the  $R^2$  for each of the equations. The closer an  $R^2$  value is to 100% the better the fit of the equation to the data provided. The  $R^2$  for the regression equations that directly impact the forecast of system peak demand in the long term are included below.

Equation	R <sup>2</sup>
<b>NP Domestic Class</b>	
Customer Additions	93.4%
Penetration of Elect. Heating	88.5%
Conversion of Non-Elect Heat	78.9%
<b>NP General Service Class</b>	
Electric Heat Customer Load	99.9%
<b>NLH Rural Domestic Class</b>	
Average Use	98.1%
<b>NLH Rural General Service Class</b>	
Energy	99.6%
<b>NP Peak</b>	99.7%

Table 1 Coefficients of Determination<sup>4</sup>

No attempt was made in this review to verify or validate the actual data used since a previous report was issued by MHI showing a detailed discussion of the data. It is obvious weather has a significant impact on the resulting energy and peak demand forecasts. NLH's forecasting models include weather variables to account for the impacts due to changing weather conditions through the historical period. However, what is missing is an evaluation of the energy and demand impacts due to extreme weather conditions. These extremes should be evaluated using sensitivities and scenario planning techniques.


Figure 1, shows a comparison of the forecasted winter months peaks to the actual peaks for the system for the years 2004 to December 2013. Since 2004 the actual winter peaks have consistently been below the forecasted peaks with the exception of seven months out of forty winter months that the actual has been higher than the forecast. However, since those seven times do not occur in the same month it would suggest that there was some random pattern

---

<sup>4</sup> Manitoba Hydro International, *MHI-Report-Volume II-Load Forecast* (February 2012)



such as weather that is impacting the actual. A review of the deviations shows that it is largely weather that impacts all the discrepancies. As indicated by the red bars, the actuals are consistently less than the forecast because NLH has experienced a period of warmer than normal peak weather conditions over this period. The December 2013 discrepancy was impacted additionally by the “exceptional” loads resulting from unavailable Avalon generation that resulted in higher system demand loads than expected. If a variable such as the number of customers was off it would be impacting the forecast for all winter months in that period.

Figure 1<sup>5</sup>

## Recommendations

It was noted above that Ventyx does not believe it is desirable to change the forecast methodology to an end-use model. Primarily this is due to the increased complexity and cost, but it is also noted above that the major end-use on the system is electric heat and is already included in the forecast model and thus capturing the majority of any additional detail accuracy

---

<sup>5</sup> Newfoundland and Labrador Hydro, *PUB-NLH-011* (Newfoundland and Labrador Hydro: Board Response, February 2014)

benefits that would be expected from an end use model. Since the  $R^2$  for the two regression equations involving heating penetrations were 79% and 89% it would be advisable that NLH continue to refine their models with respect to these two variables. This can be further enhanced through continued surveying of the customer base in terms of both average use and saturation of this end use.

The above discussion has been in terms of the base-case scenario. Later in the report, Ventyx will discuss using a formal risk assessment process that includes the evaluation of plans under extreme weather conditions. As such, it will be important to develop alternative load forecasts in both the scenario development and the sensitivity analysis phases.

## Generation Planning Reserve Criterion

### Background

The purpose of a Generation Planning Reserve Criterion is to establish the minimum reliability threshold for a power system. The reliability of a power system is defined as the probability of providing customers with continuous service of a satisfactory nature. Reliability is one of the primary factors that drive the planning, design, operation, and maintenance of a power system. The most common index for reliability is the Loss of Load Probability (“LOLP”) which is “the probability of the system load exceeding the available generating capacity under the assumption that the peak load of each day lasts all day.”<sup>6</sup> Through a series of analytical processes the reliability index, LOLP, is translated to a reserve criterion stated in terms of Loss of Load Hours (“LOLH”) or a defined reserve margin percentage. In Strategist, Loss of Load Hours is the expected total number of hours a year during which the utility will not be able to serve all of its customers. The percent reserve margin is based on the reserve margin at the time of the annual peak and defined as the amount of installed reserves, in MW, divided by the

---

<sup>6</sup> J. Endrenyi, *Reliability Modeling in Electric Power Systems* (Ontario Hydro: John Wiley & Sons, 1978), 4

system peak demand, in MW. This reserve criterion serves as an input to capacity expansion optimization to ensure that all plans selected for comparison meet or exceed the minimum reliability threshold for a power system.

NLH's capacity planning reserve criterion for capacity planning is "The Island Interconnected System should have sufficient generating capacity to satisfy a Loss of Load Hours ("LOLH") expectation target of not more than 2.8 hours per year."<sup>7</sup> The LOLH target is based upon a Loss of Load Probability of 1 day in five years or, more commonly denoted as, 0.2 days per year. In 1977, the NLH System Planning department determined that "The LOLP index to be adopted depends upon the availability of capital. System Planning feels that a .1 days/year is not realistic and would suggest .2 days/year as an optimum value to aim for".<sup>8</sup> The results of NLH's recent 2012 capital planning study, 2012 DCL-PLF IT1-A-0801-\_R-105 FE-1 Strategist 4.4.1, are enumerated in Table 2.

	Loss of Load Hours (Hours)	Reserve Margin (Percent)
2013	0.97	16.32
2014	2.59	12.28
2015	3.98	10.32
2016	2.73	12.21
2017	2.68	11.00

Table 2 Expected Loss of Load Hours

---

<sup>77</sup> PUB-NLH-008

<sup>8</sup> System Planning Department, *Recommended Loss of Load Probability (LOLP) Index for Establishing Generation Reserve Additions* (Newfoundland Labrador Hydro: internal memo, May 16, 1977), 19

Previous table is based on the assumption that a new 50 MW CT, is in service December of 2015. If that unit does not achieve that commission date the LOLH would increase to 4.57 in 2015 and 6.02 in 2016.

NLH is currently considering six options<sup>9</sup> for meeting the expected LOLH in 2015. Each of these options offers the possibility to reduce the system LOLH.

1. Retain the 16 MW (10 MW to the system) diesel facility at Holyrood;
2. Review what is needed to make the remaining 4.6 MW of diesel power at Holyrood available to the system by plant modifications to increase equipment ratings to deliver 14.6 MW capacity;
3. Enter into interruptible contracts with large Industrial customers;
4. Seek already built combustion turbines in the 50 to 100 MW range to supply deficit and blackstart;
5. Initiate the supply of a new 60 MW (nominal) combustion turbine for the Holyrood site to supply deficit and blackstart; and
6. Continue and possibly enhance conservation and demand management initiatives, with the focus on demand management.

The new 60 MW (nominal) combustion turbine or other combustion turbine options are key resources for NLH's near term reliability of supply. The current plan has this unit commissioned in December of 2015. Without this unit, NLH would face LOLH reliability indices of 4.57 hours/year in 2015, 6.02 hours/year in 2016, and 5.71 hours/year in 2017, the Labrador Infeed is in service in December of 2017.

Statistically, demand reduction is a slightly better alternative to generation additions due to inherent uncertainty of generation forced outages. In order to reduce the expected 2015 LOLH of 3.98 hours/year to 2.80 hours/year, NLH would need to secure approximately 40 MW of either interruptible contracts with existing customers or conservation and demand

---

<sup>9</sup> Newfoundland and Labrador Hydro, *PUB-NLH-062* (Newfoundland and Labrador Hydro: Board Response, February 2014)

management initiatives. If that is not practical, then the difference can be made up from the remaining generation capacity options.

Furthermore, NLH uses reasonable estimates for generation forced outage assumptions as compared to Canadian Electricity Association (CEA) five year averages and the five year averages for its own equipment. The assumptions in Strategist are based upon data collected between 2000 and 2004. The generation forced outage assumption for Holyrood and Bay D’Espoir are 9.64%<sup>10</sup> and 0.91%<sup>11</sup>, respectively, and they contributed to the forecast 2015 LOLH of 3.98 hours/year. Recent data from NLH operating data, from 2008 to 2012, indicates that the historical performance for Bay D’Espoir has improved to 0.41% and worsened for Holyrood to 10.69%. These figures are relatively consistent with current performance, however if the generation forced outage assumptions were improved for Bay D’Espoir, the 2015 LOLH would drop to 3.69 hours/year. If the generation forced outage assumptions were changed for Holyrood the contribution to the 2015 LOLH would increase to 4.49 hours/year.

The primary drivers are the Holyrood units. Focusing only on Holyrood, if the Holyrood units could achieve an annual forced outage rate of 8.48% or less then the system would achieve a LOLH of 2.8 hours/year. Recognizing the age of these assets this may not be practical in the short term and continuing the current assumptions is prudent planning, particular for the near term. As well there is merit in assessing some variation of this expected performance to gauge sensitivity on the LOLH result.

The standard industry practice is to apply a LOLP of 0.1 days/year, or “one day in ten years”. However, it should be noted that the 0.1 days/year standard applies to interconnected utilities. For true “stand alone” utilities, the cost to achieve a 0.1 days/year standard is often cost prohibitive. In 1977, NLH conducted a thorough analysis of system reserves and concluded with the recommendation of 0.2 days/year, or “one day in five years”. NLH justified the 0.2

---

<sup>10</sup> Source: CEA Typical 2000-2004. Table 6.2.2 100-199 MW Classification for Holyrood.

<sup>11</sup> Source: NLH Operating Experience between 2000-2004. Weighted Average based on Bay D’Espoir units & Hinds Lake, Upper Salmon, Cat Arm and Paradise River

days/year over 0.1 days/year based on the economics of meeting the more stringent requirement. The incremental present value revenue requirements necessary to move from a reliability index of 1.0 days/year to 0.2 days/year was approximately \$24 Billion<sup>12</sup>. The incremental present value revenue requirements necessary to move from a reliability index of 0.2 days/year to 0.1 days/year was approximately \$17 Billion<sup>13</sup>. Simply stated, the cost to serve the last tenth of the reliability index was 71% of the cost to serve the total of the first eight tenths of the reliability index. NLH was justified in its decision to adopt a reliability index of 0.2 days/year.

From a generation mix perspective, the NLH system is “roughly” the same as it was in 1977; there is no reason to reassess its reliability standard of 0.2 days/year. The primary drivers that would prompt a utility to reassess its reliability standard include: resource mix, plant reliability and maintenance, and interconnections. In 1977, the NLH system was 63% hydro and 37% thermal. Today, the NLH system is 67% hydro and 33% thermal. In terms of plant reliability, the capacity weighted average effective forced outage rate in 1977 was 3.74% versus 4.05% today. From a system reliability standpoint, the NLH system is virtually equivalent to the system in 1977. However, NLH expects to complete the Maritime Link to Nova Scotia in 2017. When NLH interconnects with the North American grid, NLH should reassess its reliability standards in light of their access to new markets.

Loss of Load Probability is a characterization of the adequacy of the generation within a system to serve the load of the system. It is important to note that LOLP does not represent the reliability of the bulk transmission or distribution systems. For the purposes of NLH’s planning criteria, it was necessary to translate the LOLP, which is based on the peak load of each of the 365 days, to an hourly equivalent, LOLH. “When Hydro switched from SYPCO generation

---

<sup>12</sup> Ibid, Table V. Grand Total (0.2) 2,896,178 (1977 K\$) minus Grand Total (1) 2,872,516 (1977 K\$) equals 23,662 (1977 K\$).

<sup>13</sup> Ibid. Table V. Grand Total (0.2) 2,912,924 (1977 K\$) minus Grand Total (1) 2,896,178 (1977 K\$) equals 16,746 (1977 K\$). 16,746 is 70.07% of 23,622.

planning software to PROSCREEN II [now called Strategist], it was necessary to switch to a Loss of Load Hours (LOLH) criterion. Benchmarking established that a LOLH of 2.8 hours per year was equivalent to a LOLP of 0.2 days per year, for Hydro's system."<sup>14</sup>

In 2017, the Maritime Link to Nova Scotia will be completed. Post 2017, NLH will be interconnected with the rest of the North American grid. In addition, there will be a long term sales agreement with Nova Scotia that will provide scheduling flexibility. NLH's current long term planning system does not reflect the reliability benefits of these incremental additions to the NLH portfolio.

## Conclusion

NLH's generation planning reserve criterion of a LOLH of 2.8 hours per year is prudent and consistent with standard industry practices. NLH has consistently used the generation planning reserve criterion as an input to their capacity expansion optimization to ensure that all plans selected for comparison meet or exceed the minimum reliability threshold for a power system.

## Recommendation

NLH should continue forward with its generation planning reserve criterion.

After completion of NLH's interconnection with Nova Scotia and Muskrat Falls, NLH should revisit their generation planning reserve criterion of 2.8 hours/year in light of the reliability benefits offered by the access to North American markets. It may be possible that this approach to reserve criterion, if still appropriate may be improved at minimum cost. In addition, NLH should continue their on-going efforts to include the modeling of external markets in Strategist to capture both the reliability benefits and market value of market interactions. In order to

---

<sup>14</sup> Newfoundland and Labrador Hydro, *PUB-NLH-056* (Newfoundland and Labrador Hydro: Board Response, February 2014),1



allow for a better understanding of the potentials of economy interchange Ventyx recommends NLH continues to pursue the Network Economy Interchange (“NEI”) modeling effort.

## Generation Forced Outage Rates

### Background

The purpose of generation forced outage rates in generation planning is to represent the probability that a specific unit will not be available for service when required. Generation Planning periodically confirms the resource adequacy of a system through detailed reliability simulations that compare the expected load profiles with specific generating unit forced outage rates and maintenance schedule to determine LOLH values. A typical unit’s contribution to resource adequacy is typically a function of the unit’s capacity and its equivalent forced outage rate (“EFOR”). NLH uses the convention Derated Adjusted Forced Outage Rate (“DAFOR”) which is known as EFOR as used by the North American Electric Reliability Council<sup>15</sup>. For the purposes of this report EFOR and DAFOR have the same meaning. A unit’s equivalent forced outage rate is defined according to the following formula:

---

<sup>15</sup> Roy Billinton, *Reliability Data Requirements, Practices and Recommendations* (Department of Electrical Engineering University of Saskatchewan) page 55.

$$EFOR = \frac{FOH + EFDH}{FOH + SH + Synchronous\ Hrs + Pumping\ Hrs + EFDHRS} \times 100\%$$

Where:

*FOH* – Forced Outage Hours

*EFDH* – Equivalent Forced Derated Hours

*SH* – Service Hours

*Synchronous Hrs* – Synchronous Condensing Mode Hours

*Pumping Hrs* – All hours pumped storage unit in pumping mode

*EFDHRS* – Equivalent Forced Derated Hours during Reserve Shutdowns

For the purposes of this discussion, Ventyx focused on NLH's largest aggregate resources that drive overall system reliability, Holyrood, 465.5 MW; and Bay D'Espoir, 592 MW. These two plants comprise 1057.5 MW and represent 54.3% of NLH's installed capacity. The EFOR used in NLH's generation planning and serving as an input to Strategist is derived from the Canadian Electrical Association's ("CEA") 2004 Report and is based on the period from January 1, 2000 through December 31, 2004. Ventyx compared these rates to the current CEA data covering the period from January 1, 2008 through December 31, 2012. NLH's other smaller CT's and Hydro units have less impact upon reliability.

Table 3 lists the five year CEA capacity weighted average EFOR based on the most recent CEA data and the EFOR assumptions in NLH's Strategist database.

Unit Name	NLH Strategist Assumptions	NLH Average 2008 - 2012
Holyrood	9.64%	10.69%
Bay D'Espoir	0.91%	0.41%

Table 3

## Conclusion

NLH's overall assumptions are consistent with industry standards. While there might be some rationalization that a significant increased investment might improve Holyrood performance further, given the time until the infeed is realized, the age of the units and outage availability it appears that the time required to gain results will be longer than the relatively short timeframe to interconnection with the North American Grid.

## Recommendation


Since Holyrood is scheduled to be retired in the next 4 to 5 years NLH should model its EFOR close to the actuals currently being experienced with sensitivities on either side of the expected value. With respect to all other thermal units in the Strategist model (existing and future) NLH should continue its practice of modeling with a more conservative estimate of EFOR for the units. However, one refinement that NLH could make to its EFOR assumptions would be to tie the level of EFOR to typical maintenance cycles. There is an inherent relationship between higher capital expenditures and maintenance corresponding to lower EFOR. However, it should be noted that a five year rolling average will also account for these cycles. By ramping up the EFOR, in the years leading up to a major maintenance cycle, NLH would have a better picture of the near-term, one to five year, view of system reliability.

Alternatively, NLH could also compute a break-even EFOR for each class of its generation resources. For example consider the Holyrood Plant, for which the maximum EFOR would be between 9.7% and 9.8%. At this point, the units' contribution to LOLH would exceed 2.8 hours/year.

## Scenario Planning

### Background

The purpose of this part of the review is to examine the NLH planning process with respect to accepted utility practices and procedures. The standard that the NLH planning process was compared is the Ventyx Integrated Resource Planning (“IRP”) process. This process was developed and used by Ventyx in its worldwide consulting practice.



© Ventyx, an ABB Company

Figure 2 IRP Planning Process

Description of each step:

- **Planning Policies Review** – This is the initial IRP project planning step in which the objectives of the IRP are set up. This includes the review of all of the rules and constraints that must be met in performing the planning process
- **Data Assumptions** – In this step all of the data assumptions are gathered and vetted. This includes the operating assumptions of all existing and proposed future alternatives, commodity prices, environmental and market prices, and transmission limits.
- **Develop Alternatives** – The simulation models for the various alternative Demand-side, Supply-side and market/transmission options are developed.
- **Portfolio Optimization** - In this step the potential resource alternatives are pre-screened using economic and operational methods. Through the use of optimization software, such as Strategist, one or more optimal plans are developed that meet a set of defined attributes and constraints.
- **Risk Assessment** - This step takes optimized plans from alternative scenarios and subjects them to sensitivity analysis to determine the impact of changes in assumptions to results. This step also determines the robustness of optimal plans to statistical distributions of sensitive variables. Then using multi-criteria decision making analysis techniques determines the trade-off between competing attributes such as risk and least cost.
- **Operation Analysis** – Selected plans are then further analyzed in terms of financial viability and operational constraints such as hydrological studies.
- **Recommended Plan and Action Plan** - The results of all the above steps is a recommended plan that the utility wished to present as its integrated resource Plan. In conjunction with this overall long –term plan an Action Plan is developed that focuses on the decision period in which actions must be decided on today. With-in the Action Plan a set of signposts are developed from the sensitivities that determine which variables should be monitored, at what value an action should be triggered, and what the contingent actions should be.

- **Documentation and Regulatory Support** –The heart of the IRP is the final documentation. These are the documents that will be filed with regulators and all other parties. It should be thorough, accurate and defensible. Note that this step is best performed as the overall IRP process is being performed.

The review of the resource planning process included a review of the original filings with the Board concerning the Muskrat Falls Project, review of two independent detailed reviews of the project, a review of the responses to the Board's questions concerning the incidents this winter, and one-on-one interviews with both NLH and NP planning staff.

## Conclusions

The resource planning process being performed by NLH conforms to the basic structure laid out in the Ventyx IRP process. All areas in the IRP process were deemed as being acceptable. However, two areas, Alternative development, and Risk Assessment were found to be acceptable but in need of improvements.

In the development of alternatives it was found that although existing demand-side programs were included in the development of the resource plan there was a lack of additional demand-side alternatives. The report only mentions the presentation of CDM alternatives to the Board, no mention of the use of demand-side as alternatives to supply resources is made. Due to slow growth requirements of demand programs the use of demand-side alternative will not be effective to solve short-term issues. It will also not change the need for the capacity and energy from the Muskrat Falls project long term. However, it is Ventyx's recommendation that the use of demand-side alternatives be further explored in the period post 2017 while there is ample capacity to cover requirements. In reviewing the documents it was noted that there is no formal risk assessment being performed.

Sensitivities were performed and included in the original documentation but focused mostly on commodity and costing assumptions. Future scenario and sensitivity processes should be expanded to include the impacts of extreme loads. These expanded sensitivity analysis can then be formally included into a risk analyses process to determine the robustness and impacts

of resulting plans. The additional load sensitivities are discussed above in the section on load forecast.

## Recommendations

It is noted that while NLH's Resource Planning processes meets the overall IRP process requirements, there are two areas that could be incrementally improved.

Improve the resource planning process by:

- Beginning to explore the use of demand-side programs as long-term alternatives to future supply-side alternatives post 2017 and
- Expand the Risk Analysis sensitivities to include several levels of load forecast uncertainty.

## Generation Outlook 2014 to 2017

On January 17<sup>th</sup>, the Board initiated a process to gather information from NLH and NP with a focus on whether load requirement on the Island Interconnected system can be met in the near term. In the near term, NLH's current resource expansion plan is within the reliability criteria.

	Loss of Load Hours (Hours)	Reserve Margin (Percent)
2013	0.97	16.32
2014	2.59	12.28
2015	3.98	10.32
2016	2.73	12.21
2017	2.68	11.00

The previous table is based on the assumption that a new 50 MW CT is in service December of 2015. If that unit does not achieve that commission date the LOLH would increase to 4.57.

NLH is currently considering six options<sup>16</sup> for meeting the expected LOLH in 2015. Each of these options offers the possibility to reduce the system LOLH.

1. Retain the 16 MW (10 MW to the system) diesel facility at Holyrood;
2. Review what is needed to make the remaining 4.6 MW of diesel power at Holyrood available to the system by plant modifications to increase equipment ratings to deliver 14.6 MW capacity;
3. Enter into interruptible contracts with large Industrial customers;
4. Seek already built combustion turbines in the 50 to 100 MW range to supply deficit and blackstart;
5. Initiate the supply of a new 60 MW (nominal) combustion turbine for the Holyrood site to supply deficit and blackstart; and
6. Continue and possibly enhance conservation and demand management initiatives, with the focus on demand management.

The new 60 MW (nominal) combustion turbine or other combustion turbine options are key resources for NLH's near term reliability of supply. The current plan has this unit commissioned in December of 2015. Without this unit, NLH would face LOLH reliability indices of 4.57 hours/year in 2015, 6.02 hours/year in 2016, and 5.71 hours/year in 2017, the Labrador Infeed is in service in December of 2017.

Statistically, demand reduction is a slightly better alternative to generation additions due to inherent uncertainty of generation forced outages. In order to reduce the expected 2015 LOLH of 3.98 hours/year to 2.80 hours/year, NLH would need to secure approximately 40 MW of either interruptible contracts with existing customers or conservation and demand

---

<sup>16</sup> Newfoundland and Labrador Hydro, *PUB-NLH-062* (Newfoundland and Labrador Hydro: Board Response, February 2014)



management initiatives. If that is not practical, then the difference can be made up from the remaining generation capacity options.

Furthermore, NLH uses reasonable estimates for generation forced outage assumptions as compared to Canadian Electricity Association (CEA) five year averages and the five year averages for its own equipment. The assumptions in Strategist are based upon data collected between 2000 and 2004. The generation forced outage assumption for Holyrood and Bay D’Espoir are 9.64%<sup>17</sup> and 0.91%<sup>18</sup>, respectively, and they contributed to the forecast 2015 LOLH of 3.98 hours/year. Recent data from NLH operating data, from 2008 to 2012, indicates that the historical performance for Bay D’Espoir has improved to 0.41% and worsened for Holyrood to 10.69%. These figures are relatively consistent with current performance, however if the generation forced outage assumptions were improved for Bay D’Espoir, the 2015 LOLH would drop to 3.69 hours/year. If the generation forced outage assumptions were changed for Holyrood the contribution to the 2015 LOLH would increase to 4.49 hours/year.

The primary drivers are the Holyrood units. Focusing only on Holyrood, if Holyrood unit could achieve an annual forced outage rate of 8.48% or less then the system would achieve a LOLH of 2.8 hours/year. Recognizing the age of these assets this may not be practical in the short term and continuing the current assumptions is prudent planning, particular for the near term. As well there is merit in assessing some variation of this expected performance to gauge sensitivity on the LOLH result.

## Summary of Recommendations

Ventyx has not found any evidence that either the generation planning process or the load forecasting process have contributed to the events of January.

---

<sup>17</sup> Source: CEA Typical 2000-2004. Table 6.2.2 100-199 MW Classification for Holyrood.

<sup>18</sup> Source: NLH Operating Experience between 2000-2004. Weighted Average based on Bay D’Espoir units & Hinds Lake, Upper Salmon, Cat Arm and Paradise River

It was noted above that Ventyx does not believe it is desirable to change the forecast methodology to an end-use model. Primarily this is due to the increased complexity and cost, but it is also noted above that the major end-use on the system is electric heat and is already included in the forecast model and thus capturing the majority of any additional detail accuracy benefits that would be expected from an end use model. Since the  $R^2$  for the two regression equations involving heating penetrations were 79% and 89% it would be advisable that NLH continue to refine its models with respect to these two variables. This can be further enhanced through continued surveying of the customer base in terms of both average use and saturation of this end use.

The above discussion has been in terms of the base-case scenario. It has been recommended above that NL begin using a formal risk assessment process that includes the evaluation of plans under extreme weather conditions. As such, it will be important to develop alternative load forecast in both the scenario development and the sensitivity analysis phases.

NLH should continue to use its generation planning reserve criterion.

After completion of NLH's interconnection with Nova Scotia and Muskrat Falls, NLH should revisit their generation planning reserve criterion of 2.8 hours/year in light of the reliability benefits offered by the access to North American markets. In addition, NLH should continue their on-going efforts to include the modeling of external markets in Strategist to capture both the reliability benefits and market value of market interactions. In order to allow for a better understanding of the potentials of economy interchange Ventyx recommends NLH continues to pursue the Network Economy Interchange ("NEI") modeling effort.

Since Holyrood is scheduled to be retired in the next 4 to 5 years NLH should model it's EFOR close to the actuals currently being experienced with sensitivities on either side of the expected value. With respect to all other thermal units in the Strategist model (existing and future) NLH should continue its practice of modeling with a more conservative estimate of EFOR for the units. However, one refinement that NLH could make to its EFOR assumptions would be to tie the level of EFOR to typical maintenance cycles. There is an inherent relationship between higher capital expenditures and maintenance corresponding to lower EFOR. However, it should be noted that a five year rolling average will also account for these cycles. By ramping up the

EFOR, in the years leading up to a major maintenance cycle, NLH would have a better picture of the near-term, one to five year, view of system reliability.

Alternatively, NLH could also compute a break-even EFOR for each class of its generation resources. For example consider the Holyrood Plant, the maximum EFOR would be between 9.7% and 9.8%. At this point, the unit's contribution to LOLH would exceed 2.8 hours/year.

Improve the resource planning process by:

- Beginning to explore the use of demand-side programs as long-term alternative to future supply-side alternatives post 2017 and
- Expand the Risk Analysis sensitivities to include several levels of load forecast uncertainty.

## Appendices

PUB-NLH-008

PUB-NLH-011

PUB-NLH-056

PUB-NLH-062

Island Interconnected System Supply Issues and Power Outages

---

Page 1 of 2

1 Q. How does Hydro determine the appropriate reserve to have available to meet the Island  
2 Interconnected system load?

3  
4  
5 A. From a long-term planning perspective, Hydro has established criteria related to the  
6 appropriate reliability for the system, at the generation level, that sets the timing of  
7 generation source additions. These criteria set the minimum level of reserve capacity  
8 and energy installed in the system to ensure an adequate supply for firm demand;  
9 however, short-term deficiencies can be tolerated if the deficiencies are of minimal  
10 incremental risk. As a general rule to guide Hydro's planning activities the following  
11 have been adopted:

12  
13 **Capacity:** The Island Interconnected System should have sufficient generating capacity  
14 to satisfy a Loss of Load Hours (LOLH) expectation target of not more than  
15 2.8 hours per year<sup>19</sup>.

---

<sup>19</sup> LOLH is a statistical assessment of the risk that the System will not be capable of serving the System's firm load for all hours of the year. For Hydro, an LOLH expectation target of not more than 2.8 hours per year represents the inability to serve all firm load for no more than 2.8 hours in a given year.

Island Interconnected System Supply Issues and Power Outages

---

Page 1 of 2

1       **Energy:**   The Island Interconnected System should have sufficient generating  
2                    capability to supply all of its firm energy requirements with firm system  
3                    capability<sup>20</sup>.

4  
5       From an operational perspective, Hydro manages generation resource availability on the  
6       Island Interconnected System and schedules generating units out of service for planned  
7       maintenance in order to meet a (n-1) system contingency reserve criterion. In this  
8       manner, sufficient reserves are planned to be available to meet the Island  
9       Interconnected System load under a contingency of the largest (MW rating) available  
10      generating unit. Hydro does not rely on capacity from wind and other non-  
11      dispatchable<sup>21</sup> resources to provide reserve. However, if these resources are in  
12      production they can further increase the reserves available. Following the (n-1)  
13      criterion results in no extended planned maintenance scheduled during the winter  
14      period. However, if the short-term load forecast permits, Hydro may take the  
15      opportunity to schedule a short duration generating unit outage to address running or  
16      corrective maintenance issues.

---

<sup>20</sup> Firm capability for the hydroelectric resources is the firm energy capability of those resources under the most adverse three-year sequence of reservoir inflows occurring within the historical record. Firm capability for the thermal resources (Holyrood Generation) is based on energy capability adjusted for maintenance and forced outages.

<sup>21</sup> Please refer to PUB-NLH-044 for a definition of "non-dispatchable".

**Island Interconnected System Supply Issues and Power Outages**

---

**Page 1 of 2**

1 Q. Provide the forecast and actual peak demand for each month in the winter period in  
2 each year from 2004 to 2013 and the forecast each year for 2014 to 2017 for each  
3 month in the winter period.

4  
5  
6 A. Please see below for the forecast and actual peak demand supplied by Hydro for the  
7 Island Interconnected System. Please note that Hydro interprets the winter period to be  
8 from December through March and that the forecasts provided are Hydro's Operating  
9 Load Forecasts. Please refer to Hydro's response to PUB-NLH-014 on timing of  
10 preparation.

Island Interconnected System Supply Issues and Power Outages

---

Page 1 of 2

**NLH System Peak Demand (MW)**

	<u>Forecast</u>	<u>Actual</u>
Jan-04	1399	1277
Feb-04	1338	1405
Mar-04	1237	1206
Dec-04	1374	1402
Jan-05	1429	1361
Feb-05	1405	1272
Mar-05	1301	1161
Dec-05	1353	1202
Jan-06	1385	1276
Feb-06	1369	1185
Mar-06	1256	1167
Dec-06	1333	1310
Jan-07	1358	1323
Feb-07	1350	1249
Mar-07	1238	1242
Dec-07	1336	1286
Jan-08	1367	1289
Feb-08	1356	1212
Mar-08	1242	1207
Dec-08	1350	1323
Jan-09	1388	1390
Feb-09	1377	1375
Mar-09	1262	1294
Dec-09	1349	1268



Island Interconnected System Supply Issues and Power Outages

---

Page 1 of 2

**NLH System Peak Demand (MW)**

	<u>Forecast</u>	<u>Actual</u>
Jan-10	1372	1253
Feb-10	1361	1305
Mar-10	1243	1142
Dec-10	1371	1207
Jan-11	1401	1278
Feb-11	1390	1292
Mar-11	1270	1200
Dec-11	1405	1399
Jan-12	1433	1385
Feb-12	1417	1350
Mar-12	1302	1341
Dec-12	1432	1307
Jan-13	1461	1378
Feb-13	1446	1374
Mar-13	1332	1272
Dec-13	1401	1501
Jan-14	1478	-
Feb-14	1429	-
Mar-14	1322	-
Dec-14	1425	-
Jan-15	1523	-
Feb-15	1470	-
Mar-15	1361	-
Dec-15	1447	-
Jan-16	1543	-
Feb-16	1498	-
Mar-16	1383	-
Dec-16	1466	-
Jan-17	1567	-
Feb-17	1515	-
Mar-17	1395	-
Dec-17	1473	-

Note: Forecast and actual peaks reflect gross requirements.

Island Interconnected System Supply Issues and Power Outages

---

Page 1 of 3

1 Q. Further to the response to PUB-NLH-008, state the date(s) the criteria used for  
2 generation source additions was last reviewed by Hydro. In the response state whether  
3 Hydro is of the opinion it should be reviewed in light of Hydro's aging infrastructure and  
4 when is the appropriate time to review this criteria.

5  
6  
7 A. Hydro's generation source additions criteria have been in use for over 35 years and in  
8 that period they have been reviewed on a number of different occasions and found to  
9 provide a good balance of reliability versus cost.

10  
11 Before 1977, there were no approved long-term reliability criteria for generation  
12 planning in Hydro. The basis of the current criteria is a report, *Recommended Loss of*  
13 *Load Probability (LOLP) Index for Establishing Generation Reserve Additions*, System  
14 Planning Department, May 16, 1977. In that report, a LOLP of 0.2 days per year, or 1  
15 day in 5 years was established. In 1997, when Hydro replaced the SYPCO generation  
16 planning software with ProScreen II (now renamed Strategist) generation planning  
17 software, it was necessary to switch to a Loss of Load Hours (LOLH) criterion.  
18 Benchmarking established that a LOLH of 2.8 hours per year was equivalent to a LOLP of  
19 0.2 days per year, for Hydro's system. From that point onward, Hydro established the  
20 capacity criteria that the Island Interconnected System should have sufficient generating  
21 capacity to satisfy an LOLH expectation target of not more than 2.8 hours per year.

Island Interconnected System Supply Issues and Power Outages

---

Page 1 of 3

1 In 1991, at the direction of the Board, George C. Baker, a consultant working for Hiltz  
2 and Seamone Company Limited carried out a study and produced a report -*Report on*  
3 *the Technical Performance of Newfoundland & Labrador Hydro* - October 2, 1991. On  
4 page 9 of the report, in Section 7 *System Planning*, it states:

5 *Hydro uses two criteria for generation planning in its interconnected system.*

6 *(a) Sufficient production capacity to meet all needs under firm water conditions (lowest*  
7 *recorded flows), and*

8 *(b) A loss of load expectancy of one day in five years.*

9  
10 *The first criterion is usual for utilities with significant dependence on hydraulic*  
11 *generation. The second differs from the one-day-in-ten-years LOLE<sup>22</sup> adopted by many*  
12 *utilities.*

13  
14 *The main reason for permitting a higher LOLE is economic. Hydro, unlike almost every*  
15 *other major utility, is an isolated system. Other utilities can, and do, rely on capacity*  
16 *support from interconnected utilities in meeting the one-day-in-ten-years criterion.*

17 *Hydro cannot do this, and would have to maintain a much higher generation reserve.*

---

<sup>22</sup> Loss of Load Expectation. LOLE is another way of stating LOLP and the two are equivalent.

Island Interconnected System Supply Issues and Power Outages

---

Page 1 of 3

1        *Hydro believes the costs of doing so would not be justified by the difference in reliability.*  
2        *The Consultant agrees.*

3  
4        In 1999, at the direction of the Board, Quetta Inc. and Associates carried out a study and  
5        produced a report *Technical Review of Newfoundland and Labrador Hydro Final Report*  
6        March 17, 1999. On page 23 of the report, in Section 2.1.3.2 *Capacity*, it states:

7  
8        *The Island Interconnected System should have sufficient generating capacity to satisfy a*  
9        *Loss of Load Expectation (LOLE) target of not more than 2.8 hours per year. This is*  
10       *equivalent to 0.2 days/year or 1 day in five years. It results in a capacity reserve*  
11       *requirement of 18%.*

12       *The LOLE capacity criterion is somewhat less stringent than that employed by large*  
13       *interconnected systems in the rest of North America (one day in 10 years or 0.1*  
14       *days/year). Considering the non-interconnected status of the Island's electric utility*  
15       *system, (reserve sharing is not an option) the cost of providing higher reliability level is*  
16       *probably in excess of the benefits to be derived.*

17  
18       *Quetta is of the opinion that the capacity and energy criteria are reasonable in the*  
19       *circumstance.*

Island Interconnected System Supply Issues and Power Outages

---

Page 1 of 3

1 Most recently, the criteria were reviewed in the *Report on Two Generation Expansion*  
2 *Alternatives for the Island Interconnected Electrical System – Volume 2: Studies January*  
3 *2012*. This report was prepared for the Board by Manitoba Hydro International. In the  
4 report, *Section 3 – Reliability Studies* runs from page 57 to page 71. *Section 3.11 –*  
5 *Conclusions and Findings*, page 70, states the following:

6  
7 *Available documentation for reliability assessment performed by Nalcor has been*  
8 *reviewed by MHI. The adequacy criteria of 2.8 hours/year of loss of load expectation for*  
9 *resource planning, which considers both generation resource availability and economics,*  
10 *appears reasonable when compared to practices of other operating utilities.*

11  
12 As part of its internal review of recent events, Hydro has engaged an outside consultant  
13 (Ventyx) to review its generation planning practices. One of the areas to be reviewed is  
14 the criteria used for generation source additions. As well, in light of Hydro's aging  
15 infrastructure, it is also appropriate to review the inputs to the generation expansion  
16 model, such as the current and expected forced outage rates of Hydro's generating  
17 units. These will also be reviewed.

Island Interconnected System Supply Issues and Power Outages

---

Page 1 of 2

1 Q. Further to the response to PUB-NLH-018, which states that there is a capacity deficit  
2 identified for 2015, explain in detail each of the “*several generating options potentially*  
3 *available to meet winter peak demand*” that Hydro stated it was pursuing, including the  
4 status of the review of each option and the time required to construct or install each  
5 option.

6  
7  
8 A. The options under consideration for meeting the deficit currently expected in 2015  
9 include the following and may be a combination of two or more to meet the potential  
10 deficit:

- 11 1. **Retain the 16 MW diesel facility at Holyrood (presently under a lease-to-own**  
12 **arrangement).** Once installed, 10 MW can immediately be supplied to the system  
13 on a sustained basis. This facility is currently being prepared for commissioning in  
14 early March 2014.
- 15 2. **Review what is needed to make the remaining diesel power available to the**  
16 **system.** Please refer to Hydro's response to PUB-NLH-064.
- 17 3. **Enter into interruptible contracts with large Industrial Customers.** Discussions  
18 with Industrial Customers (CBPP, Vale and North Atlantic Refining) were initiated  
19 in fall 2013. These discussions are ongoing and options continue to be explored.  
20 Please refer to Hydro's response to PUB-NLH-050.
- 21 4. **Seek already built combustion turbines in the 50 to 85 MW range.** Preliminary  
22 discussions indicate that these options can provide in-service to meet the 2015  
23 requirement. However, discussions with manufacturers, brokers and owners are

## Island Interconnected System Supply Issues and Power Outages

---

Page 1 of 2

ongoing to determine the delivery times, operating experiences, the extent of modifications required, and the facilities required to connect to the Island Interconnected System.

5. **Initiate the supply of a new 60MW (nominal) combustion turbine for the Holyrood site to supply deficit and blackstart functionality.** All preliminary engineering is complete. With final approval by June 2014, this plant could be in-service by 2015.

6. **Conservation and demand management initiatives, with the focus on demand management.** Work is being conducted to assess customer end use options with a view of providing demand management. This is considered a supplemental means of meeting the deficit and may provide further cost savings opportunities when combined with other options.