

March 30, 2017

The Board of Commissioners of Public Utilities
Prince Charles Building
120 Torbay Road, P.O. Box 21040
St. John's, NL A1A 5B2

Attention: Ms. Cheryl Blundon
Director Corporate Services & Board Secretary

Dear Ms. Blundon:

**Re: Investigation and Hearing into Supply Issues and Power Outages on the Island
Interconnected System -- Directions further to the Board's Phase One Report**


Further to the Board's correspondence dated October 13, 2017, attached please find:

1. A report entitled "*Establishing a Robust Operational Philosophy and Enhancing Skills and Capabilities Relating to Systems Reliability and Analysis*" outlining the actions taken in response to each of Liberty's recommendations in its report dated October 22, 2015 on the March 2015 Outage; and
2. A report entitled "*Improving the Transparency of the Designation of Critical Customers*" detailing improvements to the transparency of the designation of critical customers.

We trust the foregoing is satisfactory. If you have any questions or comments, please contact the undersigned.

Yours truly,

NEWFOUNDLAND AND LABRADOR HYDRO



Tracey Pennell
Senior Counsel, Regulatory

TLP/bs

cc: Gerard Hayes – Newfoundland Power
Paul Coxworthy – Stewart McKelvey Stirling Scales
Roberta Frampton Benefiel – Grand Riverkeeper Labrador
ecc: Denis Fleming- Vale Newfoundland & Labrador Limited

Dennis Browne, Q.C. – Consumer Advocate
Danny Dumaresque

Larry Bartlett – Teck Resources Ltd.

**Establishing a Robust Operational Philosophy and Enhancing Skills and
Capabilities Relating to Systems Reliability and Analysis**

March 30, 2017

A Report to the Board of Commissioners of Public Utilities



Table of Contents

1.0 Introduction.....	1
2.0 Establishing a More Robust Operational Philosophy	3
2.1. Overview	3
2.2. Corporate Reorganization.....	4
2.2.1 Strategic Organizational Transformation	4
2.2.2 Hydro’s Organizational Structure	6
2.3. System Operations Improvements	9
2.3.1 Daily System Status Meetings	9
2.3.2 Storm Preparation Meetings	11
2.3.3 Improved Internal Outage Communication	12
2.3.4 Increased focus on the Avalon Peninsula Reserves	13
2.3.5 Island Spinning Reserves	14
2.3.6 Operation of Standby Units.....	15
2.4. Integrated Annual Work Plan (IAWP)	16
2.4.1 Winter Readiness Plan.....	17
2.4.2 Maintenance Tracking Report.....	18
2.5 Equipment Outage Management Tracker	19
2.6 Reintroduction of Hot Line Work.....	20
3.0 Improving Reliability Engineering and Analysis Skills and Capabilities	21
3.1 Energy Control Center Operator Training.....	21
3.2 Corporate Reorganization of System Operations	23
3.3 Supply Planning and Risk Assessment	25
3.3.1 Demand Forecast Analysis	27
3.3.2 Accelerated Construction of Transmission Line TL267	29
3.3.3 Capacity Assistance Agreements.....	30
3.4 Equipment Failure Review Enhancements	31
3.5 Membership in the Center for Energy Advancement through Technological Innovation	32
4.0 Improving Situational Awareness.....	33
4.1 Internal and External Communications	33
4.2 Improved Strategic Focus of System Operations.....	36
4.2.1 Early Engagement of System Operations in IAWP	36
4.2.2 Improvements to the Energy Control Center.....	37
4.3 Staffing in Advance of Issues	43
4.4 A Strategy for Customer Service Excellence	44

4.4.1	Development of an Account Management Framework.....	44
4.4.2	Implement New Customer-Focused Mobile Application.....	45
4.4.3	Improve Customer Interaction Through Phone System.....	45
4.4.4	Structured After Hours Support	46
4.4.5	Implement Transactional Customer Surveys	46
5.0	Improving the Corporate Emergency Response Plan.....	47
6.0	Improvements to External Communications Processes.....	49
7.0	Future Improvements.....	52
7.1	Improving Equipment Reliability and Preventative Maintenance Programs Based on Lessons Learned	52
7.2	Creation of Newfoundland Labrador System Operator.....	54
7.3	Improved Standards for Measuring Gas Turbine Performance.....	56
7.4	Review and Adoption of NERC Reliability Standards	57
7.5	Service Level Agreements	57
7.6	Requirement for Additional Generation.....	58
8.0	Conclusion	59

Table of Figures

Figure 1: Executive Structure – Nalcor Energy	6
Figure 2: Executive Structure – Hydro	8
Figure 3: ECC Display (Pre Upgrades)	38
Figure 4: ECC One Line Display (Post Upgrade)	38
Figure 5: ECC One Line and Geographic (highlighted in red) Displays	40
Figure 6: ECC Geographic Display	40
Figure 7: Advanced Notification Protocols – Levels of Notification	50
Figure 8: MyHydro Application	45

Appendices

Appendix A - Glossary of Terms
Appendix B - Daily System Status Meeting Notes
Appendix C - Severe Weather Checklist
Appendix D - Avalon Capability and Reserves (T-096)
Appendix E - Generation Reserves (T-001)
Appendix F - Outage Readiness Tracker

1 **1.0 Introduction**

2 On October 13, 2016, the Board of Commissioners of Public Utilities (the Board) requested
3 Newfoundland and Labrador Hydro (Hydro) provide a report on the actions taken in response
4 to each of Liberty's recommendations in its report dated October 22, 2015, on the March
5 (2015) outage, including all actions and plans to establish a more robust operational
6 philosophy regarding reliability and to enhance the skills and capabilities of Hydro's employees
7 related to reliability engineering and analysis.

8
9 This report details the actions that Hydro has taken to establish a more robust operational
10 philosophy and its plans to establish a more reliability-centric culture. This report also discusses
11 the actions taken by Hydro to improve the skills and capabilities of its employees related to
12 reliability engineering and analysis.

13
14 It must be recognized that changing an organization's culture takes time. It is a large-scale
15 undertaking that requires the organization to first change its behaviours knowing that the
16 mindset of its employees will follow. Hydro has implemented many changes since the outages
17 in 2014 and more following March 2015 events. The company is more risk focused and strives
18 to remove known risks in addition to mitigating and managing those it cannot fully remove.
19 Today, Hydro's new leadership has set expectation that the approach to the overall system
20 management is to be customer focused with a goal of continually improving reliability as well as
21 transparency with our customers on system conditions. There is also an expectation of a
22 heightened and urgent response to system events to ensure that any outages or customer
23 impacts are minimized to the extent possible. This has been achieved by implementing a
24 number of changes in practises and processes which are directly benefiting customers and
25 fundamentally resetting the utility focus of Hydro.

26
27 Hydro has made significant progress since 2014 and has a fundamental strategy of renewing
28 the focus of Hydro and its employees to its core business of supplying its customers with a safe

1 and reliable power supply. Hydro has demonstrated to the Board and its customers improved
2 operational philosophy and an increased focus on service continuity for the customer. Hydro
3 also acknowledges that this work and the improvements to culture, processes, practices will
4 continue with appropriate urgency, driven by the current leadership but supported across the
5 company. Some examples of where Hydro's approach has ensured service continuity include:

- 6 • In 2016, Hydro experienced boiler tube issues at the Holyrood Thermal Generating
7 Station (HTGS) and took deliberate actions to ensure minimal customer outages. The
8 thermal generating units were run at lower loads and the gas turbines were started in
9 advance to ensure service continuity. There was no visibility to cost recovery for the
10 operation of the gas turbines; Hydro took this action solely to ensure reliability of the
11 system for customers.
- 12 • Starting in 2016, Hydro leased a spare engine that provides redundancy for its gas
13 turbines. Hydro believes that the need for reliability of the gas turbine generation
14 warrants the additional leasing costs and will continue to lease the spare engine.
- 15 • In 2017, Hydro entered a long-term maintenance contract with Siemens for the
16 Holyrood combustion turbine (CT). The Holyrood CT is an important component of the
17 Avalon contingency reserves and securing a long-term service provider will improve
18 access to parts inventories, improve service response times and contribute to the
19 overall reliability of the grid.
- 20 • In 2017, Hydro experienced air flow issues with the generating units at HGTS that have
21 caused de-ratings to each unit. Due to the importance of the HTGS to the Island
22 Interconnected System (IIS) and Avalon Peninsula, and rather than leave both units de-
23 rated until the summer maintenance season, Hydro is planning an outage in April to
24 restore capacity to one unit as quickly as possible.
- 25 • The March 11, 2017, windstorm shows an improved operational philosophy for Hydro
26 and demonstrates many of the improvements discussed in this report. The impending
27 weather conditions (extreme wind; up to 180 km/hr) were recognized early and it was
28 decided during the daily system status meeting that a storm preparation would be

1 required. During the storm preparation meeting, Hydro created a plan to respond to
2 the impending weather event and it was decided that crews would be placed on
3 standby in advance of the weather for quick mobilization to areas requiring attention.
4 Once the storm hit and outages were experienced, Hydro staff was able to respond
5 quickly, thus minimizing the outages. Internal communications kept all stakeholders
6 informed of the status and progress of unplanned outages and Hydro was in direct
7 communication with Newfoundland Power and the general public. Hydro staff reacted
8 appropriately and quickly to minimize the impact of the storm, with engagement of all
9 levels of the organization. Hydro's system was exposed to design specification wind
10 loading and experienced damage that was not extensive during this event. Hydro is
11 reporting to the Board separately on the March 11, 2017, windstorm.

12
13 The above are a few examples only. Each of the changes outlined in this document directly
14 influences the organization's philosophy and culture, moving ever-further in its evolution as a
15 reliability-focused organization. Hydro will continue to learn, grow and evolve its operational
16 philosophy while continuing to improve service continuity.

18 **2.0 Establishing a More Robust Operational Philosophy**

19 **2.1. Overview**

20 Liberty recommended that "Hydro should assign a team to implement a program to establish a
21 more robust operational philosophy regarding reliability."¹ Hydro regards service continuity as
22 being critical to its customers and seeks to continually improve its service reliability. Reliability
23 has been enhanced over the past several years through a series of strategic operational and
24 system improvements undertaken by Hydro.

¹ The Liberty Consulting Group, "Review of the Newfoundland and Labrador Hydro March 4, 2015 Voltage Collapse," October 22, 2015, at page 10. Available at: <http://www.pub.nf.ca/applications/March4thPowerOutage/files/reports/Liberty-Report-Oct22-15.pdf>

1 In response to its customers, the Board, and Liberty’s recommendations, Hydro has taken a
2 number of actions, as explained below, to secure a reliable power system and to support a
3 more robust operational philosophy.

4

5 **2.2. Corporate Reorganization**

6 Changes to both the Nalcor and Hydro organizational structures have improved executive focus
7 on the principal functions associated with the delivery of service. These changes position Hydro
8 to operate as an autonomous business entity within the Nalcor group of companies focused
9 solely on its mandate of delivering safe, reliable, least-cost power to industrial, utility and
10 residential customers in Newfoundland and Labrador.

11

12 **2.2.1 Strategic Organizational Transformation**

13 Since the power outage events of 2014, Hydro has implemented organizational changes that
14 have transformed the company and improved its focus on core power generation and
15 transmission operations, but through the lens of its customers. In its response to Liberty’s
16 Phase I report in early February 2015, Hydro acknowledged that its executive structure, as it
17 existed below the level of President and CEO, did not consolidate all principal functions
18 associated with the delivery of a utility service under one single executive.²

19

20 Hydro noted that the arrangement under which two Hydro vice presidents reported to the CEO
21 was implemented in 2013 as a transitional structure that would ensure the required focus on
22 ongoing operations, while at the same time enabling the Company to give the required
23 attention to the future integration of Muskrat Falls with existing electricity operations. Hydro
24 indicated that it would not maintain this structure in its longer term steady state operating
25 environment, and further indicated that the manner in which Hydro and Nalcor Energy (Nalcor)
26 would be structured for longer term electricity operations was actively under review.

² This report dated December 14, 2014 outlined various conclusions and recommendations by Liberty Consulting, specific to Hydro, as part of the *Review of Supply Issues and Power Outages on the Island Interconnected System* conducted by the Board.

1 Hydro also acknowledged that the regulatory affairs function in a regulated utility is a critical
2 function. In its response, Hydro indicated its intention to fully consider Liberty's
3 recommendation as part of Hydro's determination of its long term structure for electricity
4 operations.

5
6 In November 2015 the position of President for Hydro was created to be ultimately responsible
7 and accountable for all aspects of Hydro operations. Following the appointment of a new
8 President and CEO for Nalcor in May 2016, a number of further organizational changes were
9 instituted. The direction provided by Nalcor's CEO as part of his overall reorganization of
10 Nalcor was that Hydro was to be operationally independent from Nalcor and its other lines of
11 business. The goal was to ensure organizational separation and simplicity for Hydro as it relates
12 to operations management, budgeting and financial management, performance accountability,
13 and regulatory oversight.

14
15 Organizational changes were made with the intention of creating clear separation between
16 Hydro as Nalcor's established regulated utility. A new President for Hydro was appointed in
17 June 2016. Following this appointment, Hydro reviewed its organizational structures and
18 subordinate organizational structures for all areas of operations. Figure 1 presents the high
19 level executive structure for Nalcor that was announced by Nalcor's President and CEO in June
20 2016.




Figure 1: Executive Structure – Nalcor Energy

1 2.2.2 Hydro's Organizational Structure

2 Hydro's new executive structure reflects a more encompassing organizational model that
 3 ensures that core functions required to operate the company as an operationally independent,
 4 stand-alone organization have clear accountability within the new structure.

5

6 Hydro's new executive structure reflects a more encompassing organizational model that
 7 internalizes the core functions required to operate the company as an operationally
 8 independent, stand-alone organization. All functions have clear accountability within the new
 9 structure. The new divisions include:

- 10 • **Production** – The Production Division encompasses all aspects of power generation
 11 within Hydro, including hydroelectric, thermal, diesel, and gas turbine generation, as
 12 well as generation planning. Exploits Generation, which was previously managed as part
 13 of Hydro's non-regulated operations, is now managed by Production Operations, under
 14 its hydraulic generation group.
- 15 • **Transmission, Distribution, and NL System Operations** – The Transmission, Distribution,
 16 and NL System Operations Division also includes transmission planning and is

1 responsible for the transmission and distribution of power throughout the Island and
2 Labrador. The incorporation of System Operations, transmission planning and the
3 Energy Control Center optimizes the operation and planning of the core provincial
4 power system.

- 5 • **Engineering Services** – The Engineering Services Division includes asset management,
6 project execution and technical services employees. The division also includes an
7 Information Systems and Operations Technology group that are focused on ensuring
8 that Hydro’s has the core systems required for the business as well as maintaining the
9 company’s Energy Management System, Network Services and other critical IT
10 infrastructure utilized in the Energy Control Center.
- 11 • **Regulatory Affairs and Corporate Services** – The Regulatory Affairs and Corporate
12 Services Division consolidates and strengthens Hydro’s organizational focus on
13 regulatory affairs, including a dedicated legal resource, and integrates Customer Service,
14 Energy Efficiency, Safety, Health, Environment and Corporate Communications.
- 15 • **Financial Services** – The Financial Services Division provides financial oversight and
16 support to Hydro in the areas of Commercial Management, Treasury, Tax, Risk,
17 Insurance, Supply Chain, Administration, and other financial services.
- 18 • **Corporate Secretary and General Counsel** – The Corporate Secretary and General
19 Counsel Division provides core legal oversight to the company as well as Board
20 Secretarial functions.

21
22 Figure 2 presents the executive level structure for Hydro announced by the President of Hydro
23 in September 2016.




Figure 2: Executive Structure – Hydro

1 **2.3. System Operations Improvements**

2 Since the outages in 2014, Hydro’s System Operations Department has made significant
3 improvements that demonstrate meaningful change in its operational philosophy regarding
4 system reliability. Hydro now takes a more holistic view of customers when assessing system
5 conditions and is more focused on the end-consumer of its power, rather than being focused on
6 the end-point of its power delivery.

7
8 This change in philosophy and practise has led to enhanced communications between System
9 Operations and the rest of the organization through the addition of daily system status
10 meetings, storm preparation meetings, and improvements in communication to Executive and
11 Management to ensure awareness of both planned and unplanned outages. The Company has
12 also increased its focus on the Avalon Peninsula supply, and has changed its approach for
13 placing standby generating units into operation. Each of these improvements is described in
14 detail in the following sections.

15

16 **2.3.1 Daily System Status Meetings**

17 Hydro’s System Operations Department hosts a daily system status meeting where participants
18 discuss power supply capability and reserves and other conditions that could impact the
19 reliability of the Island Interconnected System and/or the Avalon Peninsula.

20
21 Traditionally, power system discussions were held internally within the System Operations
22 Department and had an internal focus to the Energy Control Center (ECC). Stakeholders within
23 Hydro were engaged with respect to any concerns related to their area’s assets. This meeting
24 has since evolved into a very structured process that includes key individuals throughout Hydro
25 with primary responsibilities tied to the reliability of the Island Interconnected System,
26 including participation from Hydro Executive and Management representatives from

1 Production, Transmission, Distribution, System Operations, Communications, and Regulatory
2 Affairs.³

3
4 The increased scope and structure of the daily system status meeting has improved the
5 reliability culture at Hydro by improving internal communications within Hydro as well as a
6 broader system status understanding for a large group of people involved in various aspects of
7 system management and monitoring. All stakeholders are engaged and aware of the various
8 factors that might impact the power system. As part of these meetings, system reliability
9 assessments, based on load forecasts for the current day and for the next seven days, are
10 reviewed and discussed for both the Island Interconnected System and the Avalon Peninsula.
11 These assessments outline the expected reserves based on the load forecast and the availability
12 of assets which include primary generation, standby generation and in the case of the Avalon,
13 transmission availability.

14
15 There is a review of weather warnings and special weather statements issued by environment
16 Canada that can impact the Island Interconnected System. An additional storm preparation
17 meeting is held if participants decide it is warranted (see Section 2.3.2). A review of the 14-day
18 weather outlook is also reviewed. Hydro's internal load forecasting application (Nostradamus)
19 generates a load forecast for seven days. The 14 day forecast outlines the expected
20 temperatures beyond the seven day load forecast so there is a better understanding of
21 potential high load days outside the immediate seven day window.

22
23 The previous day's power system events are also discussed to understand any outages or
24 equipment issues. This activity gives participants a better understanding of the current state of

³ The only days in 2016 that this meeting did not occur were Christmas Day and New Year's Day. It was determined on Christmas Eve and New Year's Eve, respectively, that the following days meeting was not required as the system and weather conditions indicated that there were no impending risks. All representatives remained on call for these days in the event of a system issue.

1 the power system and can serve as a lessons-learned activity for meeting participants. Existing
2 and planned equipment outages are also reviewed to assess their impacts on short and long
3 term and can lead to cancelling planned outages or implementing contingency plans if the load
4 forecast warrants this action. After each meeting, summary notes are prepared and distributed
5 to the meeting participants. An example of these meeting notes is located in Appendix B.

6

7 **2.3.2 Storm Preparation Meetings**

8 Storm preparation meetings are held when Environment Canada posts special weather
9 warnings related to wind, rain, freezing rain, and/or snow that have the potential to negatively
10 impact the Island Interconnected System. The decision to hold this meeting is at the discretion
11 of System Operations and the Executive Team and depends on the scope and severity of the
12 weather event. This practice began in January 2016 and these meetings provide a structured
13 review of the current state of the system, the preparedness of each operational area, and
14 ultimately improve system reliability by ensuring that each operational area is ready to respond
15 quickly and effectively to any severe weather impacts.⁴

16

17 The meeting includes a review of the weather warnings and the areas of concern.
18 Representatives from the impacted area will review their severe weather checklists, referenced
19 in Appendix C, to confirm they are prepared to address storm impacts. Equipment and
20 generation capacity is also reviewed so that system risks can be identified and subsequently
21 accounted for in system preparation action plans. If the weather event is considered severe,
22 Hydro may proactively staff terminal stations and generation sites to reduce travel time, help
23 troubleshoot any issues, and ultimately respond faster to incidents and reduce outage
24 durations.

⁴ If the meeting is warranted, System Operations will notify each operational area. The operational areas of the organization all have severe weather checklists that will be completed and forwarded to System Operations in advance of the meeting. The storm preparation meeting includes the same invitees as daily system status meeting.

1 For example, it was determined during the daily system status meeting that a storm
2 preparation meeting would be required for the windstorm that was forecasted for March 11,
3 2017. During the storm preparation meeting, Hydro reviewed the weather warning, its impact
4 on each region, and then created a plan to respond to the storm. It was also decided that
5 crews would be placed on standby for quick response to where the issues were experienced.

6

7 **2.3.3 Improved Internal Outage Communication**

8 Hydro has improved its internal communications during maintenance activities for both
9 planned and unplanned outages. If an outage is time sensitive, for example a unit trips off line,
10 then the asset owner proactively communicates during the outage to Executive and
11 Management.⁵

12

13 This communication includes updates on work progress, expected return to service of
14 equipment, and other details that are important for the safe and reliable return to operation.
15 These updates ensure timely information is communicated to all internal stakeholders and
16 allows for proactive management and additional actions, when necessary, including external
17 updates to customers and other stakeholders.

18

19 As an example, Hydro has set clear expectations for how the Holyrood Control Room
20 communicates with the Energy Control Center during times when a unit is down for a planned
21 outage. If the unit is going to be delayed, they are to inform the ECC and the ECC will notify
22 the system on call⁶ and System Operations personnel. The system on call will notify the Hydro
23 Executive Team. This is required as a review of both the Island Interconnected System and

⁵ Includes representatives from the various functional areas, including Production, Transmission, Distribution, System Operations, Communications and Regulatory Affairs as included in the daily system status meeting.

⁶ The system on call is the on call person that is responsible for issues related to the entire power system. The individual is intended to be the communication liaison for large scale system wide issues which require more analysis (i.e. reserves levels) or to coordinate support. It can also be used for technical advice as required.

1 Avalon reserves would need to be completed to ensure reserve levels will be maintained and if
2 there are any requirements for alert level notification.

3

4 **2.3.4 Increased focus on the Avalon Peninsula Reserves**

5 Over fifty percent (50%) of the customer load is located on the Avalon Peninsula and System
6 Operations has a requirement to safeguard against the worst case contingency on the
7 transmission system into the Avalon Peninsula. To this end, system operating instruction
8 “Avalon Capability and Reserves (T-096)” (see Appendix D) was created to provide a method of
9 assessing capability and reserves specific to the Avalon Peninsula. This instruction was
10 approved internally at Hydro on June 26, 2015, and submitted to the Board for information on
11 October 14, 2015.

12

13 Since April 8, 2015, system reliability assessments for the Avalon Peninsula have been
14 performed daily, based on current load forecasts for the next seven days. These assessments
15 determine the reserves for the Avalon Peninsula for the next seven days given the availability of
16 the assets, which includes primary generation, standby generation, and sources of reactive
17 support, such as capacitor banks.

18

19 T-096 provides clear instruction to operators that reserves equal to the single largest
20 contingency, plus an additional reserve of 35 MW must be maintained for the Avalon Peninsula.
21 If the reserves are expected to go below this contingency factor, then the policy provides clear
22 instructions of the steps required to restore the appropriate reserves.

23

24 In addition, System Operations will monitor Avalon contingency reserves in real-time. This
25 takes into account transmission line capability and generation asset capabilities. This real-time
26 analysis allows operations to monitor the Avalon reserves and make decisions to maintain
27 these reserves, as per operating instruction T-096.

1 For example, on March 27, 2017, based on the load flow analysis,⁷ a Power Watch was issued
2 for the Avalon Peninsula and no warning was issued for the Island Interconnected System.
3 There has not been any power alerts issued for the Island Interconnected System since 2014.
4 All of the alerts issued have been related to the Avalon.

5
6 It is important to note that when level 2 (Power Watch) situations are experienced, Hydro
7 analyzes the reserves more frequently and updates interested parties, often having more
8 frequent system calls than the daily norm. Depending on the time of the issue, 6 am and 9 pm
9 calls may be held to ensure the right people are informed and ready to respond. While being
10 highlighted as part of the analysis of reserves, this is a significant situational awareness and
11 communication improvement illustrating the behavioural and cultural shift within the
12 organization.

13

14 **2.3.5 Island Spinning Reserves**

15 Spinning reserve is the extra generating capacity that is available by increasing the power
16 output of either hydro or thermal generators that are already connected to the power system.

17

18 Operators use operating instructions to operate the power system in an efficient manner.

19 Operating instructions look at system-wide impact. The operating instruction “[IIS] Generation
20 Reserves (T-001)” (see Appendix E) determines the amount of spinning reserves to maintain on
21 the Island Interconnected System. T-001 provides direction to the Energy Control Center to
22 take appropriate action to maintain a minimum spinning reserve level equal to 70 MW. This
23 operating instruction applies to the entire Island Interconnected System. Maintaining
24 appropriate spinning reserves covers performance uncertainties in generating units, especially
25 wind and other variable generation and unanticipated increases in demand. It can also allow
26 for quicker restoration times on outages. As an example, if a generator trips, it could cause an

⁷Load flow analysis is used to determine if system voltages will remain within specified limits under normal and emergency operating conditions, and whether equipment is overloaded during these conditions.

1 under frequency load shed event with loss of customers. The ECC can quickly request to
2 restore customers using the online spinning reserve. In this example, the ECC will also make
3 calls to senior management and on-call personnel to ensure that all stakeholders are aware of
4 the situation.

5

6 **2.3.6 Operation of Standby Units**

7 In its process of improving system reliability, Hydro has started to operate standby generation
8 in advance to cover generation or transmission outages equal to the worst case contingency
9 (for either Island or Avalon) and to maintain Island spinning reserves. Based on reserve
10 requirements, the Energy Control Center will operate the Hardwoods gas turbine, Holyrood
11 combustion turbine, and Holyrood diesel standby generating units (or a combination thereof) in
12 advance of the single largest Avalon contingency, rather than starting them after the event has
13 occurred. This maintains the Avalon reserve. This practice results in lower risk of customer
14 impact and unserved energy in the event of a contingency.⁸

15

16 For the Island, standby generation is started in advance to maintain appropriate spinning
17 reserves. In addition to the standby generation mentioned previously, the ECC will operate the
18 Stephenville gas turbine and the Hawkes Bay and St. Anthony diesel generators for Island
19 spinning reserves.

20

21 To support this improvement, Hydro's ECC operators now receive daily standby generation
22 requirements from System Operations, supporting both the Island Interconnected System and
23 the Avalon Peninsula transmission, which allows operators to understand predicted changes to
24 the load forecast and better plan for system continuity. The standby generation requirements
25 are sent each morning as part of the daily system status meeting notes to the daily system
26 status meeting participants. There is also a standby generation group email created that

⁸ An example of a contingency would be the loss of a major 230 kV transmission line that supplies the Avalon with power generated off of the Avalon. The contingency may occur in the future and therefore must be prepared for. http://www.nerc.com/files/concepts_v1.0.2.pdf

1 receives these notifications. The requirements are monitored throughout the day and if there
2 are any changes due to load forecast changes, System Operations will send a revised standby
3 requirement.

4

5 **2.4. Integrated Annual Work Plan (IAWP)**

6 The Operations and Engineering divisions within Hydro prepare an annual work plan (AWP) to
7 schedule and plan maintenance activities critical to providing customers with safe, reliable
8 electricity. These activities include capital projects, preventative maintenance, corrective
9 maintenance, non-maintenance, and operating project work. Once finalized, these plans form
10 the baseline for each division's work plan for the year.

11 Traditionally, each division prepared their plan in the first quarter of the year and then
12 executed that plan throughout the year, mostly in isolation from other regions. When outages
13 were required for work in that region, the regions would deal directly with System Operations,
14 who would then coordinate any conflicting work being scheduled across the regions.

15

16 Since 2014, Hydro has taken a more holistic approach to the work planning function and now
17 creates an integrated annual work plan (IAWP) that includes all capital and maintenance work
18 plans for all regions. The IAWP allows planners to get a full view of the annual resource
19 requirements, including peaks and valleys. The planners can then reschedule work so that the
20 peaks are reduced and valleys levelled, leaving the organization with a more realistic and
21 balanced work plan for the year. Any peaks that exist after this process are reviewed again and
22 external contractors are then engaged for critical pieces of work. This integration of work plans
23 has improved the coordination of equipment outages and improved communications between
24 Operations and Engineering Services.

25

26 Many of the maintenance items included in the IAWP are outage dependent and System
27 Operations have the final decision for planned outages. System Operations are engaged early

1 in the planning process and review with a holistic view of all required outages which allows
2 them to proactively detect any conflicts in the IAWP that would not be acceptable for system
3 continuity. System Operations will then adjust the outage schedule and eliminate conflicts to
4 maintain the integrity of the system. The IAWP is subsequently adjusted, thus improving
5 accuracy of scheduled equipment outages.

6
7 These integrated work planning processes have improved intra-company communications and
8 accuracy of the IAWP. The integrated annual work plan has become a core process for work,
9 outage and resource planning and has a direct impact on customer reliability.

10

11 **2.4.1 Winter Readiness Plan**

12 The winter period is a critical time period for Hydro. Newfoundland and Labrador winters
13 exhibit significant variability in temperature and other weather conditions. Winter will bring
14 below freezing temperatures, snowfall, freezing rain, high winds and other extreme weather
15 conditions, such as blizzards. Hydro recognizes that power system reliability over these months
16 requires assets to be in peak condition so that they can perform optimally in these extreme
17 conditions.

18

19 The Winter Readiness Plan is a subset of the IAWP and was created to ensure system reliability
20 during the winter months. It includes those preventative maintenance, corrective
21 maintenance, and capital project work items that are considered necessary to ensure that
22 Hydro has the generation, transmission, and distribution equipment ready for the upcoming
23 winter season. The deadline for completing these items is December 1 of each year and Hydro
24 reports its progress of winter readiness items to the Board on September 30, October 30, and
25 November 30 for the upcoming winter season.

26

27 The creation of the Winter Readiness Plan helps Hydro set priorities and create work plans that
28 focus on being ready for the upcoming winter season. If it is anticipated that winter readiness

1 items will not be completed by November 30, Hydro completes a risk assessment of each item
2 and a recovery plan to complete the necessary work, or develops risk mitigation strategies, as
3 required.

4

5 **2.4.2 Maintenance Tracking Report**

6 Hydro regularly measures and tracks its progress towards the completion of its IAWP, down to
7 the level of individual work plan items. Traditionally, regions tracked the progress of their
8 individual work plans using traditional project management software. In March 2016, following
9 the completion of the baseline IAWP, a maintenance tracking system was implemented using
10 Hydro's enterprise project portfolio management software. The tracking system includes the
11 annual work plans for each division that collectively create the IAWP.

12

13 The planners within each division track progress towards completion of their work plan and
14 progress is then reported bi-weekly in the maintenance tracking report. The report shows
15 progress within each division and then for Hydro as a whole. As maintenance progresses and
16 plans need to be adjusted, the planners within each division adjust their original plans. These
17 adjustments may include the removal of non-critical activities, the addition of activities, or
18 rescheduling of activities. The Maintenance Tracking Report tracks these adjustments.

19

20 This report is delivered to Hydro Management bi-weekly and improves management's visibility
21 to IAWP progress. If issues have been encountered, management are made aware promptly,
22 thus giving them time to enact mitigation strategies and host risk-based discussions for any
23 items not completed or that are impacted by changes.

24

25 Hydro has also developed an outage tracker with a look ahead on equipment outage readiness.
26 This provides visibility on factors that can affect upcoming maintenance or capital work, such as
27 permitting or resource availability. Any areas that may prove a risk to readiness are flagged and
28 addressed in advance of outages to ensure the plan can proceed (see section 2.5).

1 **2.5 Equipment Outage Management Tracker**

2 In February 2016, Hydro implemented an Equipment Outage Management Tracker, displayed in
3 Appendix F, to minimize impact on customers, improve the efficiency of work planning, manage
4 the duration of planned outages, and improve overall system reliability. The outage
5 management tracker was reviewed twice weekly at the daily system status meeting leading up
6 to and during maintenance and construction season and was reviewed more frequently by the
7 regions completing the work. It is a risk management tool that is linked to the IAWP and
8 captures all upcoming planned outages for generation, transmission and stations. The outage
9 tracker has become an essential tool for Operations in ensuring that planned outage durations
10 are minimized and do not introduce an unacceptable level of risk to customers on the Island
11 Interconnected System.

12
13 Each planned outage can require a number of mandatory permits, involve a number of internal
14 and external stakeholders, and consist of various levels of complexity. The outage tracker
15 formally documents requirements that are critical to the outage and ensures their
16 preparedness before any outage will proceed, thus ensuring outage time is minimized to just
17 the essential tasks. The tracker ensures work is ready to proceed.

18
19 The Planned Outage Database gives the Energy Control Center a single-view of all upcoming
20 planned outages. This single-view allows the operators to review all of the planned outages for
21 that day and make a reliability assessment. If too much risk is introduced to the power system
22 by the planned outages due to system conditions (i.e. other equipment out of service, weather,
23 etc.) then an outage will not proceed and modifications to the planned outage schedule will be
24 required to reduce the level of risk. The outage tracker provides a status update for each
25 planned outage and all items must be checked in the outage tracker before being approved in
26 the Planned Outage Database. This updated status in the Outage Management Tracker is used
27 in conjunction with the Planned Outage Database to give the ECC and Operations a clear picture
28 of the upcoming planned outage requests, and a better line of sight for managing system risks.

1 **2.6 Reintroduction of Hot Line Work**

2 Hot line work, also referred to as live-line work, refers to the maintenance and upgrade of
3 electrical equipment, often at high voltage, while the equipment is still energized. Hot line
4 work techniques can be used in a variety of maintenance activities, including changing and
5 testing of insulators, replacing damaged sections of conductors, replacing transmission poles,
6 and other maintenance activities.

7
8 Performing maintenance on energized electrical equipment can be dangerous as one mistake
9 can result in fatalities. As a result, hot line work requires line crews to be trained in live-line
10 work techniques and use specialized equipment and procedures that prevent potentially
11 hazardous voltage differences across the worker's body. Hydro stopped utilizing live-line
12 techniques after two incidents resulting in fatalities occurred during the maintenance of
13 energized equipment. At the time, there were concerns of further incidents so system outages
14 became the preferred method for performing maintenance activities.

15
16 Safety standards and specialized training exist that together allow live-line work to be
17 completed safely. There are many advantages to utilizing hot line work techniques. It allows a
18 utility to complete maintenance activities with fewer planned outages, thus maintaining
19 continuity of service for customers, and provides greater flexibility for maintenance activities,
20 allowing for efficiency of operations. Overall, hot line maintenance techniques improve system
21 reliability and stability for customers.

22
23 Recognizing the advantages that hot line techniques deliver, Hydro has begun to reintroduce
24 this maintenance approach and now utilizes contractors trained in hot line work techniques to
25 perform live-line maintenance activities. In 2016, Hydro utilized hot line work to repair a
26 damaged splice on one of its Avalon Peninsula 230 kV transmission lines and to also replace
27 insulators on the Bottom Waters system. Both the 230 kV transmission line and Bottom Waters
28 work were critical to providing reliable power and Hydro was able to complete necessary

1 maintenance to ensure the integrity of the system, while avoiding any disruption of power to
2 customers.

3

4 Hydro is currently finalizing recommendations to further introduce and utilize hot line
5 techniques to both transmission and distribution work activities over the coming years.

6

7 **3.0 Improving Reliability Engineering and Analysis Skills and Capabilities**

8 Liberty recommended that “Hydro should enhance the skills and capabilities it brings to
9 reliability engineering and analysis.”⁹ Hydro is committed to the development of its personnel
10 and will continue to look for opportunities to improve staff’s training and knowledge in the
11 fields of reliability engineering and analysis.

12

13 As detailed throughout this report, Hydro has enhanced its reliability foundation over the past
14 number of years and increased medium to long term capital investment planning. As outlined
15 in Section 2.3.4 of this report, Hydro has introduced capacity assessment criteria for the Avalon
16 Peninsula that are used to make decisions from both an operational and communications
17 perspective.

18

19 The sections below outline other actions that have provided improvements in these areas.

20

21 **3.1 Energy Control Center Operator Training**

22 Hydro recognizes the importance that ECC operator training has in regards to improving its
23 skills and capabilities of ECC operators for system reliability.

24

25 Hydro has an Operating Training Simulator (OTS) training facility for the Energy Control Center
26 operators. Previously, the training space was a shared space with the Corporate Emergency

⁹ The Liberty Consulting Group, “Review of the Newfoundland and Labrador Hydro March 4, 2015 Voltage Collapse,” October 22, 2015, at page 10.

1 Operations Center (CEOC) and consisted of one trainee console and a console for the trainer. In
2 2016, Hydro created a dedicated OTS Training Facility for operators. This facility includes
3 training consoles for operators, a separate console for the trainer, and has its own training
4 digital video wall display. It can simultaneously train up to 3 operators.

5
6 The Operator Training Simulator is used to train the system operators in both normal and
7 emergency operation of the power system. Scenarios are developed which simulate various
8 generation and load configurations. The OTS simulates real-time operation, allowing system
9 operators to see the impact of contingencies, learn how to respond to events, and complete
10 restorations.

11
12 OTS training is scheduled three times each year. Many different scenarios have been developed
13 to simulate contingencies on the Interconnected Island System, including scenarios on the
14 Avalon Peninsula. These scenarios have components of monitoring power system elements
15 such as acceptable voltage levels, transmission line loadings, and frequency. As the system
16 operators go through the simulation of restoration, they learn how load restoration impacts
17 system voltages. The system operators must maintain these voltages within acceptable levels.
18 As well, there are system operating instructions that are relevant to these scenarios that are
19 used as part of the training. These instructions are procedures for restoration and maintaining
20 acceptable operating criteria. In essence, the OTS training also keeps the system operators up
21 to date on these operating instructions.

22
23 System operators have also been given training in alarm monitoring and management. This
24 was completed as part of an OTS training session and was developed to ensure the system
25 operators identify critical terminal station alarms and understand the appropriate response to
26 the alarm. Essentially, before restoration can commence, if there are alarms at the station, a
27 discussion with the asset owner needs to take place. The alarms would need to be cleared or

1 permission given to the Energy Control Center to proceed depending on the nature of the
2 alarm.

3

4 System Operations uses the OTS to continually improve the knowledge of operators. The
5 simulator can be programmed with different contingencies based on real world learnings. For
6 example, an OTS session was also developed that simulates the events of March 4, 2015. All of
7 Hydro's Energy Control Center operators participated in this simulator training session, where
8 they experienced declining voltages on the Avalon power system and acted accordingly to
9 stabilize and restore the system.

10

11 The new training facility will be critical to System Operations as the Maritime Link (ML) and
12 Labrador Island Link (LIL) are commissioned and operators are trained to manage these new
13 assets and interconnectivity with the North American power grid.

14

15 **3.2 Corporate Reorganization of System Operations**

16 Hydro has completed organizational changes that demonstrate the importance of a structured
17 and focused system operation's function. Some of the changes are being made to support the
18 creation of the Newfoundland Labrador System Operator (NLSO) and other changes are part of
19 continuous improvement initiatives. Section 7.1 provides an overview of the changes being
20 made in advance of the creation of the NLSO. This section outlines current organizational
21 changes that have added to the department's capabilities, and the removal of peripheral tasks
22 has increased staff's focus on their primary responsibilities, ultimately leading to improved
23 system reliability.

24

25 The Transmission Planning Department has been integrated with the System Operations
26 Department. Collocated in the same office space, the transmission planning and system
27 operation's staff are now able to work closer together. This change has helped to improve
28 communications and cohesion between operations and transmission planning.

1 To improve focus on primary functions, the tasks of industrial customer billing and invoicing
2 and meter validation have moved to Customer Service. Water management has been moved
3 from System Operations to Production (December 2016) and fuel/power purchase forecasting
4 and budgeting is currently being transitioned to Production. The requirement for System
5 Operations to report on asset failures has now been transitioned to Regulatory Affairs. Asset
6 owners now send their outage reports to Regulatory Affairs, who subsequently send to the
7 Board. System Operations are no longer tasked with submitting outage reports on behalf of the
8 organization.

9
10 Traditionally, the industrial customer relationships were managed inside System Operations. In
11 2016, Hydro created a Manager, Key Accounts position within Customer Service that is now
12 accountable for the overall relationship between Hydro and its key industrial and general
13 service customers across the Province. This Manager is the single point of contact for all
14 services and communications provided by Hydro to its industrial customers and leads the
15 resolution of electricity-related issues impacting key customers. This allows the Energy Control
16 Centre Operators and System Operations to focus on the power system. For the customer, the
17 Manager, Key Accounts has a much deeper understanding of the customers' business
18 operations and can advocate on their behalf when planned outages and other pertinent
19 matters are being discussed. The Manager, Key Accounts is the single point of contact for their
20 interactions with Hydro and keeps industrial customers informed of planned outages, meets
21 with them on a regular basis to understand their short-term and long-term needs, and
22 navigates the internal Hydro organization for resolution to their questions, issues, and
23 concerns. Understanding a customer's long-term plans allows Hydro to be more proactive and
24 adjust its capital plans, if it is foreseen that improvements and/or enhancements will be
25 necessary to meet customer requirements.

26
27 Hydro has also improved its after hours support for customers. Previously, the Energy Control
28 Center was tasked with answering customer inquiries during planned and unplanned outages.

1 This was distracting and prevented the Energy Control Centre from focusing on issue resolution
2 and power system management. A third party vendor was engaged to provide first-line
3 response to customer inquiries for both planned and unplanned power interruptions that occur
4 after business hours. The vendor was trained in Hydro's processes for dealing with power
5 interruption inquiries and can engage on-call staff as required to follow-up with customers on
6 resolution of issues after business hours. This change in process has been well received by both
7 customers and staff.

8

9 All of these changes allow System Operations to focus their efforts on the primary goal of
10 maintaining a stable and reliable Island Interconnected System. This focused structure also
11 allows the System Operations staff to plan for the integration of new assets that will be
12 introduced as part of the Muskrat Falls Project and plan for the creation of the NLSO.

13

14 **3.3 Supply Planning and Risk Assessment**

15 In 2016, in an effort to improve its transparency, Hydro conducted a comprehensive energy
16 supply risk assessment of its ability to meet Island Interconnected System energy and demand
17 requirements until the expected interconnection with the North American grid.

18

19 The Energy Supply Risk Assessment is an in-depth review of all of Hydro's assets and includes
20 load forecast analysis methodology for assessing Hydro's ability to meet the demands of the
21 Island Interconnected System and the Avalon Peninsula major load center. This assessment
22 represents a significant milestone in Hydro's evolution towards improving its system planning
23 techniques and reliability engineering.

24

25 The purpose of the Energy Supply Risk Assessment is to:

- 26 • Analyse the reliability of Hydro's existing generation assets, including: a) the thermal
27 generation assets at the Holyrood Thermal Generating Station, b) the gas turbines at
28 Hardwoods and Stephenville, and c) Hydro's hydraulic generating facilities;

- 1 • Determine Hydro’s ability to meet its demand requirements given the projected
- 2 reliability of these assets;
- 3 • Determine expected reliability for these assets through to the interconnection period;
- 4 • Analyse and determine Hydro’s ability to meet its energy requirements for a range of
- 5 unit reliabilities in consideration of the historical dry sequence;
- 6 • Consider alternative load growth scenarios and Hydro’s ability to meet the associated
- 7 change in forecast demand; and
- 8 • Provide alternatives and options to mitigate exposure, if required.
- 9

10 Hydro filed its energy supply risk assessment with the Board on May 27, 2016,¹⁰ and submitted
11 an updated copy of the report on November 30, 2016.¹¹

12
13 This review provided Hydro staff with focus on the critical asset components that must be
14 addressed within the IWAP. Hydro’s asset reliability is a critical component in determining its
15 ability to meet its generation and transmission planning and load forecasting criteria.

16
17 Based on the findings of the November 2016 energy risk assessment, Hydro is confident in its
18 ability to meet Island Interconnected System requirements from an energy and capacity
19 perspective. Hydro also concluded that until interconnection to the North American grid is
20 achieved, for the sensitivity cases only, there is some risk of minimal unserved energy in excess
21 of planning criteria for the current winter of 2016-17.¹²

¹⁰ Newfoundland and Labrador Hydro, “Energy Supply Risk Assessment –May 2016.” Available at:
<http://pub.nl.ca/applications/IslandInterconnectedSystem/phasetwo/files/reports/From%20NLH%20-%202015-2019%20Energy%20Supply%20Risk%20Assessment%20-%202016-05-27.PDF>

¹¹ Newfoundland and Labrador Hydro, “Energy Supply Risk Assessment –November 2016.” Available at:
<http://pub.nl.ca/applications/IslandInterconnectedSystem/phasetwo/files/reports/From%20NLH%20-%20Energy%20Supply%20Risk%20Assessment%20Report%20-%20UPDATED%20November%202016%20-%20Revision%201%20-%202017-01-26.PDF>

¹² In one case, the load that is forecast to decline actually stays stable, and in the other case, the industrial load is assumed to increase compared to forecast.

1 The following sections outline the methodology and planning criteria used to make this
2 determination and the strategies that Hydro is using to mitigate this risk. An updated Energy
3 Supply Risk Assessment will be submitted to the Board in May 2017 that includes updated
4 system demand forecast, updates to new asset deliverables, and other changes based on
5 Hydro's assessment of current system realities. Hydro will also review Liberty's assessment of
6 the November 30, 2016, Energy Supply Risk Assessment and make updates or additions where
7 appropriate.

8

9 **3.3.1 Demand Forecast Analysis**

10 Hydro bases its generation supply planning decisions for the Island Interconnected System on a
11 P90¹³ peak demand forecast.¹⁴ The P90 peak demand forecast reflects the associated increase
12 in demand over the normalized (P50) peak demand forecast resulting from instances of severe
13 wind and temperature. The development of the P90 peak demand forecast is an extension of
14 Hydro's regularly prepared system operating load forecast and allows Hydro to assess its ability
15 to reliably supply customers in instances of extreme weather conditions.

16

17 Hydro prepares its initial demand forecast in the spring of each year subsequent to receiving
18 Newfoundland Power's load forecast update and the available industrial customer demand
19 forecast updates. Hydro will subsequently revise its demand forecast in the fall, taking account
20 of industrial customer's power requirement plans which are set in the fall for the following year
21 and allowing for any revisions to Newfoundland Power's demand requirements. These demand
22 forecasts are then used in the creation of the yearly Energy Supply Risk Assessment.

¹³ A P90 forecast is one in which the actual peak demand is expected to be below the forecast number 90% of the time and above 10% of the time.

¹⁴ In accordance with direction in the Board's letter to Hydro regarding Investigation and Hearing into Supply Issues and Power Outages on the Island Interconnected System - "Directions further to the Board's Phase One Report", received October 13, 2016.

1 As part of the 2016 Energy Supply Risk Assessment, Hydro updated its peak demand forecasts
2 to reflect the latest available customer and system information available. The revised forecast
3 was then used to review reliability of generation assets.

4

5 Hydro studied its demand forecasts with two planning criteria including:

6 a) An Expected Case,¹⁵ and

7 b) A Fully Stressed Case for three different demand forecast projections,¹⁶ including:

8 1) Sensitivity Load Projection I (the stable utility demand case),¹⁷

9 2) Sensitivity Load Projection II (the high industrial coincidence),¹⁸ and

10 3) Sensitivity Load Projection III (the high utility coincidence).¹⁹

11 Based on the projected asset reliability and demand forecasts listed in the November 2016
12 Energy Supply Risk Assessment, neither the Expected Case nor the Fully Stressed Reference
13 Case result in Expected Unserved Energy (EUE)²⁰ in excess of planning criteria beyond the
14 current winter of 2016-17 for either of the three sensitivity load projections. Both Sensitivity
15 Load Projection II (the high industrial coincidence) and Sensitivity Load Projection III (the high
16 utility coincidence) estimated a demand forecast result in EUE in excess of planning criteria for
17 the winter 2016-17, only. This EUE in excess of planning criteria is observed for these cases
18 despite having a relatively low increase in demand forecast for winter 2016-17 over the base
19 case forecast, 9 MW and 12 MW, respectively.

¹⁵ The Expected Case reflects Hydro's anticipated system capability and the P90 demand forecast with scheduled in-service of the Labrador Island Link and Maritime Link.

¹⁶ The Fully Stressed Reference Case is a conservative analysis reflecting Hydro's anticipated capacity in consideration of the P90 peak demand forecast should no interconnection to the North American grid be established through winter 2019-20.

¹⁷ Sensitivity Load Projection I - Stable utility demand: Assumes that in spite of the current forecast, which is for reduced energy requirements relative to 2015, demand requirements remain stable (i.e. lower load factor).

¹⁸ Sensitivity Load Projection II - High industrial coincidence: Includes increased industrial load requirement over Hydro's base case expectation assuming less diversity in industrial customer demand requirements at island Interconnected system peak.

¹⁹ Sensitivity Load Projection III - High utility coincidence: Includes increased utility load requirement over Hydro's base case expectation assuming less diversity in utility customer demand requirements at Island Interconnected system peak.

²⁰ Expected Unserved Energy (EUE) is the summation of the expected number of MWh of load that will not be served in a given year as a result of demand exceeding available capacity.

1 To mitigate this risk, Hydro has undertaken initiatives to secure additional curtailable Avalon
2 Peninsula load to reduce the identified transmission exposure (see Section 3.3.3) and has
3 accelerated the in-service of the third 230 kV transmission line from Bay d'Espoir to the Avalon
4 Peninsula (TL267). The in-service of TL267 for winter 2017-18 more than mitigates any
5 additional exposure for EUE in excess of planning criteria (see Section 3.3.2).

6

7 **3.3.2 Accelerated Construction of Transmission Line TL267**

8 On April 30, 2014, Hydro filed an application for approval to construct a 230 kV transmission
9 line between Bay d'Espoir Hydroelectric Generation Station and Western Avalon Terminal
10 Station at Chapel Arm, including upgrades at both stations to accommodate the new
11 infrastructure.

12

13 The transmission line project, now known as TL267, will increase Hydro's capability to deliver
14 power to the major load centre on the Avalon Peninsula and will ensure the continued stability
15 and reliability of the Island Interconnected System, particularly during faulting events. TL267
16 will help Hydro meet the long-term power requirements of the Island Interconnected System
17 by providing additional capacity, enhancing resiliency to system faults, and relieving congestion
18 on the existing transmission system.

19

20 Accelerating the in-service date of TL267 to October 31, 2017, will increase Hydro's capability to
21 deliver power to the major load centre on the Avalon Peninsula and transmission constraints on
22 the Avalon Peninsula will be eliminated to the extent that the loss of two Holyrood units will
23 not result in transmission system violations.

24

25 As requested by the Board on July 19, 2016, Hydro has been filing monthly reports since
26 September 15, 2016, that provides a status of this project. As stated in the March 12, 2017,
27 report, the construction of TL267 is on schedule and Hydro is working aggressively to deliver
28 this project on schedule for the 2017-2018 winter season.

1 **3.3.3 Capacity Assistance Agreements**

2 Capacity assistance agreements with industrial customers are used by many utilities as a way to
3 reduce peak load by having large customers interrupt their operations. Hydro's capacity
4 assistance arrangements are considered an appropriate utility practice and have been
5 negotiated as an instrument of insurance for system reliability. The capacity assistance
6 agreements allow for the purchase or curtailment of power from industrial customers.²¹ For
7 multiple reasons, demand can exceed Hydro's capability to generate and/or distribute the
8 required power to meet the need. Usually there is a hierarchy of customers, in which some
9 may be required to partially or totally reduce their power consumption. Industrial users, for
10 example, are usually curtailed before service to residential users is reduced.

11

12 Hydro presently has capacity assistance agreements in place with the following industrial
13 customers:

- 14 • 60 MW of capacity assistance from Corner Brook Pulp and Paper Limited (CBPP), as per
15 Board Order P.U. 49(2014). CBPP interrupts its production activities to provide this
16 capacity assistance to Hydro.
- 17 • 30 MW of capacity assistance from CBPP through a further interruption of mill
18 operations, via the Supplemental Capacity Assistance Agreement.
- 19 • 7.6 MW of capacity assistance from Vale Newfoundland & Labrador Limited (Vale) to be
20 provided to the Island Interconnected System from Vale's standby diesel generating
21 facilities.²²
- 22 • In December 2016, a 5 MW interruptible agreement was reached with Praxair Canada
23 Inc. (Praxair), as per Board Order P.U. 55(2016).
- 24 • In January 2017, as per Board Order P.U. 3(2017), a 6 MW interruptible agreement was
25 reached with Vale.

²¹ Curtailment is the reduction of power delivery to a customer due to a shortage of supply.

²² The agreement allows for up to 15.8MW of capacity assistance, with a test of Vale's diesel generating facilities each year. The test completed in 2016 confirms 7.6MW of capacity assistance for winter 2016-2017.

1 Hydro can also request Newfoundland Power to utilize its Curtailable Service Option to reduce
2 its load requirements. The amount of curtailable load that is forecasted to be available for
3 winter 2016-2017 by Newfoundland Power is 11 MW.

4
5 These capacity assistance agreements help to maintain generation reserves on both the Island
6 Interconnected System and Avalon Peninsula systems and, in the case of significant system
7 events, help to lessen the impact on residential customers. These agreements proved to be
8 prudent actions, as capacity assistance requests were issued during the winter of 2014-2015,
9 winter of 2015-2016, and winter of 2016-2017. These agreements have provided Hydro with
10 operational flexibility during times of higher demand and/or unforeseen system events and
11 were a core element in the company's pursuit of increased reliability and system continuity.

12

13 **3.4 Equipment Failure Review Enhancements**

14 Hydro has improved its new model for investigating equipment failures. Traditionally,
15 individuals from the immediate operational area worked to primarily fix the issue and
16 subsequently look for the root cause of the equipment failures.

17

18 In the new model, a broader focus to find the root cause of equipment failure is mandatory and
19 frequently involves internal experts from across the organization, addressing issues with
20 increased urgency. Lessons learned from previous equipment failures are also captured and
21 incorporated into the current investigation so that insights learned during previous equipment
22 investigations can be applied to the current review.

23

24 The investigation of the unit trip issue at Paradise River is one such example of the improved
25 and more inclusive equipment review model. Paradise River is a hydroelectric generating plant
26 that generates 8 MW of electrical power. The plant had been experiencing an increasing
27 number of unit trips through 2016 in comparison to previous years. From January to mid-
28 November 2016, the plant experienced almost 30 unit trips, compared to 4 in 2014 and 11 in

1 2015. No cause could be determined for a high proportion of the trips in 2016, despite a
2 thorough review and inspection by staff at the plant.

3
4 Hydro expanded the review team, incorporating expertise from across the organization, to
5 complete a more extensive review to determine the cause of the repeated trips.²³ The cross-
6 departmental team developed a set of actions to structure the investigation. Following the
7 cross-departmental investigation plan led Hydro to work with Newfoundland Power to replace
8 a recloser²⁴ in their Monkstown substation. Since the installation, there have been no trips of
9 the plant with an undetermined cause. This is a significant improvement over the frequency
10 experienced prior to replacement.

11
12 This model is now being rolled out across the organization with the mandate of more consistent
13 investigation and reporting, ultimately improving equipment reliability.

14

15 **3.5 Membership in the Center for Energy Advancement through Technological** 16 **Innovation**

17 Hydro joined the Centre for Energy Advancement through Technological Innovation's (CEATI's)
18 Power System Planning & Operations program to gain access to additional technical expertise
19 and support Hydro's broad-based focus on system reliability.

20

21 The CEATI Program Model provides electrical utilities with a cost-effective vehicle for sharing
22 experiences and addressing issues pertinent to their day-to-day operations, maintenance, and
23 planning. The Power System Planning & Operations program's areas of focus include: a)
24 planning and operations practices, including high-voltage direct current planning solutions, b)

²³ It has been hypothesized that the distribution line into which the plant is connected may be experiencing some system disturbances. Paradise River plant is connected to the Island Interconnected System via a distribution line, as opposed to a dedicated transmission line.

²⁴ A recloser is a protection device for electrical distribution networks. It combines a circuit breaker that trips if an overcurrent is detected with an electronically-controlled reclosing function that automatically restores power to the affected line if the fault clears itself quickly.

1 methods for increasing capacity and security, and c) modern simulation and modelling tools
2 and techniques. The strategic direction of Power System Planning & Operations program is
3 "...to enable the use of new technologies, including FACTS²⁵, to enhance the use of existing and
4 new transmission facilities while continuing to maintain a high level of reliability. This includes
5 exploring and developing tools and techniques for planning and operating transmission systems
6 in a reliable, secure and cost-effective manner."²⁶

7

8 **4.0 Improving Situational Awareness**

9 Liberty recommends that "Hydro should take steps to assurance situational awareness among
10 operators and others who need the information to respond promptly and ably to adverse
11 system conditions."²⁷ Situational analysis refers to the methods that staff utilize to analyze
12 Hydro's environment with the goal of better understanding the organization's capabilities,
13 constraints, customers, and other operational influences.

14

15 Hydro now places a greater focus on the end-consumer of power, rather than its end-point of
16 power delivery. This change in operational philosophy has led to multiple enhancements, one
17 being its improved situational awareness. Key personnel within Hydro are better informed of
18 system's vulnerabilities and are better prepared to react to system events.

19

20 **4.1 Internal and External Communications**

21 Improving situational awareness starts with improved communications. Hydro has taken many
22 actions to improve both its internal and external communications. The Daily System Status
23 Meeting hosted by System Operations described in section 2.3.1 provides participants with
24 daily updates on Hydro's supply capability and reserves and other conditions that could impact

²⁵ Flexible Alternating Current Transmission System (FACTS) are electronic devices that allow for quick adjustments to control the electrical system. The benefits they offer include improved stability of the grid, control of the flow of active and reactive power on the grid, loss minimization, and increased grid efficiency.

²⁶ <https://www.ceati.com/collaborative-programs/transmission-distribution/pspo-power-system-planning-operations>

²⁷ The Liberty Consulting Group, "Review of the Newfoundland and Labrador Hydro March 4, 2015 Voltage Collapse," October 22, 2015, at page 10.

1 the reliability of the Island Interconnected System and Avalon Peninsula. Hydro Executive and
2 Management representatives from the various functional areas, including Production,
3 Transmission, Distribution, System Operations, Communications, and Regulatory Affairs all
4 participate, which has improved internal communications and system status understanding
5 within Hydro.

6

7 If Environment Canada has posted special weather statements related to wind, rain, freezing
8 rain, and/or snow, that have the potential to negatively impact the Island Interconnected
9 System or the Avalon Peninsula, then Hydro will host a Storm Preparation Meeting, as
10 described in section 2.3.2. These meetings provide a structured review of the current state of
11 the system, the preparedness of each operational area, and ultimately improve situational
12 awareness and system reliability by ensuring that each operational area is ready to respond
13 quickly and effectively to any severe weather impacts.

14

15 Maintenance of Hydro's systems and equipment often require planned power outages to
16 complete. Hydro uses the Planned Outage Database and the Equipment Outage Management
17 Tracker, described in section 2.5, to provide staff with a complete picture of existing and
18 upcoming planned outages. The Planned Outage Database gives the ECC a single-view of all
19 upcoming planned outages. It allows operators to see the impacts of concurrent outages and if
20 too much risk to the system is introduced by multiple planned outages, the planned outages
21 will be modified to reduce the level of risk to the Island Interconnected System.

22

23 The Equipment Outage Management Tracker provides a current status update for each planned
24 outage listed in the Planned Outage Database. The outage management tracker is linked to the
25 IAWP and captures all upcoming planned outages for generation, transmission and stations. The
26 status in the outage management tracker is used in conjunction with the outage database to
27 give operations a clear picture of the status of upcoming planned outage requests.

1 Hydro has also improved its communications with external stakeholders, including
2 Newfoundland Power, its industrial customers, end consumers (residential), and the Board.
3 Hydro's General Manager of System Operations will contact their Newfoundland Power
4 counterpart to review any noteworthy items that came out of the meeting. The General
5 Manager will also follow-up with a weekly report to Newfoundland Power. The Hydro ECC
6 Supervisor will also follow-up with their counterpart at Newfoundland Power to discuss
7 noteworthy items with a more detailed technical scope. This is done on a regular basis to
8 discuss any upcoming planned outages to ensure common understanding.

9

10 The Advance Notification Protocol (see section 6.0) was developed to proactively communicate
11 important information to customers, with clear direction on actions required, based on
12 forecasted supply shortages and Hydro's ability to supply customers on the Island
13 Interconnected System. Recognizing the importance and intricacies of power delivery to the
14 Avalon Peninsula, the operating instructions and Advance Notification Protocol were updated
15 after March 2015 to include additional protocols specific to the Avalon Peninsula.

16

17 Finally, since January 10, 2014 Hydro has prepared a daily supply and demand report for the
18 Board, based on their reporting guidelines. The report gives the Board visibility to the current
19 state of the Island Interconnected System. It includes the amount of electricity being generated
20 to meet the needs of customers, the amount electricity needed by residential and business
21 customers, the current state of generation facilities and the current and forecasted weather
22 conditions. Hydro also produces and provides several other regular reports for the Board,
23 including Power Outage and Incident Reports, 12 Month Rolling Generation quarterly reports,
24 monthly Energy Supply Reports, and a semi-annual Nostradamus Report. These reports serve
25 to provide regular updates on system status and maintain open communication and
26 accountability of the system. Hydro's Manager, Regulatory Engineering also provides regular
27 updates to the Board whenever there is an active or pending system issue, which could include
28 weather events, unplanned outages, or other event impacting the integrity of the system.

1 All of these communication improvements make Hydro and its stakeholders more observant of
2 the risks and current constraints facing the Island Interconnected System and Avalon Peninsula.

3

4 **4.2 Improved Strategic Focus of System Operations**

5 Changes to Hydro's organizational structure have improved Executive focus on Hydro's core
6 mandate to provide customer with safe, least cost, reliable power and the principal functions of
7 generation and transmission. As described in section 3.2, Transmission and Planning was
8 merged into the System Operations organization which has helped to improve the interface
9 between operations and planning. This change facilitates and stronger working relationship,
10 leading to improved cooperation and outcomes.

11

12 Strategic organizational changes have also been made within System Operations. The tasks of
13 billing, invoicing, and meter validation have moved to Customer Service. Water management
14 has been moved from System Operations to Production and fuel/power purchase forecasting
15 and budgeting is currently being transitioned to Production. The requirement for System
16 Operations to report asset failures has been transitioned to Regulatory Affairs.

17

18 All of these changes allow System Operations and Transmission Planning to focus their efforts
19 on the primary goal of maintaining a stable and reliable Island Interconnected System. This
20 focused structure also allows the System Operations staff to plan for the creation of the NLSO
21 (see section 7.2) and the integration of new assets that will be introduced as part of the
22 Muskrat Falls Project.

23

24 **4.2.1 Early Engagement of System Operations in IAWP**

25 As described in section 2.4, the IAWP includes all capital and maintenance work plans for all
26 regions for the given year. One noted improvement in the creation of the 2016 IAWP was the
27 involvement of system operations staff in the development process. Engaging System

1 Operations in the planning phase allowed for proactive system balancing of generation and
2 transmission outages.

3
4 With a view to all required outages, System Operations proactively detects conflicts and
5 eliminates them during planning, rather than taking reactionary measures later in the
6 maintenance season to ensure system continuity. Engaging System Operations early in the
7 IAWP process has improved the accuracy of scheduled equipment outages.

8

9 **4.2.2 Improvements to the Energy Control Center**

10 Hydro has made extensive improvements in its Energy Control Center that provide operators
11 with improved visibility and an enhanced holistic view of the Provincial power grid. The
12 physical space has been reconfigured to improve operator focus on the grid and the enhanced
13 situational awareness tools added to the ECC allow operators to proactively monitor the power
14 grid and identify and respond to system events quickly. These improvements include:

15

16 **1. Installation of Digital Video Wall**

17 Commissioned in November 2016, the new digital video wall provides flexibility and an
18 improved holistic view of the provincial power grid than its static wall predecessor. The
19 video wall consists of two components: a) the One Line Display and b) the Geographic
20 Display.

- 21 • The **One Line Display** shows the single line version of the provincial grid. It
22 includes all power sources, transmission lines and status of each line.
- 23 • The **Geographic Display** is part of the digital display wall and includes a digital
24 map of Newfoundland and Labrador, and the tip of Nova Scotia.



Figure 3: ECC Display (Pre Upgrades)



Figure 4: ECC One Line Display (Post Upgrade)

1 **2. Situational Awareness Tool**

2 The existing situational awareness tool has been integrated with the video wall to
3 provide operators with:

- 4 • A single-view of alarms for transmission lines approaching limits;
5 • A single-view to transmission line outages; and,

- 1 • Graphical indicators of the megawatts and directional flow of power on each
2 transmission line.

3
4 These changes provide the operators with better visibility and awareness of the power
5 grid and highlight potential issues of which they should be aware. Previously, the
6 transmission line views were spread over multiple screens and operators only had
7 visibility to one screen at a time. Using the new video wall, the operators get a full
8 system view of the transmission lines without having to navigate through multiple
9 screens.

10
11 The video wall will highlight any transmission line reaching pre-defined threshold limits
12 for the operator and will dynamically change the color of any transmission lines outages,
13 either planned or unplanned. Newly added directional flow indicators will become
14 critical once the Labrador Island Link (LIL) and Maritime Link (ML) are commissioned.

15
16 **3. Lightning Graphic System**

17 The lightning graphic system is now part of the geographic display. This system provides
18 the operator with a visual representation of the power grid, including Labrador, overlaid
19 with lightning weather systems. Previously, this system was available on the operator's
20 desktop screen and was not visible to the operator at all times.

21
22 Integrating the lightning graphic system with the geographic display gives operators
23 better visibility of potential lightning strikes and allows them manage the grid while
24 maintaining visibility to such events.



Figure 5: ECC One Line and Geographic (highlighted in red) Displays



Figure 6: ECC Geographic Display

1 **4. Contingency Analysis Tool**

2 The contingency analysis (CA) tool was installed on the ECC Display Wall in February
3 2017 and is being developed with an expected completion date in April 2017. The CA
4 tool defines contingency violations for regional areas (zones) based upon a
5 predetermined set of transmission line and bus violations and provides a visual means

1 of quickly identifying where a contingency violation could potentially occur. For
2 example, this application indicates to the system operators the single worst-case
3 contingency on the power system at the time the application runs. CA has a number of
4 equipment outages defined and will run a load flow for each contingency. The
5 application then ranks each contingency in the order of severity and the results are
6 displayed to the system operators. The severity is rated both from a voltage and
7 thermal overload perspective. CA runs on the EMS automatically and is updated every
8 five minutes.

9
10 Hydro has identified nine regional areas within the CA tool, five of these areas have
11 been defined with CA rules and four others will be expanded upon once new assets
12 come on line. Three warning levels have been developed for these regional areas
13 including: Normal (0% CA Violation), Yellow (<5% CA Violation) and Red (<10% CA
14 Violation). The CA warnings will be displayed as a highlighted border around each area
15 that has a violation. This will prompt operators to drill deeper into the system to
16 determine cause and potential solution to the CA violation.

17 18 **5. Spinning Reserves Display**

19 The spinning reserves are charted for operators to visually see spinning reserves on a
20 real-time basis. This running chart provides operators with a visual target for
21 monitoring and feedback. This is further enhanced by an audible alarm should the
22 spinning reserve drop below the pre-determined target.

23 24 **6. Addition of Electronic Notes to Video Wall**

25 The use of electronic notes now takes advantage of the video wall and notes can now be
26 added to any part of the grid, giving operators constant visibility to them. These notes
27 are not shift-dependent and allow operators to leave notes of current system
28 interactions/events visible on the video wall. Previously, notes could be added to a

1 screen and were only visible on that single view of the operator's screen. This reduced
2 the visibility of the notes across the grid for operators when focused on other screen
3 views. The enhanced functionality of electronic notes improves communication and
4 knowledge transfer between operators during shift changes. The type of information
5 contained in a note would include name and contact number of a lead person on site,
6 estimated completion time, etc. This information would be especially useful during an
7 operator shift change if work on site transitions between shifts.

8
9 **7. Creation of a Breakout Room in ECC**

10 A breakout/meeting room was added to the ECC that allows System Operations Staff to
11 meet and discuss ongoing issues without disturbing the on-shift operators. This
12 additional room will allow operators to maintain their focus on management of the
13 power grid.

14
15 **8. Relocation of the Corporate Emergency Operations Center**

16 The Corporate Emergency Operations Center (CEOC) was moved out of the ECC to a new
17 dedicated center. This change reduces the number of individuals that would be present
18 in the ECC during an emergency and reduces the number of person interactions with the
19 operators, which will allow them to focus on power grid management with minimal
20 interruption.

21
22 Moving the CEOC out of the ECC has the added benefit of giving System Operations a
23 dedicated training facility for operators (see Section 5.0).

1 **4.3 Staffing in Advance of Issues**

2 Since 2016, Hydro has adopted the policy of staffing its offices and generation and transmission
3 facilities in advance of certain system conditions to provide additional support and oversight,
4 and improve Hydro's response time to system events.

5
6 The daily systems status meetings references upcoming weather events and provides an
7 opportunity for those managing and monitoring the system to take proactive measures should
8 the circumstances warrant. Depending on the severity of weather events Hydro will:

- 9 • Staff terminal stations in advance of weather impacts,
- 10 • Mobilize transmission crews closer to impacted areas, or areas that may be impacted,
11 and,
- 12 • Mobilize operators and technical support staff to the gas and combustion turbine
13 facilities, based on the potential of running this equipment in the event of issues with
14 transmission or generating equipment as a result of the weather event.

15
16 All of these actions reduce travel time and gives ECC operators on-site support to help
17 troubleshoot issues, ultimately respond faster to incidents, and reduce outage durations.

18
19 As noted in Section 6.0, since the March 4, 2015, events, the Communication Department adds
20 staff to provide coverage during peak periods, typically 6-8am and 5-8pm in the winter months,
21 and during any public power alerts (Power Watch, Power Warning or Power Emergency) to
22 ensure that communications personnel are on-site and have full and immediate access to
23 system operations information and the tools necessary to communicate effectively with the
24 public.

25
26 Each of these preventative measures is costly but Hydro deems them important to the supply
27 of reliable power.

1 **4.4 A Strategy for Customer Service Excellence**

2 Recognizing a desire to improve customer service and the customer experience, Hydro
3 developed a Customer Service Strategy, with the purpose of creating a strategic roadmap for
4 delivering customer service at Hydro. The purpose of the Customer Service Strategy is to
5 outline a strategic roadmap for customer service at Hydro from 2015 - 2017. The report,
6 entitled “*Customer Service Strategic Roadmap 2015 – 2017,*” filed with the Board on September
7 30, 2014, describes a vision for improving service to Hydro’s industrial, utility, and retail
8 customers. The report also identifies the vision, supporting strategies, and guiding principles to
9 meet Hydro’s current business needs and support long-term customer service strategies.

10

11 Hydro continues the execution of its Customer Service Strategy and has seen a number of
12 improvements to software, hardware, and process and procedures. Based on survey feedback
13 from Hydro’s customers, Hydro strategy is working and Hydro looks forward to continuing to
14 improve the service it provides to its customers. In 2017, the strategic plan will be reviewed and
15 refreshed to take Hydro into 2020. New strategies will continue to focus on enhancing the
16 customer experience through continuous improvement and the implementation of new
17 technology to support processes where needed.

18

19 **4.4.1 Development of an Account Management Framework**

20 An essential requirement identified in Hydro’s Account Management Framework was the
21 creation of a dedicated account manager within Hydro’s Customer Service Department to
22 support Hydro’s industrial and identified commercial customers, as well as Hydro’s utility
23 customer Newfoundland Power.

24

25 In 2016, Hydro created a Manager, Key Accounts position. The Manager, Key Accounts act as
26 the single point of contact for its key customers, and focuses on enhancing these individual
27 customer relationships. This allows all interactions to be managed via a single channel and be
28 filtered throughout the Hydro organization in an efficient manner. Once a customer request is

1 received by the Manager, Key Accounts, it is their responsibility to advocate on behalf of the
2 customer within Hydro and pursue a resolution.

3

4 **4.4.2 Implement New Customer-Focused Mobile Application**



Figure 7: MyHydro Application

5 In April 2016, Hydro launched a new mobile and web portal platform called *MyHydro*. *MyHydro*
6 keeps things simple and provides customers with unlimited access to their account anytime,
7 anywhere and on any device. Users can easily and conveniently:

- 8 • View account balance, payment history, and set up payment options online,
- 9 • Subscribe to text and email notifications for planned and unplanned power outages,
- 10 • View and report power outages online,
- 11 • Subscribe to payment reminders via text and email notifications,
- 12 • Sign up for paperless e-billing and equal payment plan,
- 13 • Track and manage electricity usage in easy-to-read charts, set budget goals, compare
14 power usage year over year, or against the average usage of residents in their
15 neighborhood, and
- 16 • Submit service requests.

17

18 **4.4.3 Improve Customer Interaction Through Phone System**

19 Hydro implemented a new Interactive Voice Response (IVR) telephone system to better support
20 its customers. Hydro's new enhanced IVR outage system replaces an older, unsupported
21 system. The new system removes risk as both software and hardware components are vendor

1 supported. The new phone system provides enhanced functionality such as automated billing
2 and outage information. It also links the phone system and our online customer outage
3 notification application.

4

5 **4.4.4 Structured After Hours Support**

6 Hydro established a formal after hours support arrangement with a third party vendor,
7 TeleLink. TeleLink provides power outage handling and reporting service for after business
8 hours customer calls related to outages. TeleLink has been trained and provided with Hydro's
9 process for dealing with outage calls and engages on-call staff when required to follow-up with
10 our customers to resolve an individual and widespread unplanned outage.

11

12 Hydro has seen positive results from this service and has increased the visibility into Hydro's
13 after-hours customer calls though reporting provided by TeleLink. Hydro's customers, as well
14 as Hydro's Energy Control Center, have experienced the benefit of this new process as it
15 removes responsibility from the operators in the Energy Control Center for managing outage
16 calls and allows them to focus on supporting the power system. In addition, it allows Hydro to
17 provide customer focused service 24 hours per day.

18

19 **4.4.5 Implement Transactional Customer Surveys**

20 Hydro has implemented a transactional survey process to receive timely feedback on the
21 service that Hydro's call center staff provides to customers. Transactional surveys are
22 conducted through an automated outbound call service where customers are asked five
23 questions about their most recent experience with Hydro staff in relation to the reason of their
24 call. The survey focuses on the quality of service received, staff's knowledge, and measuring
25 first contact satisfaction.

1 **5.0 Improving the Corporate Emergency Response Plan**

2 Liberty has recommended that “Hydro should implement a more robust approach to the
3 CERP.”²⁸

4
5 Hydro has taken ownership of its own Corporate Emergency Response Plan(CERP) and fully
6 staffs its Corporate Emergency Operations Center Response Team with Hydro Executive and
7 Management personnel. Hydro’s Corporate Emergency Response Plan provides clear and
8 concise guidelines for actions to be taken by Hydro’s Management Team during emergency
9 situations. Its purpose is to ensure an effective corporate response to all emergency situations
10 and provide guidance on all necessary emergency support actions required to reduce the
11 probability of emergency events escalating in severity.

12
13 As part of its corporate management review process, Hydro reviews CERP on an annual basis.
14 Since March 2015, improvements and necessary changes have been identified and are being
15 implemented in a phased approach. These changes improve Hydro’s response to emergency
16 situations and reflect the ongoing organizational changes taking place as Hydro prepares for
17 integration into the North American grid, and include:

- 18
- 19 1. CERP has been updated to provide dedicated resources and focus for events related to
20 Hydro operations. CERP now includes a dedicated Hydro Executive on Call (EOC) and
21 Hydro Corporate Emergency Operations Center (CEOC) Response Team. These
22 individuals have autonomy for making decisions related to events impacting Hydro and
23 would have direct knowledge of Hydro Operations resulting in quicker focused
24 responses for Hydro events.

²⁸ The Liberty Consulting Group, “Review of the Newfoundland and Labrador Hydro March 4, 2015 Voltage Collapse,” October 22, 2015, at page 10.

1 2. The on-call and delegation of authority process has been streamlined. The Executive on
2 Call now assumes the roles of Incident Commander, determines the level of response
3 required by CERP, and assumes responsibility for managing the emergency response.
4 Prior to this amendment, there was a dedicated Incident Commander and Deputy
5 Incident Commander and EOC would notify the Incident Commander (or Deputy
6 Incident Commander). The new process allows for quicker decision-making and
7 response times.

8
9 3. The Corporate Emergency Operations Center has been moved to its own dedicated
10 location, outside of the Energy Control Center. Previously, the CEOC was a shared
11 location within the ECC's training facility.

12
13 4. CERP has improved the clarity of the notification and mobilization protocol. Hydro's
14 Advance Notification Protocol Levels have been incorporated into the CERP Alert and
15 Emergency Criteria. The EOC will be alerted when the EEC has moved into a Power
16 Warning and will mobilize (either fully or partially) when the ECC has moved into a
17 Power Emergency.

18
19 CERP has also added definitions for minor and major outages to its notification
20 protocols. These definitions are used by the EOC as part of criteria for determining
21 whether mobilization of CERP, either full or partial mobilization.

22
23 5. CERP has updated its process for notifying and mobilizing the CERP Team. The CERP
24 team is now notified by a third party call center vendor. The pager-system has been
25 replaced with a third party vendor that is contracted to make contact with members of
26 CERP. Prior to this improvement, the CERP members were contacted via pager and
27 there was no assurity that the individual received the page. CERP members are now
28 notified via text and required to respond. If no response is received within five minutes,

1 then the third party vendor will follow-up by phone call, ensuring the CERP members
2 receive notification of the emergency.

3 4 **6.0 Improvements to External Communications Processes**

5 Following the supply disruptions in January 2014, several robust protocols and processes were
6 developed to ensure clear and timely external communications with customers and key
7 stakeholders. Liberty recommended the development of a Joint Storm/Outage Communication
8 Plan with Newfoundland Power as well as the development of Advance Notification Protocols
9 that appropriately identify potential impact in terms of the loss of power to customers.

10
11 Newfoundland and Labrador Hydro, along with Newfoundland Power, have developed a joint
12 storm/outage communication plan that clearly outlines the roles and responsibilities of each
13 utility along with expected timelines for communications, as well as tactics, messaging and
14 approval processes. In addition, the utilities developed three levels of alerts to advise
15 customers of the status of the power supply in the province.²⁹ The goal of the Advance
16 Notification Protocol is to provide early information to customers when there is potential for a
17 supply shortage, to advise on specific actions required of customers and to better prepare
18 customers for any potential impacts.

19
20 Communications tools (including videos and infographics) were developed, along with clear
21 messaging for each alert level, to ensure that time is not wasted during the activation of an
22 alert aligning on appropriate messaging. In addition, during a power alert, Hydro's website is
23 activated with a screen pop-up with clear information for customers who visit the site. Figure
24 7 displays the infographic developed to explain the Advance Notification Protocol.

²⁹ <https://www.nlhydro.com/winter/advance-notification-protocol/>




Figure 8: Advanced Notification Protocols – Levels of Notification

1 The original Advance Notification Protocol was developed after the supply issues experienced in
 2 January 2014 to communicate important information to customers, in advance, based on
 3 forecast generation shortages and Hydro’s ability to supply customers on the Island
 4 Interconnected System.

5
 6 Because the events in March 2015 were specific to the Avalon Peninsula, the Island Advance
 7 Notification Protocol was not triggered. In retrospect, power customers on Avalon Peninsula
 8 should have been notified in advance of the March 4 event. As referenced in section 2.3, Hydro
 9 is now focused on the end-consumer of power, rather than being focused on the end-point of
 10 its power delivery. This change in philosophy has led to several important enhancements. The
 11 Advance Notification Protocol and system operating procedures were expanded in April 2015 to
 12 ensure reserves are analyzed daily, from both an Island (IIS) and Avalon Peninsula perspective,
 13 to trigger any supply shortages (reference system operating instructions “Avalon Capability and
 14 Reserves (T-096)” in Section 2.3.4).

15
 16 The Advance Notification Protocol public communication alerts (Power Watch, Power Warning
 17 and Power Emergency) are now able to be executed for either the Island or the Avalon
 18 Peninsula, allowing for advance communication and messaging to the appropriate customers.

1 As an improvement to its operational philosophy and improved communication protocols,
2 Hydro communicates any equipment failure or system vulnerability significant in nature to its
3 stakeholders. After the March 4 (2015) event, an additional communication process was
4 developed to help better inform customers when major pieces of equipment are offline. The
5 Equipment Advisory Process outlines the communications activities that will take place when
6 major generation equipment³⁰ or major transmission equipment³¹ is offline and unavailable to
7 the system. Public equipment advisories are posted on Hydro's website –
8 www.nlhydro.com/projects under the maintenance and repairs section.

9

10 Hydro has recognized the importance of educating customers and stakeholders on their
11 provincial electricity system and is working hard to keep customers better informed about the
12 inner workings of the provincial electricity grid. To that end, since 2014 the Hydro
13 Communications Team has been working to develop relevant and easily understood
14 information for customers to help them understand the overall system as well as outage and
15 event-specific information. For example, videos, infographics and web content have been
16 developed on the following topics;

- 17 • how to conserve energy
- 18 • power outage safety
- 19 • the Advance Notification Protocol
- 20 • how the system works
- 21 • restoring power after a distribution outage
- 22 • restoring power after a generation outage
- 23 • communications during outages
- 24 • under frequency load shedding
- 25 • how outages are planned
- 26 • power line safety

³⁰ Limited to generating units greater than 80MW and stand-by units

³¹ 138 kV or 230 kV transmission lines

- 1 • cold load pickup

2 All of this customer education material can be found on Hydro’s website –www.nlhydro.com
3 and is regularly shared on Hydro’s social media channels throughout the year and during
4 specific events and/or outages.

5
6 Finally, an additional change made to communications processes after the March 4, 2015, event
7 includes staffing of peak periods (typically 6-8am and 5-8pm in winter months) during any
8 public power alerts (Power Watch, Power Warning or Power Emergency). This allows
9 communications personnel to be on-site and have full and immediate access to system
10 operations information and the tools necessary to communicate effectively with the public.

11

12 **7.0 Future Improvements**

13 In addition to the enhancements that have been detailed in this report, Hydro continues to
14 seek improvements in support of its goal of delivering safe, reliable and least cost supply
15 electricity to the consumer. The following items will help improve Hydro’s operational
16 reliability and will prepare Hydro for the integration of the Maritime Link, the Labrador Island
17 Link, and the Muskrat Falls assets into the provincial electricity system.

18

19 **7.1 Improving Equipment Reliability and Preventative Maintenance Programs** 20 **Based on Lessons Learned**

21 Changing the operational philosophy of Hydro involves creating a learning environment where
22 continuous improvement is achieved by learning from the past projects and experiences.
23 Hydro is taking an approach to learn from known operational issues and react conservatively,
24 meaning to put plans in place to reduce risk as much as is practicable. This may involve
25 additional operational maintenance, operational monitoring, or capital investment. For
26 example:

- 1 1. Hydro has experienced penstock failures and generating unit seal issues at the Bay
2 d’Espoir hydro generation facility. In review of these items, Hydro felt it important to
3 look at the Preventative Maintenance (PM) program and ensure we are identifying
4 these types of issues earlier. To identify issues, the PM program needs to be reviewed
5 to ensure it is appropriate. Therefore, in 2016, Hydro contracted an external consultant
6 to review its PM programs related to surge tanks, penstocks and generating station
7 transformers. In an effort to continually improve its programs and long-term reliability,
8 Hydro has asked the consultant to identify if there are gaps in the maintenance
9 programs for these assets. Hydro will update its PM programs based on the findings of
10 the consultant. Hydro will review the outcomes of the engagement with the outside
11 consultant and ascertain if the external review approach provides the improvement
12 sought for the asset management program.
13
- 14 2. As referenced in section 7.3, Hydro is also increasing its focus on its gas turbine units
15 with the goal of improving their reliability. Hydro has engaged another external
16 consultant to review all aspects of gas turbine operation and control and provide Hydro
17 with recommendations which will further improve the reliability of these units going
18 forward. This is being reported to the Board through a separate process.
19
- 20 3. Hydro also recognizes the importance of reliability at the Holyrood Thermal Generating
21 Station until decommissioning and has refocused its maintenance efforts here.
22 Condition assessments and inspections, along with operational experience, will dictate
23 when Hydro requests to move ahead with investments to address reliability risks, such
24 as the exciter controls replacement at Holyrood in the supplemental application filed
25 with the Board February 28, 2017. This is a known reliability risk and Hydro’s
26 perspective is to remove as many such risks as is reasonable. The approach to address
27 the risks is conservative as we are not waiting until the risk becomes so significant that it
28 becomes an impact on the ability to serve customers.

1 Hydro recognizes the need to proactively improve its condition assessments, asset
2 management programs, and ultimately, its system reliability, and will continue engage
3 consultants for external review of its preventative maintenance programs for other corporate
4 assets.

5

6 **7.2 Creation of Newfoundland Labrador System Operator**

7 The creation of the Newfoundland Labrador System Operator (NLSO) is an important step in the
8 integration of the Muskrat Falls assets into the provincial electricity system, and the island's
9 interconnection with the North American electricity market.

10

11 Industry recognized standards, such as those developed by the Federal Energy Regulatory
12 Commission (FERC), require that electricity entities maintain a clear functional separation
13 between the system operator and any other functions of that entity that are concerned with
14 power production and/or marketing.³² The purpose of this requirement is to ensure that there
15 is no collaboration or exchange of information between affiliated business units which could
16 impair non-discriminatory, open system access within the wider electricity market.

17

18 The NLSO will continue to exist within Hydro but will also be the system operator for the
19 transmission and distribution system in Newfoundland and Labrador. The NLSO will represent
20 all interests on the transmission and distribution network and will be governed by a set of rules
21 and regulations that ensures fair and equitable treatment of all entities seeking access to the
22 network.

23

24 The NLSO will be created by making structural and resourcing changes needed to enable the
25 System Operations Division to function as the NLSO. Although the NLSO will reside inside

³² The Federal Energy Regulatory Commission (FERC) is an independent agency, based in Washington, D.C., which regulates the inter-state transmission of electricity, natural gas, and oil. In the United States, and in neighboring Canadian jurisdictions, wholesale sales of electricity are typically governed by FERC's Open Access Transmission Tariff which sets out standards and other requirements governing market access and system reciprocity.

1 Hydro, it will act as the independent system operator³³ (ISO) for the province. It will operate
2 the facilities owned by Hydro and Nalcor Power Supply along with interconnections with
3 Emera's Maritime Link assets on the island.

4
5 Hydro is in the process of identifying the structural, process, and other changes required to be
6 compliant with applicable open access obligations, including those pertaining to tariff
7 transparency, system access, and reciprocity with jurisdictions where Nalcor takes transmission
8 service. Section 3.2 outlines substantial organization changes that have already been made to
9 improve the efficiency and focus of System Operations and to prepare for the creation of the
10 NLSO. In addition to these changes, Hydro is in the process of making the following changes to
11 support the creation of the NLSO:

12 1. From an operational readiness standpoint, Hydro is adding and training five System
13 Operators to support the integration of the ML and the LIL with the IIS. This is required
14 in order to address the new work scope assumed by the NLSO as the province's
15 independent system operator to meet the requirements related to the standards of
16 interchange scheduling and interconnection system reliability. Hydro's Energy Control
17 Centre will continue to be staffed on a 24/7 basis. It will also transition to a
18 complement of three Energy Control Center staff per shift, versus the current
19 complement of two.

20
21 2. To meet the requirements related to the standards of interchange scheduling and
22 interconnection system reliability, Hydro will hire:

23 a) **Reliability Coordinator** – This individual has the highest level of authority and has
24 responsibility for the grid. Reliability Coordinators have the authority, plans, and
25 agreements in place to immediately direct reliability entities within their jurisdiction

³³ An independent system operator (ISO) is an organization that is formed at the recommendation of the Federal Energy Regulatory Commission (FERC). It coordinates, controls, and monitors the operation of the electrical power system.

1 to re-dispatch generation, reconfigure transmission, or reduce load to mitigate
2 critical conditions to return the system to a reliable state.

3 b) **Transmission Operator** – This individual ensures the real time operating reliability of
4 the transmission assets and manages the power system in real time and coordinates
5 the supply of and demand for electricity in a manner that avoids fluctuations in
6 frequency or interruptions of supply.

7 c) **Balancing Authority** – This individual maintains load-resource balance through the
8 collection of generation, transmission, and load data within its metered boundaries.
9

10 **7.3 Improved Standards for Measuring Gas Turbine Performance**

11 Hydro currently uses industry standard metric Utilization Forced Outage Probability (UFOP) for
12 measuring its gas turbines performance.³⁴
13

14 While UFOP is an industry standard, as Hydro has been reviewing system reliability, Hydro
15 determined this metric does not capture all of the necessary aspects of gas turbine asset
16 reliability. In the “*Gas Turbine Failure Analysis Final Report*”³⁵ submitted to the Board on
17 January 11, 2017, Hydro recognized and stated that an additional metric that measures the
18 availability of its gas turbine assets is required. Material steps have been taken to identify this
19 measure and the final selection is nearing completion. This new measure will be discussed in
20 the May 2017 Energy Supply Risk Assessment update.
21

22 In the January 11, 2017 report, and discussed in section 7.1, Hydro also stated that it is
23 increasing its focus on the gas turbine units with the goal of improving their reliability. To this
24 end, Hydro has engaged external consultant Performance Improvements Ltd. (PI) to review all

³⁴ UFOP is defined as the probability that a generation unit will not be available when required. It is used to measure performance of standby units with low operating time such as gas turbines.

³⁵ Available at: <http://www.pub.nf.ca/applications/IslandInterconnectedSystem/phasetwo/files/reports/From%20NLH%20-%20Hardwoods%20and%20Stephenville%20Gas%20Turbine%20Failure%20Analysis%20-%20Final%20Report%20-%202017-01-11.PDF>

1 aspects of gas turbine operation and control and to provide recommendations which will
2 further improve the reliability of these units going forward.

3

4 **7.4 Review and Adoption of NERC Reliability Standards**

5 The North American Electric Reliability Corporation (NERC) is a not-for-profit international
6 regulatory authority with a mission is to assure the reliability and security of the bulk power
7 systems in North America. NERC Reliability Standards define the reliability requirements for
8 planning and operating the North American bulk power system and are developed using a
9 results-based approach³⁶ that focuses on performance, risk management, and entity
10 capabilities.³⁷

11

12 Hydro recognizes the benefits that the NERC reliability standards provide and is in the
13 preliminary stages of reviewing and assessing these standards for adoption into the Island
14 Interconnected System. Hydro is also reviewing the impacts that the NERC reliability standard
15 will have on Hydro's reliability and the approach it would use to implement applicable NERC
16 reliability standards.

17

18 **7.5 Service Level Agreements**

19 Service level agreements (SLA) are contracts between a service provider and end-user that
20 define the level of service that is expected from the service provider. The purpose of the SLA is
21 to define what the customer will receive.

22

23 Hydro currently has SLAs in place with many of its suppliers to ensure that Hydro can get timely
24 support and service when issues arise. Through the issues experienced in the past several

³⁶ Results based standards are standards that focus on required actions or results (the "what") and not necessarily the methods by which to accomplish those actions or results (the "how").

³⁷ <http://www.nerc.com/pa/Stand/Pages/Default.aspx>

1 years, Hydro believes that its SLAs need to be reviewed and a high level of support is required
2 from some of its suppliers to ensure a more timely and substantial response.

3
4 One improvement in this area includes Hydro’s recent long-term maintenance contract with
5 Siemens for the Holyrood combustion turbine (CT). The Holyrood CT is an important
6 component of the Avalon contingency reserves and securing a long-term service provider will
7 improve access to parts inventories, improve service response times and contribute to the
8 overall reliability of the grid.

9
10 Hydro will continue to review its SLAs with a view to renegotiating those for critical assets that
11 are viewed as having insufficient SLAs.

12

13 **7.6 Requirement for Additional Generation**

14 In its report titled *“Review of Newfoundland and Labrador Hydro Power Supply Adequacy and*
15 *Reliability Prior to and Post Muskrat Falls”*,³⁸ Liberty recommended that “Hydro should
16 expedite efforts to determine (a) the availability of dependable reserves from Nova Scotia or
17 elsewhere and (b) the competitiveness of those reserves versus new Island Interconnected
18 System generation.”³⁹

19

20 In order for Hydro to do a complete evaluation of the competitiveness of new sources of Island
21 Interconnected System generation, Hydro requires an accurate estimate of each reasonable
22 generation alternatives. One proposed Island Interconnected System generation alternative is
23 the construction of a new hydroelectric generation turbine unit at the Bay d’Espoir Power Plant.

24

25 The new hydroelectric generation turbine (unit 8) would be identical to unit 7 and would add
26 154.4 MW of capacity to the Island Interconnected System. It could also be started quickly and

³⁸ <http://www.pub.nf.ca/applications/IslandInterconnectedSystem/phasetwo/files/reports/TheLibertyConsultingGroup-PhaseTwoReport-2016-08-19.pdf>

³⁹ Recommendation V-1

1 could be put on-line when coming into high load periods or kept on-line for extended periods.
2 Given improvements in technology, a new turbine could also be more efficient than the existing
3 turbines at Bay D’Espoir. Bay D’Espoir unit 8 is one candidate for the least-cost source of
4 additional capacity.

5
6 Hydro is currently completing more detailed feasibility studies and cost estimated for this
7 alternative. The results of this analysis will be used as input to the evaluation of the
8 competitiveness of new sources of Island Interconnected System generation. The construction
9 schedule for a new unit is estimated to be approximately 3.5 years, so Hydro is taking action to
10 attain the required information for its review.

11

12 **8.0 Conclusion**

13 Hydro remains committed to the provision of safe, reliable and least cost supply of electricity to
14 its customers. This report outlines the many changes that Hydro has taken since 2014 to
15 improve its operational philosophy and reliability culture. Hydro understands that changing an
16 organization’s culture takes time and it is a large-scale undertaking that requires the
17 organization to first change its behaviours. The current leadership and employees throughout
18 the company are fully committed to delivering stronger service to Hydro’s customers and
19 delivering on the company’s mandate.

Appendix A
Glossary of Terms

Glossary of Terms


ANP - Advanced Notification Protocols
AWP - Annual Work Plan
CEOC - Corporate Emergency Operations Center
CERP - Corporate Emergency Response Plan
ECC - Energy Control Center
EMS - Energy Management System
EOC - Executive on Call
ESRA – Energy Supply Risk Assessment
EUE - Expected Unserved Energy
HTGS – Holyrood Thermal Generating Station
IAWP - Integrated Annual Work Plan
IIS – Island Interconnected System
kV - Kilovolt
LIL - Labrador Island Link
ML - Maritime Link
MW – Megawatts
NERC - North American Electric Reliability Corporation
NLSO - Newfoundland Labrador System Operator
OTS - Operator Training Simulator
UFOP - Utilization Forced Outage Probability

Appendix B
Daily System Status Meeting Notes

Daily System Status Meeting - Notes			
	Topic	Lead	Notes
1	Safety Moment and Key Messages		http://www.nlhydro.com/winter/power-outage-safety Move towards our gaps as immediate opportunities to improve our performance and resiliency Open and honest discussion on risks and how we mitigate them Visible leadership supporting awareness and demonstrating a heightened sense of urgency
2	System Risk/Watch		<p>HRD Unit #2 to come offline for cell replacement on VFD B Phase.</p> <p>Water Management Thermal generation to follow the guidelines below based on current outlook of low reservoir storage, low snowpack, and low inflows. When 2 units are available at Holyrood, the total Holyrood + Standby output shall be 400 MW. When 3 units are available at Holyrood, the total Holyrood + Standby output shall be 460 MW.</p> <p><u>Note:</u> 3 units considered available when Unit 2 is available at 70 MW.</p> <p>Hydrology position as of Thursday, February 4: Total system energy storage is at 48% and all reservoirs are continuing to decline Exploits Generation is currently at 55% of normal, Red Indian Lake is 45% full and continuing to decline</p>

			<p>Fall/winter Inflows fourth lowest in 65 years Inflows year to date at 26% average Snowpack is at 30 - 50% of typical end of winter maximums Thermal generation has been increased for water management Holyrood generation is at maximum Standby generation increased for reliability and energy Holyrood plus standby generation averaged 431 MW over last 7 days</p> <p>The Avalon peak for today is 655 MW in the evening. Based on this forecast and maintaining current wind generation (2 MW) the Avalon reserves for this evening would be 265 MW with no alert.</p> <p>Western Avalon T5: Please see notes below in section 6b.</p>
3	Previous Day's Events	System On-Call / Sys Ops	<p>VBN T1 was taken out of service at 1732 hour due to due to burnt CT block. CBC C1 was taken out of service as the 487 relay is showing failed.</p>
4	Labrador Operations	System Operations	<p>Unit G7 HVY will be returned to service today at approximately 6pm.</p> <p>The unit in Postville (573) is unavailable for operation due to white smoke coming from the stack yesterday afternoon. The unit was shut down immediately and tagged out. They are currently arranging for a crew to get into Postville today from Nain where there is currently a Mechanical crew. Update Feb 03: The unit in Postville will require a partial</p>

			<p>dismantle to assess the issue. They are suspecting a broken liner so want to ensure they have enough time to assess the problem this week and order the repair parts by before weeks end. If damage is not too significant the unit should be up and running sometime next week depending on delivery of parts.</p>
5	<p>Weather Outlook and Notifications</p>	<p>Sys Ops/ Corp Relations</p>	<p>Wind warning in effect for: Avalon Peninsula North Avalon Peninsula Southeast Avalon Peninsula Southwest Boniest Peninsula Bay of Exploits Clareville and vicinity St. John's and vicinity Terra Nova</p> <p>Strong winds that may cause damage are expected or occurring. A low pressure system is forecast to track through central Newfoundland early on Saturday. Northwestern winds gusting up to 110 km/h are expected along parts of the coast on Saturday behind this system.</p> <p>Rainfall warning in effect for: Avalon Peninsula Southeast Burgeo-Ramea Burin Peninsula</p> <p>Rain, heavy at times is expected. A low pressure system is expected to approach from the southwest</p>

 <p>Environment Canada / Environnement Canada</p>	<p>today and will cross central Newfoundland early on Saturday. Rain ahead of this system will begin near noon today and will persist into Saturday morning. Total rainfall accumulations of 25 to 35 millimetres are expected before the rain tapers off by noon on Saturday.</p> <p>Winter storm warning in effect for: Corner Brook and vicinity Deer Lake -Humber Valley Green Bay-White Bay Gros Morne Northern Peninsula East Parson's Pond-Hawke's Bay Port Saunders and the Straits</p> <p>Hazardous winter conditions are expected. A low pressure system is forecast to track across central Newfoundland early on Saturday. Snow ahead of this system will spread northward across western Newfoundland this afternoon into this evening becoming heavy at times tonight. Total snowfall accumulations of up to 35 centimetres are expected before the snow tapers off on Saturday. In addition, strong northerly winds are expected to develop early Saturday morning. These winds will combine with the freshly fallen snow to give reduced visibilities in blowing snow. Conditions are expected to improve Saturday afternoon.</p> <p>Special weather statement in effect for: Gander and vicinity</p>
--	---

			A low pressure system is forecast to track through central Newfoundland early on Saturday. This system will bring warm temperatures and rain to northeastern Newfoundland tonight into Saturday morning. Total rainfall amounts are expected to be near 20 mm before the rain tapers off on Saturday.
6a	Equipment Outages and Notifications - <u>Planned</u>	Sys Ops/ Corp Relations	Outage is required to remove two of the mobile diesels from HRD. HRD to review and send in a detailed plan to system operations. This work will wait until HRD Unit #2 is back online.
6b	Equipment Outages and Notifications - <u>Ongoing</u>	Sys Ops/ Corp Relations	BDE Unit #2: It has been requested by P&C engineering that this unit not be shut down due to a start/stop relay. TL 227 remains out of service from BHL to SCV due to a landslide in the area. Section of line was taken out to be proactive and prevent possible outages and equipment damage. No customers were lost. Area assessment, extent of damage and recovery plan will be further developed when weather conditions permit and it is safe to access area. Corporate communications have been talking to parks Canada. Update Feb 05: Stantec has completed the geotechnical assessment for Parks Canada and will provide the assessment today. This will confirm the safe distance for the relocation. A detailed work plan and resources are being developed. The work will be coordinated with system operations to minimize impact to customers. Engineering design is ongoing, with surveying crews in the field, materials acquisition. All activities are being coordinated

			<p>with Parks Canada.</p> <p>Western Avalon T5 still out of service. Work will be rescheduled next week based on the performance of HRD Unit#1.</p>
7	Island Capability / Reserves and Notifications	Sys Ops/ Corp Relations	<p>Island reserves are adequate at 515- 705 MW for the next 7 days.</p> <p>Continue to watch for Frazil ice at GCL, USL and HLK. Exploits are generating at 39 MW. Exploits generation will be adjusting output to 40 MW through discussions with System Operations. Also watching situation at Badger</p> <p>Wesleyville GT is out of service. There is a bearing issue and it has to be replaced. It will be out for about 6 weeks</p> <p>NP reported 70 MW of total hydraulic capability.</p>
8	Avalon Capability / Reserves and Notifications	Sys Ops/ Corp Relations	<p>Avalon reserves are at 235- 350 MW for the next 7 days.</p> <p>Three HRD units are available and unit# 2 will go offline tonight.</p> <p>HWD GT and HRD CT are available</p> <p>NP reported 41 MW of Avalon hydraulic capabilities.</p>
9	Standby Unit Staffing / Operation Requirements	System Operations	<p>This outlook reflects:</p> <p>Three HRD units are available and unit #2 will go offline tonight.</p> <p>HWD GT and HRD CT are available</p> <p>All Avalon transmission lines are in service.</p>
10	Communications - Stakeholders and Public	Corporate Relations	
11	Other		

Appendix C
Severe Weather Checklist

Severe Weather Preparedness Checklist

Date:	Location:
Current and Forecasted Weather:	
Things to think about before preparing	
<input type="checkbox"/> Do workers know and understand the tasks? <input type="checkbox"/> Have all workers been given orientations? (Is there an orientation or training for working in severe weather?) <input type="checkbox"/> Ensure Tailboards are completed prior to start of work <input type="checkbox"/> Communicate forecasted weather conditions to all employees. Keep employees updated on changing conditions <input type="checkbox"/> Are all proper tools available for job? <input type="checkbox"/> Ensure employees have Proper PPE for working in extreme weather conditions <input type="checkbox"/> Will employees be working alone? If yes, circulate the working alone procedure for review. <input type="checkbox"/> Have environmental aspects been considered?	
Emergency Information	
Emergency response plan(s) in place? <input type="checkbox"/> Yes	
Has it been communicated to all required personnel? <input type="checkbox"/> Yes	
Nearest medical facility:	
Emergency Contact Numbers	
1.	3.
2.	4.
Severe Weather Preparedness	
Safety	Trucks
<input type="checkbox"/> Consider holding safety briefings with available staff <input type="checkbox"/> Ensure workers are familiar with the safety tools and procedures associated with severe weather <ul style="list-style-type: none"> <input type="checkbox"/> Tailboard <input type="checkbox"/> Step Back 5x5 <input type="checkbox"/> Proper PPE for Weather conditions 	<input type="checkbox"/> Fuel all vehicles <input type="checkbox"/> Ensure Distribution line trucks are stocked with critical spare parts and consumables <input type="checkbox"/> Equip trucks with special tools and equipment as required <input type="checkbox"/> Ensure distribution line workers and distribution front line supervisors have company vehicles at home <input type="checkbox"/> Provide on call supervisors with a company vehicle <input type="checkbox"/> Consider having other staff take company vehicles home <input type="checkbox"/> Ensure truck radios are working
Tools and Equipment	Buildings
<input type="checkbox"/> Test portable generators, standby diesels and gas turbines <input type="checkbox"/> Test tools as required <input type="checkbox"/> Ensure fuel supply available	<input type="checkbox"/> Schedule additional snow removal <input type="checkbox"/> Consider renting portable generators for buildings not equipped with a backup <input type="checkbox"/> Check ability to alter temperature controls in buildings to override normal after-hour temperature settings
Substation and Generation	Stores – Not sure this applies to us (or maybe diff name)
<input type="checkbox"/> Consider location and availability of portable generation and portable substations. Re-deploy as required <input type="checkbox"/> Ensure fuel Supply for system generators	<input type="checkbox"/> Ensure all stores have proper staffing levels <input type="checkbox"/> Check stock levels for items likely needed during storms <input type="checkbox"/> Consider confirming the supply of poles on the island

<p>Operations Staff</p> <ul style="list-style-type: none"> <input type="checkbox"/> Notify Staff of forecasted storm. Consider scheduling staff to work outside of normal working hours to ensure quick response <input type="checkbox"/> Equip Supervisors with up to date staff listings and contact information <input type="checkbox"/> Consider re-deploying staff to areas most likely impacted by the severe weather <input type="checkbox"/> Put technical staff on notice of pending storm <input type="checkbox"/> Ensure support and costumer service staffs are aware if the forcasted weather <input type="checkbox"/> Consider enhancing staff levels at ECC and other control rooms <input type="checkbox"/> Ensure IS support team is in place <input type="checkbox"/> Ensure Protection and Control Engineering are aware of the pending weather and that contact information is available 	<p>Transportation</p> <ul style="list-style-type: none"> <input type="checkbox"/> Where possible, put a rush on maintenance or repair work for any company vehicle <input type="checkbox"/> Complete inspections of additional equipment and vehicles (four wheel drive trucks, snowmobiles, ATVs and specialized vehicles) <input type="checkbox"/> Notify garages and mechanics of forecasted storm <input type="checkbox"/> Confirm after hour contacts with government departments in the event that permits are required to re-locate portable equipment, or obtain permits in advance <input type="checkbox"/> Confirm the availability of tractors or other equipment to relocate portable equipment <input type="checkbox"/> Arrange for any necessary escorts
<p>Communications</p> <ul style="list-style-type: none"> <input type="checkbox"/> Hold a pre-event coordination call to coordinate response activities <input type="checkbox"/> Consider additional communication with on-call personnel to ensure rediness to respond <input type="checkbox"/> Contact NF Power for generation Status <input type="checkbox"/> Check availability of Satellite Phones, ensure they are charges and working <input type="checkbox"/> Ensure appropriate staff have cell phones. Ensure adequate cell phone chargers and spare batteries are available <input type="checkbox"/> Charge and test portable radios <input type="checkbox"/> Test area office base station radios 	<p>System Security</p> <ul style="list-style-type: none"> <input type="checkbox"/> Make extra effort to correct any adnormal system conditions <input type="checkbox"/> Where practical consider suspending construction on capital jobs to return the system to normal <input type="checkbox"/> Consider developing a contingency plan for any abnormal conditions that cannot be corrected <input type="checkbox"/> Consider protection changes above normal settings
<p>Contractors</p> <ul style="list-style-type: none"> <input type="checkbox"/> Put contractors on notice of pending storm and ask that they prepare <input type="checkbox"/> Confirm Contractor's emergency contact information <input type="checkbox"/> Confirm their available resources and their ability to assist <input type="checkbox"/> Ensure Snow clearing contractors are on alert and available 	<p>Customer Service and Communications Hub</p> <ul style="list-style-type: none"> <input type="checkbox"/> Confirm area connections to the communications hub. Ensure an area person is assigned to communicate with the hub <input type="checkbox"/> Consider assigning a communications hub member to the ECC <input type="checkbox"/> Communicate with Customer Service to determine their requirement for remote <input type="checkbox"/> Check the availability of local Costumer Service Staff
<p>Accommodations</p> <ul style="list-style-type: none"> <input type="checkbox"/> Contact local hotels to determine availability of rooms in the event that crews are moved into the area. Consider reserving a block of rooms. 	<p>Finance</p> <ul style="list-style-type: none"> <input type="checkbox"/> Arrange for numbers to be used for charging the storm. Communicate to staff
<p>Government</p> <ul style="list-style-type: none"> <input type="checkbox"/> Prior to the storm, confirm contacts for emergency snow clearing with the Department of Transportation <input type="checkbox"/> Ensure updates contact lists are available for surrounding municipalities <input type="checkbox"/> Prior to the storm, confirm ferry schedules and contact information 	<p>Other Utilities</p> <ul style="list-style-type: none"> <input type="checkbox"/> Coordinate response with Newfoundland Power

Appendix D
Avalon Capability and Reserves (T-096)

SYSTEM OPERATING INSTRUCTION

STATION: GENERAL	Inst. No. T-096
TITLE: AVALON CAPABILITY AND RESERVES **	Page 1 of 5

INTRODUCTION

In order to ensure that customer service is maintained, the Energy Control Centre (ECC) shall exercise its authority to reduce risks to the Avalon capability and maintain sufficient Avalon reserves to meet current and anticipated customer demands. The ECC shall be prepared to deal with reserve deficiencies and take appropriate actions in order to maintain the reliability of the Avalon system.

Avalon reserve is required to replace generation or transmission capacity lost due to equipment forced outage, to cover performance uncertainties in generating units or to cover unanticipated increases in demand. Sufficient reserve is required to meet current and forecasted demands under a worst case contingency.

PROCEDURE

A. Calculation of *Total Avalon Capability and Available Avalon Reserve*

Total Avalon Capability is determined using load flow analysis¹ and is based on the availability of equipment on the Avalon for each day. This would include the following:

1. Generation on the Avalon (Holyrood thermal units, Hardwoods GT, Holyrood CT, Holyrood Diesels, Newfoundland Power hydro, Newfoundland Power standby, Fermeuse Wind² and Vale Capacity Assistance³)
2. Transmission Availability (230 kV transmission lines on the Avalon, 138 kV transmission lines from Stony Brook – Sunnyside and Western Avalon - Holyrood)
3. Reactive resources (capacitor banks in Oxen Pond, Hardwoods and Come By Chance)

Available Avalon Reserve shall be calculated for the current day and the following six days in the manner as indicated below:

$$\begin{aligned} \text{Available Avalon Reserve for each day} = \\ \text{Total Avalon Capability ; less} \\ \text{Forecasted Avalon Peak Load (adjusted for Voltage Reduction}^4 \text{ when applicable)} \end{aligned}$$

¹ Base case load flows will be used to determine the Avalon Capability.

² Included for the current day based on actual wind output, but assumes no wind generation for the following six days.

³ *Capacity Assistance* (when available) from Vale through operation of standby diesel units with a combined capacity of up to 15.8 MW.

⁴ Up to 10 MW of Avalon load reduction (on peak) is expected to be achieved through the *Voltage Reduction* strategy. This is approximated as one-half the total Island reduction.

SYSTEM OPERATING INSTRUCTION

STATION: GENERAL	Inst. No. T-096
TITLE: AVALON CAPABILITY AND RESERVES **	Page 2 of 5

PROCEDURE (cont'd.)

B. Assessment and Notification of Available Avalon Reserve

The available Avalon reserve will be calculated for the current day and the following six days and an assessment will be made against the criteria in the table below and a notification will be issued to stakeholders when available Avalon reserve is below the stated thresholds.

<u>Available Avalon Reserve</u>	<u>Expected Action</u>	<u>Level</u>
> Impact of largest contingency + min reserve ⁵	none	0
< Impact of largest contingency + min reserve	Prepare for potential Load Reduction	1
< Impact of largest contingency	Load Reduction	2
< Impact of ½ largest contingency	Conservation	3
Zero/deficit	Rotating Outages	4

Based on the assessment above, perform the following:

- Level 0 - If the available Avalon reserve is anticipated to be greater than the impact of the largest contingency plus min reserve, the ECC are not expected to perform any further actions, other than to advise the on-call Executive member (Exec On-call) of NLH's Corporate Emergency Response Plan (CERP), Corporate Relations and Newfoundland Power's Control Centre that the available Avalon reserve has returned to normal following a prior Level 1, 2, 3 or 4 notice.
- Level 1 - If the available Avalon reserve is anticipated to be less than the impact of the largest contingency plus min reserve, the ECC will notify Newfoundland Power's Control Centre, advising of possible requirements for load reduction to maintain sufficient Avalon reserve, if the available Avalon reserve should decrease.
- Level 2- If the available Avalon reserve is anticipated to be less than the impact of the largest contingency, the ECC will notify Exec On-call (CERP)⁶ Corporate Relations⁷ and Newfoundland Power's Control Centre⁸, advising of load reduction strategies to maintain sufficient Avalon reserve, if the capability shortfall is not corrected.

⁵ Min reserve is 35 MW.

⁶ As part of the CERP, the Exec On-Call makes the decision to activate the Corporate Emergency Operations Centre (CEOC) and issues alert notifications. If activated, a partial mobilization is recommended consisting of Deputy Incident Commander, Operations Liaison and Communications Support.

⁷ Corporate Relations is responsible for activating the joint communication plan between NLH and Newfoundland Power.

⁸ ECC will advise the NP Control Centre once internal alignment is achieved on the alert level through the CERP process.

SYSTEM OPERATING INSTRUCTION

STATION: GENERAL	Inst. No. T-096
TITLE: AVALON CAPABILITY AND RESERVES **	Page 3 of 5

PROCEDURE (cont'd.)

- Level 3- If the available Avalon reserve is anticipated to be less than the impact of half the largest contingency, the ECC will notify Exec On-call (CERP), Corporate Relations and Newfoundland Power’s Control Centre, advising of customer conservation strategies to help maintain sufficient Avalon reserve, if the capability shortfall is not corrected.
- Level 4 - If the available Avalon reserve is anticipated to approach zero or fall into a deficit, the ECC will notify Exec On-call (CERP), Corporate Relations and Newfoundland Power’s Control Centre, advising of rotating outages in order to maintain supply point voltages and transmission line loadings within acceptable ranges.

The following is the standard message that will be communicated if it is anticipated that a notification is to be made under Level 1, 2, 3 or 4; or a return to Level 0:

“System Operations is advising that the available Avalon reserve is at a notification level [0-4] for [insert date here]. The available Avalon reserve is expected to be [insert reserve amount in MW], calculated from the total Avalon capability of [insert available capacity in MW] and a peak Avalon load forecast of [insert peak forecast in MW].”

C. Operational requirements to cover largest contingency

The ECC shall maintain sufficient Avalon reserve to cover performance uncertainties in generating units and transmission equipment and unanticipated increases in demand. Such actions include the following: placing in service all available generating and transmission capacity, cancelling outages to generating units and transmission equipment that have a short recall, deploying all available standby resources, including Vale Capacity Assistance, cancelling Avalon industrial interruptible load and reducing Avalon load, through procedures such as public conservation notices, voltage reductions, curtailing interruptible loads and non-essential firm loads.

The ECC shall use the following guideline in the sequence outlined in order to cover the largest contingency, maintain the reliability of the Avalon and minimize service impacts to customers:

SYSTEM OPERATING INSTRUCTION

STATION: GENERAL	Inst. No. T-096
TITLE: AVALON CAPABILITY AND RESERVES **	Page 4 of 5

PROCEDURE (cont'd.)

Normal Sequence

1. Determine the Avalon capability under worst case contingency and the Avalon load threshold for operating standby units.
2. Based on this threshold and expected loads, determine requirements for staffing and potential operation for standby generation on the Avalon and notify appropriate personnel of standby staffing requirements.

To position the Avalon power system in order to cover off the single largest contingency, perform the following:

3. Ensure all NLH static reactive resources are in service (i.e. capacitor banks).
4. Request Newfoundland Power to maximize Avalon hydro generation.
5. Increase Holyrood real and reactive power up to the maximum Holyrood capability.
6. Start and load (to minimum) standby generators on the Avalon, both Hydro's and Newfoundland Power's, to cover the largest contingency once the Avalon load threshold for operation is exceeded. (At this point in time it is important to notify Avalon customers taking non-firm power and energy that if they continue to take non-firm power, the energy will be charged at higher standby generation rates.)
7. Request Newfoundland Power to curtail its interruptible loads on the Avalon (typically up to 10 MW and can take up to 2 hours to implement).
8. Request Vale for Capacity Assistance (7.6 MW) and to put all its available capacitor banks in service.
9. Request Praxair for Capacity Assistance (5 MW).

Load Reduction

10. Cancel all non-firm power delivery to customers and ensure Avalon industrial customers are within contract limits.
11. Inform Newfoundland Power of Hydro's need to reduce supply voltage at Hardwoods and Oxen Pond to minimum levels to facilitate load reduction. Implement voltage reduction (if not already in a reduced voltage condition).
12. Request Avalon industrial customers to shed non-essential loads, informing them of system conditions.

SYSTEM OPERATING INSTRUCTION

STATION: GENERAL	Inst. No. T-096
TITLE: AVALON CAPABILITY AND RESERVES **	Page 5 of 5

PROCEDURE (cont'd.)

Rotating Outages

If the Avalon reserve continues to decrease below the minimum level, the Avalon voltages and transmission line loadings should be watched closely. Delivery point voltages at CBC (212 kV) and Hardwoods and Oxen Pond (62.5 kV) need to be maintained. Transmission line loadings need to be kept to within thermal ratings. If voltages or line loadings deviate outside of acceptable operating ranges, perform the following:

13. Request Newfoundland Power to shed load by rotating feeder interruptions.

** Part of the Emergency Response Plan

REVISION HISTORY

<u>Version Number</u>	<u>Date</u>	<u>Description of Change</u>
0	2015-06-26	Original Issue
1	2016-12-22	Added Praxair Capacity Assistance
PREPARED: J. Tobin		APPROVED:

Appendix E
Generation Reserves (T-001)

SYSTEM OPERATING INSTRUCTION

STATION: GENERAL	Inst. No. T-001
TITLE: GENERATION RESERVES *, **	Page 1 of 5

INTRODUCTION

In order to ensure that customer service is maintained, the Energy Control Centre (ECC) shall exercise its authority to reduce risks to the generation supply and maintain sufficient generation reserves to meet current and anticipated customer demands. The ECC shall be prepared to deal with generation shortages and take appropriate actions in order to maintain the reliability of the Island Interconnected System.

*Generation reserve*¹ is required to replace generation capacity lost due to an equipment forced outage, to cover performance uncertainties in generating units or to cover unanticipated increases in demand. Sufficient generation reserve is required to meet current and forecasted demands under a contingency of the largest generating unit.

PROCEDURE

A. Calculation of *Available Generation Reserve*²

Available generation reserve shall be calculated for the current day and the following six days in the manner as indicated below:

Available Generation Reserve for each day =
 Available Generation of NLH (Hydro + Thermal + *Standby*³ + *Purchases*⁴); *plus*
 Available Generation of NP (Hydro + *Standby*); *plus*
 Available Generation of DLP (60 Hz Hydro); *plus*
 Capacity Assistance of Vale (*Standby*)⁵; *less*
 Forecasted Island Peak Load (adjusted for CBPP Capacity Assistance⁶ and Voltage Reduction⁷)

A plot is provided on the EMSView – Production - Load Forecast page for reference.

¹ *Generation Reserve* is defined as the quantity of available generation supply that is in excess of demand, and includes spinning reserve⁸. It is equal to Available Generation Supply less Current / Forecasted Demand.

² *Available Generation Reserve* is associated with generation that is in service or standby generation that can be placed in service within 20 minutes. NP's mobile generation may take up to 2 hours to place in service.

³ *Standby* generation includes combustion turbine / diesel generation, including the new CT at Holyrood.

⁴ *NLH Purchases* includes wind for the current day based on actual wind output, but assumes no wind generation for the following six days.

⁵ *Capacity Assistance* (when available) from Vale through operation of standby diesel units with a combined capacity of 10.8 MW.

⁶ *Capacity Assistance* (when available) from CBPP through load interruption in 20, 40 or 60 MW blocks.

⁷ Up to 20 MW of load reduction (on peak) is expected to be achieved through the *Voltage Reduction* strategy.

⁸ *Spinning reserve* is defined as unloaded generation that is synchronized to the power system and ready to serve additional demand.

SYSTEM OPERATING INSTRUCTION

STATION: GENERAL	Inst. No. T-001
TITLE: GENERATION RESERVES *, **	Page 2 of 5

PROCEDURE (cont'd.)

B. Assessment and Notification of Available Generation Reserve

The available generation reserve will be calculated for the current day and the following six days and an assessment will be made against the criteria in the table below. A notification will be issued to stakeholders when available generation reserve is below the stated thresholds for anytime within the next week.

<u>Available Reserve</u>	<u>Expected Action</u>	<u>Level</u>
> Largest Generating Unit + min. spinning reserve	none	0
< Largest Generating Unit + min. spinning reserve	Prepare for Potential Load Reduction	1
< Largest Generating Unit	Load Reduction	2
< ½ Largest Generating Unit	Conservation	3
Zero/deficit; hold f=59.8 Hz	Rotating Outages	4

Based on the assessment above, perform the following:

- Level 0 - If the available reserve is anticipated to be greater than the largest available generating unit capacity plus minimum spinning reserve, the ECC are not expected to perform any further actions, other than to advise the on-call Executive member (Exec On-call) of NLH's Corporate Emergency Response Plan (CERP), Corporate Relations and Newfoundland Power that available reserve has returned to normal following a prior Level 1, 2, 3 or 4 notice.
- Level 1 - If the available reserve is anticipated to be less than the largest available generating unit capacity plus the minimum spinning reserve, the ECC will notify Newfoundland Power's Control Centre, advising of possible requirements for load reduction to maintain sufficient spinning reserve, if the available generation reserve should decrease.
- Level 2 - If the available reserve is anticipated to be less than the largest available generating unit capacity, the ECC will notify Exec On-Call (CERP)⁹, Corporate Relations¹⁰ and Newfoundland Power, advising of load reduction strategies to maintain sufficient spinning reserve, if the generation shortfall is not corrected.

⁹ As part of the CERP, the Exec On-Call makes the decision to activate the Corporate Emergency Operations Centre (CEOC) and issues alert notifications.

¹⁰ Corporate Relations is responsible for activating the joint communication plan between NLH and Newfoundland Power.

SYSTEM OPERATING INSTRUCTION

STATION: GENERAL	Inst. No. T-001
TITLE: GENERATION RESERVES *, **	Page 3 of 5

PROCEDURE (cont'd.)

- Level 3 - If the available reserve is anticipated to be less than half of the largest available generating unit capacity, the ECC will notify Exec On-call (CERP), Corporate Relations and Newfoundland Power, advising of a requirement for customer conservation strategies to help maintain sufficient spinning reserve, if the generation shortfall is not corrected.
- Level 4 - If the available reserve is anticipated to approach zero or fall into a deficit, the ECC will notify Exec On-call (CERP), Corporate Relations and Newfoundland Power, advising of a requirement for rotating outages to help maintain frequency near the 60 Hertz standard, if the generation shortfall is not corrected.

The following is the standard message that will be communicated if it is anticipated that a notification is to be made under Level 1, 2, 3 or 4; or a return to Level 0:

“System Operations is advising that the available Island generation reserve is at a notification level [0-4] for [insert date here]. The available generation reserve is expected to be [insert reserve amount in MW], calculated from an available generation capacity of [insert available capacity in MW] and a peak load forecast of [insert peak forecast in MW].”

C. Maintaining Spinning Reserve

The ECC shall maintain sufficient spinning reserve to cover performance uncertainties in generating units, especially wind and other variable generation, and unanticipated increases in demand. The ECC will take appropriate action to maintain a minimum spinning reserve level equal to 70 MW. Such actions include the following: placing in service all available generating capacity, cancelling outages to generating units that have a short recall, deploying all available standby resources, including CBPP and Vale Capacity Assistance, cancelling industrial interruptible load and reducing system load, through procedures such as public conservation notices, voltage reductions, curtailing interruptible loads and non-essential firm loads.

SYSTEM OPERATING INSTRUCTION

STATION: GENERAL	Inst. No. T-001
TITLE: GENERATION RESERVES *, **	Page 4 of 5

PROCEDURE (cont'd.)

The following guideline shall be followed by the ECC Shift Supervisor and System Operator in the sequence outlined in order to maintain sufficient spinning reserve, maintain the reliability of the Island Interconnected System and minimize service impacts to customers:

Normal Sequence

1. Place in service all of Hydro's available hydroelectric generation.
2. Request Newfoundland Power to maximize their hydroelectric generation.
3. Make a Capacity Request of Deer Lake Power to maximize their hydroelectric generation.
4. Request Non-Utility Generators to maximize their hydroelectric and wind generation.
5. Maximize Holyrood thermal generation.
6. Start and load standby generators, both Hydro and Newfoundland Power units, in order of increasing average energy production cost with due consideration for unit start-up time, while holding the least efficient NLH standby combustion turbine unit in reserve. (At this point in time it is important to notify customers taking non-firm power and energy that if they continue to take non-firm power, the energy will be charged at higher standby generation rates.)
7. Request Newfoundland Power to curtail its interruptible loads (typically up to 10 MW and can take up to 2 hours to implement).
8. Request Corner Brook Pulp and Paper for Capacity Assistance (20, 40 or 60 MW).
9. Request Vale for Capacity Assistance (7.6 MW).
10. Request Praxair for Capacity Assistance (5 MW).
11. Start and load the remaining NLH standby combustion turbine unit.

Load Reduction

12. Cancel all non-firm power delivery to customers and ensure all industrial customers are within contract limits.
13. Inform Newfoundland Power of Hydro's need to reduce supply voltage at Hardwoods and Oxen Pond and other delivery points to minimum levels to facilitate load reduction. Implement voltage reduction.
14. Request Newfoundland Power to implement voltage reduction on its system.

SYSTEM OPERATING INSTRUCTION

STATION: GENERAL	Inst. No. T-001
TITLE: GENERATION RESERVES *, **	Page 5 of 5

PROCEDURE (cont'd.)

Load Reduction (cont'd)

15. Request industrial customers to shed non-essential loads, informing them of system conditions.
16. Request Corner Brook Pulp and Paper Supplemental Capacity Assistance (to a maximum of 30 MW). Note that this is above the Capacity Assistance request and a request for the full 30 MW will likely reduce CBPP Mill load to that required for essential services. Upon request for Supplemental Capacity Assistance, arrangements should be made with TRO-Central to close the load break bus tie switch B2B4-1 at Massey Drive.

Rotating Outages

If the spinning reserve continues to decrease below the minimum level, the system frequency should be watched closely. In order to minimize outages to customers, utilize the reserve as much as possible and maintain the system frequency at 59.8 Hz.

17. Request Newfoundland Power to shed load by rotating feeder interruptions. At the same time, shed load by rotating feeder interruptions in Hydro's rural distribution areas. Follow instruction for rotating outages, T-042.

* Part of the Environmental Plan
** Part of the Emergency Response Plan

REVISION HISTORY

<u>Version Number</u>	<u>Date</u>	<u>Description of Change</u>
0	1992-07-16	Original Issue
13	2016-12-22	Added Praxair Capacity Assistance
PREPARED: J. Tobin		APPROVED:

Appendix F
Outage Readiness Tracker

Equipment Outage	MOS Outage #	Customer Outage	PETS	Baseline %	Start	Finish	Outage Request Submitted?			WPC Requirements Reviewed?					Field Isolation Plan Required?			Energization/Start-Up Plan Required?						Commissioning Plan & Procedures			Resource Confirmation														
							Submitted	System Outage #	Approved	None	TAWP	OAWP	PC1 Submittal (7 Days Prior)	Submitted	Approved	Required		Plan Finalized (7 Days Prior)	Approved	Required		1st Draft (28 Days Prior)	Received	Plan Finalized (14 Days Prior)	Approved	Extra Outage Required	System Outage #	Plan Required		Plan Prepared (1 Day Prior)	Approved	Internal External Manpower (7 Days Prior)	Confirmed	Equipment Parts Deliverables (7 Days Prior)	Confirmed						
																Y	N			Y	N							Y	N							Y	N				
BDE B3T6	T-C024	No	<input type="checkbox"/>	<input checked="" type="checkbox"/>	100%	9-May-16	25-Jun-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9533	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2-May-16	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2-May-16	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	28-May-16	<input checked="" type="checkbox"/>	11-Jun-16	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	9689	<input checked="" type="checkbox"/>	<input type="checkbox"/>	8-May-16	<input checked="" type="checkbox"/>	2-May-16	<input checked="" type="checkbox"/>	2-May-16	<input checked="" type="checkbox"/>	
BDE B2T3	T-C021	No	<input type="checkbox"/>	<input checked="" type="checkbox"/>	92%	6-Jun-16	23-Jul-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9535	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	30-May-16	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	30-May-16	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	25-Jun-16	<input checked="" type="checkbox"/>	9-Jul-16	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input checked="" type="checkbox"/>	<input type="checkbox"/>	5-Jun-16	<input checked="" type="checkbox"/>	30-May-16	<input checked="" type="checkbox"/>	30-May-16	<input checked="" type="checkbox"/>	
BUC L05L33 Breaker PM	T-C164	No	<input type="checkbox"/>	<input checked="" type="checkbox"/>	100%	21-Jun-16	24-Jun-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9627	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
BDE T3 Transformer Protection	T-C211	No	<input type="checkbox"/>	<input checked="" type="checkbox"/>	100%	6-Jun-16	23-Jul-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9676	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
HWD B7B8 breaker replacement	T-C015	No	<input type="checkbox"/>	<input checked="" type="checkbox"/>	96%	30-May-16	14-Jul-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9649	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
HRD B12L42 Breaker replacement	T-C013	No	<input type="checkbox"/>	<input checked="" type="checkbox"/>	96%	28-May-16	14-Jul-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9602	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
TL203 Insulator Replacements, Outage #1	T-C048	No	<input type="checkbox"/>	<input checked="" type="checkbox"/>	100%	13-Jun-16	11-Jul-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9650	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	6-Jun-16	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
TL242 Replace Protection Systems	T-C006	No	<input type="checkbox"/>	<input checked="" type="checkbox"/>	100%	6-Jun-16	29-Jun-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9603	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
TL242 reconfiguration around soldiers pond	T-C007	No	<input type="checkbox"/>	<input checked="" type="checkbox"/>	100%	6-Jun-16	29-Jun-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9604	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	30-May-16	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
BDE T4 Transformer Protection Replacement	T-C269	No	<input type="checkbox"/>	<input checked="" type="checkbox"/>	100%	13-Jun-16	8-Jul-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9722	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
MDR T2 A-B phase PT replacement	T-C188	No	<input type="checkbox"/>	<input checked="" type="checkbox"/>	92%	29-Jun-16	30-Jun-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9710	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
BUC L05L33-1, B1L05-2, L05G disconnect PMs	T-C166	No	<input type="checkbox"/>	<input checked="" type="checkbox"/>	100%	20-Jun-16	20-Jun-16	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	9728	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	13-Jun-16	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
MDR B5L11-2, L11G disconnect PM, doble CTs	T-C191	No	<input type="checkbox"/>	<input type="checkbox"/>	92%	17-Jun-16	17-Jun-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9714	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	10-Jun-16	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
WAV B4 outage. L64G CM, PT doble	T-C134	No	<input type="checkbox"/>	<input checked="" type="checkbox"/>	100%	20-Jun-16	21-Jun-16	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	9661	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	13-Jun-16	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
HRD TS T3 Oil Replacement	T-C221	No	<input type="checkbox"/>	<input checked="" type="checkbox"/>	100%	20-Jun-16	1-Jul-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9769	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	13-Jun-16	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
BBK L400T2 Breaker Replacement	T-C027	No	<input type="checkbox"/>	<input checked="" type="checkbox"/>	92%	20-Jun-16	5-Aug-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9543	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
WAV B2T1 Breaker Replacement	T-C028	No	<input type="checkbox"/>	<input checked="" type="checkbox"/>	92%	21-Jun-16	5-Aug-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9652	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
BDE B3 outage. To install new B3T6 breaker	T-C253	No	<input type="checkbox"/>	<input checked="" type="checkbox"/>	100%	21-Jun-16	21-Jun-16	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	9689	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
BDE Unit #7, T7 replacement	T-C010	No	<input type="checkbox"/>	<input checked="" type="checkbox"/>	79%	26-Jun-16	19-Aug-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9545	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	19-Jun-16	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
BDE B9B10 breaker PM. B9B10-1 & B9B10-2 PM CTs	T-C101	No	<input type="checkbox"/>	<input type="checkbox"/>	92%	27-Jun-16	28-Jun-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9745	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
HRD B3L18 complete auxiliary contacts	T-C251	No	<input type="checkbox"/>	<input checked="" type="checkbox"/>	100%	21-Jun-16	24-Jun-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9777	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
MDR B2 doble PTs	T-C187	No	<input type="checkbox"/>	<input type="checkbox"/>	92%	28-Jun-16	28-Jun-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9766	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	21-Jun-16	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
BDE B1B2 Breaker Replacement	T-C045	No	<input type="checkbox"/>	<input checked="" type="checkbox"/>	83%	30-Jun-16	16-Aug-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9179	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
BDE T7 Transformer Protection Replacement	T-C215	No	<input type="checkbox"/>	<input checked="" type="checkbox"/>	83%	4-Jul-16	19-Aug-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9545	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
OPD B1L36 Breaker Replacement	T-C019	No	<input type="checkbox"/>	<input checked="" type="checkbox"/>	58%	4-Jul-16	20-Aug-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9767	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
BDE B13T12 replacement. T12 outage (TL220 to be feed via T10)	T-C069	No	<input type="checkbox"/>	<input checked="" type="checkbox"/>	83%	4-Jul-16	18-Jul-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9785	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	27-Jun-16	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
IRV B1L24 overhaul	T-C168	No	<input type="checkbox"/>	<input type="checkbox"/>	67%	4-Jul-16	11-Jul-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
BDE B9 outage. Install Mobile Sub (to bypass T11, T-C232), split B13, Isolate T12.	T-C237	YES	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	33%	4-Jul-16	4-Jul-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9784	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	27-Jun-16	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
TL233 Replace Crossarm on Structure #386	T-C270	No	<input type="checkbox"/>	<input type="checkbox"/>	83%	5-Jul-16	5-Jul-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9656	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	28-Jun-16	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
CRV TS L20T1 PM	T-C174	YES	<input checked="" type="checkbox"/>	<input type="checkbox"/>	33%	5-Jul-16	5-Jul-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9784	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	28-Jun-16	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
CRV TS T1 PM	T-C272	YES	<input checked="" type="checkbox"/>	<input type="checkbox"/>	33%	5-Jul-16	5-Jul-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9784	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	28-Jun-16	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
OPD B5 outage. B2B5-2, B5C1-1, B5T3-1 Disconnect PMs. PTs	T-C128	No	<input type="checkbox"/>	<input type="checkbox"/>	92%	6-Jul-16	8-Jul-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9663	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	29-Jun-16	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
OPD B2B5 doble	T-C127	No	<input type="checkbox"/>	<input type="checkbox"/>	92%	6-Jul-16	8-Jul-16	<input type="checkbox"/>	<input checked="" type="checkbox"/>	9663	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	29-Jun-16	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>																	
IRV B1L23 overhaul	T-C169	No	<input type="checkbox"/>																																						