

1 Q. Should the system be able to withstand the loss of the Sunnyside sub-station (or
2 any sub-station for that matter) without losing firm load?

3

4

5 A. The Hydro transmission system is planned such that it is acceptable to have loss of
6 firm load for the complete loss of any terminal station on the Island Interconnected
7 System. This is consistent with the North American Electric Reliability Corporation
8 (NERC) transmission planning standards TPL-001-0.1, TPL-002-0b, TPL-003-0b and
9 TPL-004-0a Table I Transmission System Standards – Normal and Emergency
10 Conditions. Within the NERC transmission planning standards, Table I defines
11 Category D – Extreme event resulting in two or more (multiple) elements removed
12 or cascading out of service. Included in Category D is loss of a substation (one
13 voltage level plus transformers), loss of a switching station (one voltage level plus
14 transformers), and loss of a large load or major load centre. The evaluation of the
15 risks and consequences include¹:

16

- 17 • may involve substantial loss of customer demand and generation in a
18 widespread area or areas ; and
- 19 • portions or all of the interconnected systems may or may not achieve a
20 new, stable operating point.

¹ NERC TPL-004-0a System Performance Following Extreme BES Events Table I Category D dated June 20, 2013.