

1 Q. Please explain the arrangement with CBPP in terms of generation and curtailable  
2 load and how they interact to provide value to the system under normal and  
3 emergency situations.

4

5

6 A. Under normal circumstances, with respect to generation loading sequence, please  
7 see Hydro's response to CA-NLH-008 with respect to the demand credit supply  
8 arrangement with CBPP.

9

10 Under the circumstances experienced in January 2014, the arrangement put in  
11 place made additional capacity available by CBPP curtailing some of its paper  
12 manufacturing processes, thus providing more security for critical loads and  
13 vulnerable customers.