

1 Q. Does Hydro intend to modify/introduce procedures granting it control during  
2 system emergencies over Island generation that it does not own? Would greater  
3 control be beneficial, and what would be involved in obtaining the necessary  
4 control over Island generation it does not own? Does NPCC have any requirements  
5 in this regard?

6

7

8 A. As outlined in Hydro's response to CA-NLH-008, Hydro already has operational  
9 control over a substantial amount of the generation it does not own. The Energy  
10 Control Center operators also work with Newfoundland Power and Hydro's  
11 Industrial Customers who own generation during both normal and emergency  
12 operating conditions to dispatch all generation in the most efficient manner to  
13 supply the full Island load and ensure system security and reliability. Hydro will  
14 continue to review and have discussions with Newfoundland Power and Hydro's  
15 Industrial Customers who own generation to examine whether any operational  
16 changes are appropriate.

17

18 NPCC has no further special requirements other than that Hydro, as the System  
19 Operator, will be responsible for the reliability and security of the system and will  
20 require direct or indirect control of all generation connected to the system.