

1 Q. Will Hydro's planning and operating criteria for supply to the Avalon Peninsula
2 change post Muskrat Falls? Specifically, please provide a detailed analysis of the
3 demand/supply situation for the Avalon Peninsula post Muskrat Falls showing
4 demand, existing generation, new generation, sales/purchases, demand
5 management including interruptible supply contracts, firm imports over the
6 transmission feeding the Avalon Peninsula and reserve margins for the 10-year
7 period following commissioning of Muskrat Falls and interconnecting transmission
8 project. Please show results for base case and contingency scenarios.

9

10

11 A. The supply to the Avalon Peninsula will be enhanced by the completion of the
12 Labrador-Island HVdc Link (LIL). The LIL will make 673 MW of capacity available to
13 the Island at Soldier's Pond net of the Nova Scotia block corresponding to
14 approximately 730 MW at Muskrat Falls. This 673 MW will replace the current
15 capability of the Holyrood Thermal Generating Station (HTGS) of 465 MW. In
16 addition, the completion of the third circuit from Bay d'Espoir to the Avalon
17 Peninsula will strengthen the supply to the area from other areas of the grid.
18 Furthermore, the addition of the LIL and the high inertia synchronous condensers at
19 Soldiers Pond will eliminate the need for operation of the under frequency load
20 shedding scheme for loss of on island generation.

21

22 Hydro's planning and operating criteria will not change with respect to supply to the
23 Avalon Peninsula post Muskrat Falls. Hydro's existing transmission planning criteria
24 with respect to equipment load levels and voltage levels under both normal and
25 single contingency events will remain in effect.

Island Interconnected System Supply Issues and Power Outages

Hydro plans generation additions for the Island Interconnected System as one system and not by region or geographic area. Table 1 provides a base case analysis of the demand/supply situation for the Island Interconnected System net customer generation for the period 2018 to 2027. The Hydro allocation for deliveries over the Labrador-Island Link is estimated to be 673 MW net of the Nova Scotia Block allocation.

Table 1 NLH Island Interconnected System Base Case Peak Demand – Supply Analysis - MW 2018 - 2027										
Firm Generation	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027
NLH Hydro	927.3	927.3	927.3	927.3	927.3	927.3	927.3	927.3	927.3	927.3
NUGs	86.0	86.0	86.0	86.0	86.0	86.0	86.0	86.0	86.0	86.0
HVdc	673.0	673.0	673.0	673.0	673.0	673.0	673.0	673.0	673.0	673.0
Subtotal	1686.3	1686.3	1686.3	1686.3	1686.3	1686.3	1686.3	1686.3	1686.3	1686.3
NLH Standby	234.7	234.7	234.7	234.7	234.7	234.7	234.7	234.7	234.7	234.7
NP standby	41.5	41.5	41.5	41.5	41.5	41.5	41.5	41.5	41.5	41.5
Subtotal	276.2	276.2	276.2	276.2	276.2	276.2	276.2	276.2	276.2	276.2
Total Gen	1962.5	1962.5	1962.5	1962.5	1962.5	1962.5	1962.5	1962.5	1962.5	1962.5
System Peak	1570	1559	1558	1568	1589	1616	1635	1656	1677	1695
Reserve	392.5	403.5	404.5	394.5	373.5	346.5	327.5	306.5	285.5	267.5
Notes: Analysis is for NLH System NUGs – non-utility generators NLH Standby includes Hardwoods (50 MW), Stephenville (50 MW), New Holyrood Combustion turbine (120 MW), Hawke's Bay (5.0 MW) and St. Anthony (9.7 MW) diesel plants NP Standby includes Greenhill, Wesleyville and Grand Bay Combustion turbines and portable diesels System Peak taken from 2013 Provincial Load Forecast (PLF) dated June 19, 2013 Holyrood units (while available for 2018 to 2020 period) have not been included in the reserve analysis										

Table 2 provides an analysis of the demand/supply situation for the Island Interconnected System net of customer generation for the period 2018 to 2027 under the loss of one pole on the Labrador-Island Link (i.e., monopolar outage). Hydro's allocation under continuous operation in monopolar mode is estimated to be 448 MW.

Island Interconnected System Supply Issues and Power Outages

Table 2 NLH Island Interconnected System Contingency Loss of One Pole of The Labrador-Island Link Peak Demand – Supply Analysis - MW 2018 - 2027										
Firm Generation	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027
NLH Hydro	927.3	927.3	927.3	927.3	927.3	927.3	927.3	927.3	927.3	927.3
NUGs	86.0	86.0	86.0	86.0	86.0	86.0	86.0	86.0	86.0	86.0
HVdc	448.0	448.0	448.0	448.0	448.0	448.0	448.0	448.0	448.0	448.0
Subtotal	1461.3	1461.3	1461.3	1461.3	1461.3	1461.3	1461.3	1461.3	1461.3	1461.3
NLH Standby	234.7	234.7	234.7	234.7	234.7	234.7	234.7	234.7	234.7	234.7
NP standby	41.5	41.5	41.5	41.5	41.5	41.5	41.5	41.5	41.5	41.5
Subtotal	276.2	276.2	276.2	276.2	276.2	276.2	276.2	276.2	276.2	276.2
Total Gen	1737.5	1737.5	1737.5	1737.5	1737.5	1737.5	1737.5	1737.5	1737.5	1737.5
System Peak	1570	1559	1558	1568	1589	1616	1635	1656	1677	1695
Reserve	167.5	178.5	179.5	169.5	148.5	121.5	102.5	81.5	60.5	42.5
Notes: Analysis is for NLH System NLH allocation via HVdc at Soldiers Pond reduced to 448 MW in continuous monopolar operation. NUGs – non-utility generators NLH Standby includes Hardwoods (50 MW), Stephenville (50 MW), New Holyrood Combustion turbine (120 MW), Hawke's Bay (5.0 MW) and St. Anthony (9.7 MW) diesel plants NP Standby includes Greenhill, Wesleyville and Grand Bay Combustion turbines and portable diesels System Peak taken from 2013 PLF dated June 19, 2013 Holyrood units (while available for 2018 to 2020 period) have not been included in the reserve analysis										

1

2

3

4

5

6

7

8

9

10

Table 3 provides an analysis of the demand/supply situation for the Island Interconnected System net of customer generation for the period 2018 to 2027 for the low probability contingency of the loss of the Labrador-Island Link bipole. For loss of the entire Labrador-Island Link, Hydro will import up to 300 MW of power from the Maritime Provinces over the Maritime Link to the island. The calculations indicate that based upon firm generation values there will be insufficient generation reserves for loss of the bipole over peak beginning in 2023. The response to PUB-NLH-217 identifies options that would be considered to extend the generation shortfall beyond 2023.

Island Interconnected System Supply Issues and Power Outages

Table 3 NLH Island Interconnected System Contingency Loss of The Labrador-Island Link Peak Demand – Supply Analysis - MW 2018 - 2027										
Firm Generation	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027
NLH Hydro	927.3	927.3	927.3	927.3	927.3	927.3	927.3	927.3	927.3	927.3
NUGs	86.0	86.0	86.0	86.0	86.0	86.0	86.0	86.0	86.0	86.0
HVdc	0	0	0	0	0	0	0	0	0	0
Subtotal	1013.3	1013.3	1013.3	1013.3	1013.3	1013.3	1013.3	1013.3	1013.3	1013.3
NLH Standby	234.7	234.7	234.7	234.7	234.7	234.7	234.7	234.7	234.7	234.7
NP standby	41.5	41.5	41.5	41.5	41.5	41.5	41.5	41.5	41.5	41.5
Subtotal	276.2	276.2	276.2	276.2	276.2	276.2	276.2	276.2	276.2	276.2
Total Island Gen	1289.6	1289.6	1289.6	1289.6	1289.6	1289.6	1289.6	1289.6	1289.6	1289.6
Import ML	300.0	300.0	300.0	300.0	300.0	300.0	300.0	300.0	300.0	300.0
Total Gen	1589.6	1589.6	1589.6	1589.6	1589.6	1589.6	1589.6	1589.6	1589.6	1589.6
System Peak	1570	1559	1558	1568	1589	1616	1635	1656	1677	1695
Reserve	19.6	30.6	31.6	21.6	0.6	-26.4	-45.4	-66.4	-87.4	-105.4
Max cont hydro capacity	30.1	30.1	30.1	30.1	30.1	30.1	30.1	30.1	30.1	30.1
Min interruptible	0	0	0	0	0	0	15.3	36.3	57.3	75.3
Notes: Analysis is for NLH System NUGs – non-utility generators NLH Standby includes Hardwoods (50 MW), Stephenville (50 MW), New Holyrood Combustion turbine (120 MW), Hawke's Bay (5.0 MW) and St. Anthony (9.7 MW) diesel plants NP Standby includes Greenhill, Wesleyville and Grand Bay Combustion turbines and portable diesels System Peak taken from 2013 PLF dated June 19, 2013 Holyrood units (while available for 2018 to 2020 period) have not been included in the reserve analysis										

1

2

3

4

5

6

7

8

9

With respect to the supply to the Avalon Peninsula, generation contingencies will have little impact on the ability to supply the region with all 230 kV transmission lines in operation. The addition of a new 230 kV transmission line between Bay d'Espoir and Western Avalon to ensure stable operation of the LIL under system contingencies will alleviate the existing transmission system constraints along the Bay d'Espoir east 230 kV corridor. When considering the supply to the Avalon Peninsula it is important to consider the load supplied at the isthmus via the Sunnyside and Come By Chance Terminal Stations.

During winter peak load conditions, the three 230 kV transmission lines between Bay d’Espoir and the Avalon Peninsula (i.e., TL202, TL206 and the new Bay d’Espoir to Western Avalon line) will have a combined thermal load limit of 1198 MVA.

Table 4 provides the transfers and generation capacities for the 230 kV transmission system east of Bay d’Espoir in the base case scenario (i.e., no outages). The table indicates by reference to the required flow from Bay d’Espoir (BDE) that there is sufficient transfer capacity and generation to supply the Bay d’Espoir-East load throughout this period.

Table 4 NLH Island Interconnected System Bay d’Espoir East Base Case Peak Demand – Supply Analysis - MW 2018 - 2027										
	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027
Avalon Peninsula	924.5	931.8	938.5	949.7	964.9	974.0	985.3	996.7	1004.9	1016.2
CBC	31.0	30.5	30.5	30.5	30.5	30.5	30.5	30.5	30.5	30.5
Sunnyside	110.2	111.3	112.2	113.7	115.8	117.0	118.5	120.1	121.2	122.7
Total load East of BDE	1034.7	1043.1	1050.7	1063.4	1080.7	1091.0	1103.9	1116.8	1126.1	1138.9
Avalon Gen										
HVdc	830.0	830.0	830.0	830.0	830.0	830.0	830.0	830.0	830.0	830.0
Paradise River	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0	8.0
Required flow from BDE	196.7	205.1	212.7	225.4	242.7	253.0	265.9	278.8	288.1	300.9
Avalon Standby Gen										
Hardwoods	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0
Holyrood CT	120.0	120.0	120.0	120.0	120.0	120.0	120.0	120.0	120.0	120.0
NP CTs	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0
Total standby	200	200	200	200	200	200	200	200	200	200
Notes: Analysis is for NLH System NLH Standby includes Hardwoods (50 MW), Stephenville (50 MW), New Holyrood Combustion turbine (120 MW), Hawke’s Bay (5.0 MW) and St. Anthony (9.7 MW) diesel plants NP Standby includes Greenhill, Wesleyville and Grand Bay Combustion turbines and portable diesels System Peak taken from 2013 PLF dated June 19, 2013 Holyrood units (while available for 2018 to 2020 period) have not been included in the reserve analysis										

Table 5 provides the demand/supply analysis for the system east of Bay d’Espoir assuming that the Labrador-Island Link is operating in continuous monopolar mode.

[illegible]

1 The analysis indicates a maximum flow of 100.9 MW from Bay d’Espoir and west
2 generation to the Avalon Peninsula for this contingency. Given a maximum transfer
3 capacity of approximately 629 MW on the remaining two 230 kV transmission lines
4 there is significant margin to maintain supply to the Avalon Peninsula under the
5 single 230 kV line outage event.