

1 Q. Can Hydro provide a quantitative assessment of how it converts LOLE requirements  
2 into LOLH and vice versa?

3

4

5 A. As Hydro does not use LOLE as a reliability criterion, Hydro does not convert LOLE  
6 requirements into LOLH or vice versa. Hydro did convert from using LOLE to LOLH as  
7 a reliability criterion in 1997. The process used is described in Hydro's response to  
8 PUB-NLH-122.