

1 Q. **Reference: PUB-NLH-269:** Hydro states in its reply that there is adequacy of  
2 separation between the AC and DC lines. The value of the 60Hz current induced in  
3 the HVdc line was not provided. Has this 60Hz induced current been calculated? If  
4 yes, has the HVdc manufacturer been required to design 60Hz blocking filters for  
5 the DC circuit?

6

7

8 A. The value of the 60 Hz current induced in the HVdc line has been calculated.

9

10 The maximum 60 Hz current on the dc line is expected to be approximately 3.4 A at  
11 the Soldiers Pond converter, and approximately 1.6 A at Muskrat Falls.

12

13 A requirement for blocking filters has not been identified.