

1 Q. Reference: Teshmont Report - Section 5 – HVDC Reliability Data (Part 5.2)

2 Data Provided by Nalcor Energy (pg 21):

3 **5.2.1.2. HVDC Overhead Lines**

4 *“Based on the Nalcor study the following are the expected failure rates and repair*
5 *times for the HVDC overhead lines.*

6 *Average failure rate per pole (based on 1100km length): 2.101/year*

7 *Average repair time: 1.78 hours*

8 *Average common mode failure rate: 0.02/year/100km*

9 *Average common mode repair time: 24 hours”*

10 **5.2.1.4. Electrode Lines**

11 *“In addition, and in agreement with what was stated in the study, the above*
12 *analysis would be considered only if the electrode lines will be constructed on a*
13 *separate wood-pole line. As the electrode lines will be installed on the main dc*
14 *line towers, the reliability of the electrode lines is expected to be included in the*
15 *common mode failure of the dc line. Given that the electrode line in Labrador will*
16 *be constructed on the main dc line towers for much of its length, it is not*
17 *anticipated that the LIL’s relatively long electrode line will impact or have a major*
18 *influence on LIL overall reliability.”*

19 Reference: NP-NLH-038, page 2, paragraph (f) states:

20 *“Anti-cascade requirements dictated that a maximum of 20 suspension 10*
21 *structures would be permitted between full-tension deadends.”*

22 Please explain the relationship between these data points.

23

24

25 A. The overhead line failures rates from Section 5 of the Teshmont report are

26 addressed in Hydro’s response to NP-NLH-133.

1 The reference to Section 5.2.1.4. of the Teshmont report relates to the fact that as
2 the electrode lines shall be installed on the HVdc structures, the electrode failure
3 rate was considered to be included in the common mode failure rate of the line.

4 This is in contrast to a scenario where the electrode is installed on separate
5 structures.

6

7 It is noted that the reference to Hydro's response to NP-NLH-038, page 2,
8 paragraph (f), relates to Hydro's design standard with respect to the Labrador Island
9 Link. Other than to ensure the structural integrity of the structures, this reference
10 does not relate to electrode reliability.