

1 **Q. Please provide a table showing for each of the past 10 years SAIDI and SAIFI**
 2 **statistics for NP's customers broken down by generation- and transmission-related**
 3 **(i.e., owing to Hydro outages) and distribution-related (i.e., owing to NP outages).**
 4

5 A. The SAIDI and SAIFI statistics for Newfoundland Power's customers for the past 10
 6 years are detailed in Table 1.
 7

8 In accordance with the Canadian Electricity Association guidelines, Newfoundland
 9 Power categorizes all outages originating with Newfoundland and Labrador Hydro
 10 ("Hydro") as "Loss of Supply".¹ Newfoundland Power does not have information to
 11 provide a further breakdown of outages originating with Hydro.
 12
 13

Table 1
Breakdown of Customer Interruptions

	SAIDI			SAIFI		
	NP Distribution	NP Transmission	Hydro Loss of Supply	NP Distribution	NP Transmission	Hydro Loss of Supply
2004	3.18	1.38	0.31	2.08	1.02	0.48
2005	2.50	0.77	0.26	1.61	0.96	0.64
2006	2.18	0.71	0.09	1.70	0.94	0.25
2007 ²	5.15	0.79	0.52	1.70	0.76	0.84
2008	2.01	0.66	0.13	1.53	0.82	0.49
2009	2.14	0.40	0.12	1.40	0.59	0.47
2010 ³	8.72	4.70	0.40	1.54	0.87	0.28
2011 ⁴	3.29	0.74	0.06	1.47	0.48	0.14
2012 ⁵	5.56	0.29	0.93	1.77	0.35	0.38
2013 ⁶	1.94	1.36	7.09	1.09	0.95	1.60

¹ The Canadian Electricity Association provides direction to utilities for reporting outages through its 2014 User Manual for the Service Continuity Reporting System.

² Includes SAIDI of 3.29 and SAIFI of 0.25 for a sleet storm on the Bonavista Peninsula in March.

³ Includes SAIDI of 11.23 and SAIFI of 1.17 for hurricane Igor.

⁴ Includes SAIDI of 1.26 and SAIFI of 0.25 for a winter storm.

⁵ Includes SAIDI of 3.11 and SAIFI of 0.40 for tropical storm Leslie.

⁶ Includes SAIDI of 0.81 and SAIFI of 0.32 for NLH system problems in January.