

1 Q. Please explain what work was being done to get Unit 3 back on line from 0413 to
2 0630, January 11, 2013.

3

4

5 A. When Unit 3 tripped offline, the operations staff at the Holyrood Plant assessed the
6 condition to determine why the unit tripped. It was determined that a fault
7 occurred in the switchyard. Once the fault was identified and it was determined
8 that the unit could be reliability restarted, the process to restart the unit
9 commenced.