

1 Q. Please outline the diesel engine capacity available to power the Holyrood plant
2 after 0700 hrs. on January 11, 2013 and how long this capacity was required.

3

4

5 A. The two emergency diesel generators at Holyrood ran as required to maintain
6 battery chargers for critical DC systems as well as plant high bay lighting and other
7 essential services. Their capacity is 650kW and 450kW respectively. These
8 generators ran from 0642 to the time when station service was restored in the
9 afternoon of January 11, 2013.