

1 Q. Please provide the scope of work completed on the fuel system at Holyrood in 2014
2 and indicate if there has been any issues with the quality of fuel received this year
3 and/or the fuel system.

4

5

6 A. In addition to the extensive work completed in 2013, the following corrective
7 repairs were executed on the fuel oil system in 2014: the east and west suction
8 heaters were replaced on fuel storage tank #1; the east fuel oil heater was opened
9 for maintenance and inspection on Unit #3; steam tracing leaks and traps were
10 repaired in the main tank farm; and minor inspection and repairs were completed
11 on the marine terminal jetty loading arms. Other than as noted above, there have
12 been no issues with the fuel system and/or the quality of the fuel received in 2014
13 which have impacted Holyrood's reliable supply of power.