

1 Q. Please complete the following table (all amounts in GWh, net of losses):

	MF/WMA generation	Energy delivered to Soldier's Pond	MF energy used to meet NLH requirements	MF energy delivered from Soldier's Pond under the Maritime Link Agreement	MF energy delivered from Soldier's Pond under the Energy Access Agreement	Surplus MF energy
2014						
2015						
...						
2067						

2

3

4 A. Please see the tables on the next two pages. The amount of energy delivered to
5 Soldiers Pond for purposes other than the requirements of Hydro under the
6 Hydro/Muskrat Falls PPA and for the Nova Scotia Block under the Nalcor/Emera
7 Energy and Capacity Agreement are dependent on the market activities of Nalcor
8 (including the outcome from time to time of solicitations for energy from Nova
9 Scotia Power under the Energy Access Agreement (EAA)) and therefore cannot be
10 quantified. For Muskrat Falls Additional Energy available at Soldiers Pond (to
11 potentially satisfy additional growth on the Island Interconnected System, the EAA
12 or other market opportunities), please see Hydro's response to CA-NLH-029.

Island Interconnected System Supply Issues and Power Outages

Page 2 of 3

	MF/WMA Gen at Muskat Falls	Energy Delivered to Soldier's Pond ¹	MF energy used to meet NLH requirements at Soldier's Pond	MF energy delivered from Soldier's Pond under the Maritime Link Agreement	MF energy delivered from Soldier's Pond under the Energy Access Agreement	Surplus MF energy at Soldier's Pond
	(GWh)	(GWh)	(GWh)	(GWh)	(GWh)	(GWh)
2014	N/A	N/A	N/A	N/A	N/A	N/A
2015	N/A	N/A	N/A	N/A	N/A	N/A
2016	N/A	N/A	N/A	N/A	N/A	N/A
2017	N/A	N/A	N/A	N/A	N/A	N/A
2018	3,961	1,623	1,067	556	N/A	N/A
2019	4,930	3,041	1,886	1,155	N/A	N/A
2020	4,930	2,990	1,835	1,155	N/A	N/A
2021	4,930	3,062	1,907	1,155	N/A	N/A
2022	4,930	3,163	2,008	1,155	N/A	N/A
2023	4,930	3,175	2,111	1,064	N/A	N/A
2024	4,930	3,111	2,183	929	N/A	N/A
2025	4,930	3,182	2,253	929	N/A	N/A
2026	4,930	3,254	2,325	929	N/A	N/A
2027	4,930	3,325	2,396	929	N/A	N/A
2028	4,930	3,475	2,546	929	N/A	N/A
2029	4,930	3,626	2,697	929	N/A	N/A
2030	4,930	3,696	2,768	929	N/A	N/A
2031	4,930	3,768	2,839	929	N/A	N/A
2032	4,930	3,840	2,911	929	N/A	N/A
2033	4,930	3,911	2,982	929	N/A	N/A
2034	4,930	3,983	3,054	929	N/A	N/A
2035	4,930	4,053	3,125	929	N/A	N/A
2036	4,930	4,125	3,196	929	N/A	N/A
2037	4,930	4,197	3,268	929	N/A	N/A
2038	4,930	4,268	3,339	929	N/A	N/A
2039	4,930	4,340	3,411	929	N/A	N/A
2040	4,930	4,410	3,482	929	N/A	N/A
2041	4,930	4,502	3,573	929	N/A	N/A
2042	4,930	4,564	3,635	929	N/A	N/A

Note:

1. Energy Delivered to Soldier's Pond consists of
MF energy delivered from Soldier's Pond under the Maritime Link Agreement
and MF energy used to meet NLH requirements at Soldier's Pond

Island Interconnected System Supply Issues and Power Outages

Page 3 of 3

	MF/WMA Gen at Muskat Falls	Energy Delivered to Soldier's Pond ¹	MF energy used to meet NLH requirements at Soldier's Pond	MF energy delivered from Soldier's Pond under the Maritime Link Agreement	MF energy delivered from Soldier's Pond under the Energy Access Agreement	Surplus MF energy at Soldier's Pond
	(GWh)	(GWh)	(GWh)	(GWh)	(GWh)	(GWh)
2043	4,930	4,618	3,689	929	N/A	N/A
2044	4,930	4,670	3,742	929	N/A	N/A
2045	4,930	4,724	3,795	929	N/A	N/A
2046	4,930	4,765	3,836	929	N/A	N/A
2047	4,930	4,765	3,836	929	N/A	N/A
2048	4,930	4,765	3,836	929	N/A	N/A
2049	4,930	4,765	3,836	929	N/A	N/A
2050	4,930	4,765	3,836	929	N/A	N/A
2051	4,930	4,765	3,836	929	N/A	N/A
2052	4,930	4,765	3,836	929	N/A	N/A
2053	4,930	4,520	4,055	464	N/A	N/A
2054	4,930	4,093	4,093	0	N/A	N/A
2055	4,930	4,131	4,131	0	N/A	N/A
2056	4,930	4,168	4,168	0	N/A	N/A
2057	4,930	4,206	4,206	0	N/A	N/A
2058	4,930	4,244	4,244	0	N/A	N/A
2059	4,930	4,281	4,281	0	N/A	N/A
2060	4,930	4,319	4,319	0	N/A	N/A
2061	4,930	4,357	4,357	0	N/A	N/A
2062	4,930	4,394	4,394	0	N/A	N/A
2063	4,930	4,432	4,432	0	N/A	N/A
2064	4,930	4,470	4,470	0	N/A	N/A
2065	4,930	4,507	4,507	0	N/A	N/A
2066	4,930	4,545	4,545	0	N/A	N/A
2067	4,930	4,583	4,583	0	N/A	N/A

Note:

1. Energy Delivered to Soldier's Pond consists of
MF energy delivered from Soldier's Pond under the Maritime Link Agreement
and MF energy used to meet NLH requirements at Soldier's Pond