

1 Q. **Re: GRK-NLH-031**

2 Preamble: The response provides a link to the full text of the framework
3 agreement, but does not provide a concise summary of Nalcor's energy delivery
4 obligations under the Maritime Link Agreements.

5 Please provide a concise summary of Nalcor's energy delivery obligations under the
6 Maritime Link Agreements.

7

8

9 A. The referenced Energy and Capacity Agreement provides the complete detail of
10 Nalcor's delivery obligations to Emera; however, a concise summary of the
11 obligations is for the delivery of the Nova Scotia Block which includes:

- 12 • 0.98 TWh of energy annually from Muskrat Falls to be delivered to
13 Woodbine, Nova Scotia at a constant capacity less the associated
14 transmission losses, seven days per week, 16 hours per day, between
15 0700 APT and 2300 APT for a period of 35 years.
- 16 • Any Supplemental Energy as outlined in Schedule 4 of the Energy and
17 Capacity Agreement. Supplemental Energy would be amounts of energy
18 owing to compensate for the adjustment of the amortization of the
19 Maritime Link Assets from 50 to 35 years. Final determination of any
20 requirement for Supplemental Energy cannot be made until after First
21 Commercial Power. Any Supplemental Energy required would be
22 delivered over the first five years of the agreement during the months
23 of January to March and November to December, seven days per week,
24 eight hours per day, between 2300 APT and 0700 APT.