

1 Q. Re: PUB-NLH-217

2 Citation (p. 9):

3 In the event of a complete LIL outage, capacity available to supply Island load would
4 include approximately:

- 5 • 1013 to 1043 MW of on Island hydro-electric (variation due to reservoir
6 levels);
- 7 • 276 MW of on Island thermal generation;
- 8 • Up to 300 MW of import via the Maritime Link; and
- 9 • Potential interruptible customer loads of 60 MW or more.

10 Please indicate for how many hours a year NLH can count on 1013 to 1043 MW
11 from Island hydro-electric generation.

12

13

14 A. The ability of the hydro-electric generation on the island to supply maximum output
15 for extended periods of time is dependent, to a large degree, on the reservoir
16 storage levels at the time of the Labrador - Island HVdc Link (LIL) outage, the
17 expected inflows post outage and the required reservoir storage levels necessary to
18 ensure the supply of energy in the post outage period.¹

19

20 As noted in Hydro's response to PUB-NLH-212, Hydro has set the maximum LIL
21 bipole outage duration at two weeks for loss of the overhead line. The worst case
22 two-week outage window with respect to capacity to supply the load would occur
23 during the winter peak load period.

24

¹ Hydro has large multi-year storage reservoirs designed to enable sustained production levels during dry periods and to capture as much water as economically possible without spilling. As a result of this storage capability, the plants have significant operating flexibility to adjust to changing production requirements.

1 A review of the average hydrology for the Hydro island hydro-electric generation
2 indicates that there would be in excess of 1400 GWh of storage in the hydro
3 reservoirs. Using hourly data from Hydro's Energy Management System, an hourly
4 load shape for the worst-case two-week outage window in the year 2025 was
5 developed. A typical hydro-electric dispatch to follow the load pattern for the two-
6 week outage was found to result in generation of 262.3 GWh of energy. Operating
7 the hydro-electric generation at the maximum level for the entire two-week outage
8 period is found to result in an 87.2 GWh increase in energy production. Given the
9 storage position in the reservoirs, there is no issue with operating the hydro
10 generation continuously at maximum output for a two-week LIL outage. On
11 average, in excess of 1,400 GWh of energy would be in storage in Hydro's on-island
12 reservoirs. Assuming no inflows (which is a conservative assumption), 1,400 GWh is
13 sufficient to generate 1,000 MW for a period of approximately two months.² As
14 further demonstrated in Hydro's response to GRK-NLH-074, Hydro would have
15 sufficient energy resources from both on-island hydro, the Maritime Link and
16 standby thermal resources to supply full load.

² $[1,400 \text{ GWh} * 1,000 \text{ MWh/GWh}] / 1,000 \text{ MW} = 1,400 \text{ hours}$
 $[1,400 \text{ hr} / 24 \text{ hr/day} / 30 \text{ days/month}] = 1.94 \text{ months, or approximately 2 months}$