

1 Q. Please provide incremental and cumulative MW savings resulting from Hydro's
2 CDM efforts 2009-2013.

3
4
5 A. As noted in Hydro's response to GRK-NLH-081, Hydro's efforts in CDM have been
6 focused on energy savings. Demand savings were incidental to the energy savings
7 and are the result of the various technologies customers applied in response to
8 Hydro's CDM program offerings. The tables below provide the incremental and
9 cumulative kW savings resulting from Hydro's CDM efforts during 2009-2013.

10

Hydro's CDM Demand Savings – Incremental (kW)					
	2009	2010	2011	2012	2013
Insulation	9	19	51	39	37
Thermostats	1	5	5	9	2
Windows	3	12	11	15	13
HRV Program	-	-	-	-	-
Commercial Lighting	-	-	36	8	6
Industrial	-	-	-	71	321
Total	13	36	103	142	379

11

Hydro's CDM Demand Savings – Cumulative (kW)					
	2009	2010	2011	2012	2013
Insulation	9	28	79	118	155
Thermostats	1	6	11	20	22
Windows	3	15	26	41	54
HRV Program	-	-	-	-	-
Commercial Lighting	-	-	36	44	50

Hydro's CDM Demand Savings – Cumulative (kW)					
Industrial	-	-	-	71	392
Total	13	49	152	294	673

1

2

3

4

5

6

Note: The above are savings attributed to Island Rural Customers and the Industrial Customers on the Island Interconnected System that participated in Hydro's energy efficiency programs. Please see Newfoundland Power's response to GRK-NP-005 for a description of the savings associated with Newfoundland Power's program participation.