

1 Q. Re: GRK-NLH-060, rev. 1
2 Please state the combined forced outage rate for the Muskrat Falls Generating
3 Station in combination with the Labrador-Island Link as a whole.
4 Please confirm that this combined rate does not include any provision for
5 outages related either to a) the integrity of the MF reservoir (e.g. a North Spur
6 slide) or b) outages related to application of the Water Management Agreement.

7
8
9 A. As stated in Hydro's response to GRK-NLH-060 (Revision 1, Mar 2-15), the forced
10 outage rate for the Labrador-Island Link as a whole is 0.91%.

11 Also, as provided in Hydro's response to GRK-NLH-060 (Revision 1, Mar 2-15):

12
13 Regarding forced outage rates for the Muskrat Falls generating
14 station, assuming that having three or more units in-service is a
15 reasonable full and/or reduced power capability, then if a forced
16 outage rate of 0.9% is assumed for each unit, the forced outage rate
17 for two or more units out simultaneously would be 0.05%.

18
19 Therefore, the combined forced outage rate for the Muskrat Falls Generating
20 Station in combination with the Labrador-Island Link as a whole would be 0.96%.

21
22 This combined rate does not include any provision for outages related either to a)
23 the integrity of the MF reservoir (e.g., a North Spur slide) or b) outages related to
24 application of the Water Management Agreement.

25
26 Hydro's position with respect to events concerning the integrity of the Muskrat
27 Falls reservoir and the application of the Water Management Agreement are set
28 out in Hydro's response to GRK-NLH-060 (Revision 1, Mar 2-15).