

1 Q. **Re: PUB-NLH-217 Citation:**

2 In the event of a complete LIL outage, capacity available to supply Island load
3 would include approximately:

- 4 • 1013 to 1043 MW of on Island hydro-electric (variation due to reservoir
5 levels);
- 6 • 276 MW of on Island thermal generation;
- 7 • Up to 300 MW of import via the Maritime Link; and
- 8 • Potential interruptible customer loads of 60 MW or more.

9 **Please confirm that the 276 MW of on Island thermal generation mentioned**
10 **here includes the 234.7 MW of NLH standby combustion turbines and diesel and**
11 **the 41.5 MW of NP standby thermal generation mentioned in the preceding**
12 **paragraph.**

13

14

15 A. Confirmed.