

1 Q. Re: GRK-NLH-022, GRK-NLH-102

2 Citation 1: "The overall power from Muskrat Falls is unaffected by a
3 different interpretation of the power contract renewal in 2016."

4 Citation 2: "The reference refers to the annual energy from the plant."

5 **Question: Would the ability of Muskrat Falls to provide capacity at the winter**
6 **peak be affected by a different interpretation of the power contract renewal in**
7 **2016?**

8 **Please indicate the capacity at winter peak available to NLH for planning purposes**
9 **from Muskrat Falls, under a) Nalcor's and b) Hydro-Québec's interpretation of the**
10 **power contract renewal provisions. In each case, please explain in detail the**
11 **justification for the stated capacity value.**

12

13

14 A. The planned installed capacity of Muskrat Falls is 824 MW. Hydro does not foresee
15 the winter capacity of Muskrat Falls being affected by the interpretations of the
16 power contract renewal because the winter capacity is not tied to the manner in
17 which the monthly amount energy is requested to be delivered by CF(L)Co to
18 Hydro-Quebec.