

1 Q. With reference to Hydro's response to IC-NLH-011, was the increases in employee
2 person hours and contractor expenditures in 2013 and 2014, relative to previous
3 years, planned (i.e. specifically budgeted for) by Hydro or unplanned (for example,
4 in response to events such as the January 2013 and January 2014 outage events)?
5
6

7 A. The increase in employee person hours and contractor expenditures in 2013 and
8 2014 as a result of: (1) the January 2013 and 2014 outage events, and (2) actions
9 Hydro initiated following a review of these events. Some examples of drivers of the
10 increases are:

11 **2013**

- 12 a. Installation of infrastructure and Newfoundland Power mobile
13 generation at Holyrood.
14 b. Exercising of air blast circuit breakers.
15 c. RTV coating of air blast circuit breakers in Holyrood.
16 d. Protection and control improvement items.
17

18 **2014**

- 19 a. Sunnyside transformer T1 fire and environmental remediation.
20 b. Air blast circuit breaker repairs to B1L17 at Holyrood and B1L03 in
21 Sunnyside.
22 c. Accelerated preventive maintenance and corrective maintenance
23 recovery program (contractors and internal employees).
24 d. Exercising of air blast circuit breakers.
25 e. Protection and control improvement items.