

1 Q. In reference to Table 2 on page 13 of the ESRA Report, please provide details of P50
2 and P90 load forecasts, including how Hydro estimates probability of actual peak
3 being 50%/90% lower than forecast, conversely being higher than forecast
4 50%/10% of the time.

5
6
7 A. Hydro's P90 demand forecast establishes the influence that severe winter weather
8 has on island system peak requirements due to weather driven loads demanded by
9 Newfoundland Power and Hydro Rural customers. Peak demands on the Island
10 Interconnected System are highly influenced by weather as measured by wind chill.

11
12 On a probabilistic basis, the peak demand forecast based on the 90th percentile or
13 P90 wind chill infers that peak demand will be lower than forecast 90% of the time
14 and higher than forecast 10% of the time. Similarly, the peak demand forecast
15 based on the average or P50 load factor infers that peak demand will be lower than
16 forecast 50% of the time and higher than forecast 50% of the time.

17
18 Hydro estimates probability of actual peak being 90% lower than forecast,
19 conversely being higher than forecast 10% of the time, through inference based on
20 historical wind chill. Hydro uses the historical wind chill in conjunction with Hydro's
21 long established forecast model, which predicts utility peak demand load
22 requirements on the basis of wind chill along with other explanatory variables of
23 peak demand.

1 Hydro maintains a database of historical weather records from weather stations at
2 three geographically dispersed locations on the island from which the coldest¹
3 annual weighted Island wind chill is established for each of the past 30 years. From
4 this database, Hydro establishes the historical average (P50) wind chill as well as the
5 90th percentile (P90) wind chill. Hydro uses the P50 and P90 wind chill values in
6 Hydro's peak demand model to predict incremental peak demand requirements
7 associated with P90 verses P50 wind chill conditions.

8

9 Hydro estimates probability of actual base case peak being 50% lower than
10 forecast, conversely being higher than forecast 50% of the time, through inference
11 based on historical load factors. Both Hydro and Newfoundland Power forecast
12 peak demand requirements for each of their respective customer groups based on
13 average historical annual load factor records.

¹ The data set encompasses the core day time hours at which island peaks have historically occurred.