

1 Q. In section 4.2, page 6 of the ESRA Report, Hydro notes that it is committed to
2 maintaining a megawatt (MW) reserve of greater than 240 MW to provide the
3 ability to withstand the most onerous single contingency (loss of Holyrood Unit 1 or
4 2) while maintaining a spinning reserve of 70 MW. Please detail how the 240 MW
5 reserve will provide a spinning reserve of 70 MW with the loss of Holyrood Unit 1 or
6 2.

7

8

9 A. As stated in the Energy Supply Risk Assessment (ESRA) report,

10

11 *“...Hydro has committed to maintaining a megawatt (MW) reserve*
12 *of greater than 240 MW. The 240 MW reserve provides the ability to*
13 *withstand the most onerous single contingency (loss of Holyrood*
14 *Unit 1 or 2) while maintaining a spinning reserve of 70 MW.”*

15

16 Under normal operating conditions, Hydro plans to operate with a minimum
17 reserve of 240 MW during peak demand. In this case, the loss of Unit 1 or 2 at
18 Holyrood would decrease this reserve by 170 MW, reducing Hydro’s reserve to
19 70 MW (240 MW – 170 MW = 70 MW).

20

21 Therefore, in the case of the most onerous contingency (loss of Holyrood Unit 1 or
22 2), Hydro would have at least 70 MW of generation available in excess of its
23 forecast peak demand that it could hold in spinning reserve.