

1 Q. Please explain why the nameplate rating for Holyrood Units 1 and 2 are shown at
2 175 MW in Table 4 [page 18] of the ESRA Report compared to 170 MW in the table
3 in Appendix A of that Report.

4

5

6 A. The nameplate rating of the generators for both Holyrood units 1 and 2 are 175
7 MW (194.4 MVA at 0.9 power factor = 175 MW); however, the maximum
8 continuous ratings for these units, inclusive of all generation equipment, was
9 determined after the unit upgrades in 1988 and 1989 to be 170 MW each. As such,
10 the 170 MW available to the Island Interconnected System is reflected in Appendix
11 A of the ESRA Report.