

1 Q. In reference to sections 4.2 and 4.3 of the ESRA Report, please provide details of  
2 the N-1 generation and transmission contingencies required to be reviewed for the  
3 IIS after the Maritime Link (ML) is in service (assuming the LIL is not yet in service).  
4 Please provide the most onerous single generation contingency and transmission  
5 contingency after the ML is in service.

6

7

8 A. Once the Maritime Link (ML) is placed in service, regardless of the in-service of  
9 Muskrat Falls or the LIL, the most onerous ac transmission line contingency would  
10 be in the TL242-TL266 corridor between Soldiers Pond Terminal Station and  
11 Hardwoods Terminal Station. This will be the most heavily loaded ac corridor in the  
12 IIS. Required upgrades to this corridor, identified via transmission planning analysis,  
13 were addressed in Hydro's 2016 Capital Budget where the construction of a new  
14 230 kV transmission line, TL 266, was approved. With respect to transmission  
15 contingencies required to be reviewed after the ML is in service, Hydro will  
16 continue to evaluate its transmission network in accordance with Board-approved  
17 transmission planning criteria, as described in section 4.3 of the ESRA report.

18

19 Hydro does not use N-1 criterion in the determination of generation adequacy for  
20 the Island Interconnected System. Hydro currently uses Loss of Load Hours (LOLH),  
21 a probabilistic determination of generation adequacy, and reserve margin, based on  
22 the current 240 MW target.

23

24 Without the in service of Muskrat Falls, Holyrood plant will continue to provide  
25 base load power to the Island Interconnected System, and as such, the loss of Unit 1  
26 or Unit 2 at Holyrood will remain the most onerous single generation contingency.