

1 Q. Please describe the assumed role, for the purposes of the ESRA Report, that  
2 Holyrood oil-fired, gas-fired and diesel units each would play after the LIL is in  
3 service (assuming that neither Muskrat Falls nor the ML is yet in service).

4

5

6 A. For the purposes of the ESRA Report, no scenarios were considered with the  
7 Labrador Island Link (LIL) in service without the Maritime Link (ML) as well.

8

9 However, if the LIL were in service providing power available through recall only  
10 (110 MW firm capacity, as noted in Section 7.3.1), with neither the ML or Muskrat  
11 Falls in service, Holyrood Thermal Generating Station would continue to supply  
12 Island Interconnected System (IIS) base load requirements. Further, in this scenario,  
13 Hydro would operate its gas turbines and diesel units as standby units or for  
14 operational support, barring an operational requirement to use these assets to  
15 provide energy.