

1 Q. In reference to Table 23 at page 43 of the Teshmont Report, “Major Hydro Owned  
2 or Power Purchase Generating Units in Pre-HVDC and Post-HVDC Cases”, please  
3 confirm that the table includes all Power Purchase Generating Units. If not, please  
4 explain.

5

6

7 A. Table 23 does not include backup generation owned by Vale, Newfoundland Power  
8 hydraulic generation, Deer Lake Power generation, or St. Lawrence and Fermeuse  
9 wind farms.

10

11 Vale generation was not available when the project was initiated in 2014 and is not  
12 included.

13

14 Newfoundland Power hydraulic generation and Deer Lake Power generation is  
15 assumed to be online in both cases.

16

17 St Lawrence and Fermeuse wind farms are assumed to be offline in both cases.

18

19 It is noted that the dispatch of these units is consistent in both cases and therefore  
20 does not have an appreciable impact on the relative reliability comparison  
21 performed by Teshmont.