

1 Q. In reference to the table on page 5 of Hydro's Summary Report, please confirm that  
2 2.72 GW.h/year EUE is estimated taking into account of Hydro's power purchases,  
3 including purchases under capacity assistance agreements, Newfoundland Power  
4 thermal units. If not, please explain.

5

6

7 A. EUE indices calculated as part of the Teshmont analysis did consider Hydro's power  
8 purchases, including Newfoundland Power thermal units. Purchases under capacity  
9 assistance agreements were not included. This simplification was common to both  
10 Pre-HVdc and Post-HVdc scenarios and therefore did not have a material impact on  
11 the relative comparison of reliability, as discussed in Hydro's response to IC-NLH-  
12 072.