

1 Q. In reference to the table on page 5 of Hydro's Summary Report,, please confirm
2 that 2.72 GW.h/year EUE is estimated based on an assumption that Holyrood units
3 would be off line.

4

5

6 A. The statement is correct as it was assumed that Holyrood units would not be
7 available for generation in the specified case.