

1 **Q: Reference: *Review of Newfoundland and Labrador Hydro Power Supply***
2 ***Adequacy 18 and Reliability Prior to and Post Muskrat Falls Final Report, August***
3 ***19, 2016, 19 Page 77, Conclusion IV-17, Point 2***
4

5 **For Conclusion IV-17, Point 2, bullets a, b, c and e, please indicate Liberty's**
6 **estimation of the duration for these "relatively short duration" outages and the**
7 **probability per year of their occurrence.**
8

9
10 A. Conclusion IV-17, Point 2, bullets a), b) and c): Tripping of ac lines leading to a
11 converter station can be caused by lightning strikes, pollution flashover or a tower
12 collapse, e.g. due to severe weather. Lightning strikes may result in a short outage
13 only, and may not impact on the HVdc transmission. Pollution may result in so
14 frequent flashovers, that continued operation may not be advisable, because
15 mechanical damage could be caused to insulators. The worst scenario will be the
16 collapse of several towers. Hydro has stated that they will target to repair any line
17 outage within 2 weeks, but if the weather is very severe, both HVdc and HVac
18 towers might need to be repaired, which will stretch resources. Liberty does not have
19 sufficient information to estimate the probability of such occurrences.
20

21 Conclusion IV-17, Point 2, bullet e): Operator errors are minimized by continuous
22 and on-going training of Operators. Nevertheless, errors may happen, and the station
23 may be tripped. Equipment damage, as a cause of operator error is usually unlikely,
24 because the converter station protection will act. Therefore, the scheme can be
25 returned to service following an investigation of the cause, and the usual safety
26 checks. This will typically take at least 15 minutes. With good and continuous
27 Operator training scheme the probability of outages being caused by Operator errors
28 will be very small.