

- 1 Q. Reference: Response to Request for Information NP-NLH-004
2 The response to Request for Information NP-NLH-004 provides graphs on pages 20,
3 21, 36, 37, 44, 45, 46, 47, 48, and 49 showing % Utilization for each as-designed
4 structure under various load cases. Please provide the methodology used to
5 determine the %Utilization for each of these graphs.
6
7
- 8 A. Refer to Hydro's response to NP-NLH-040. For each graph noted in NP-NLH-004,
9 specific load cases of maximum ice, maximum wind and combined wind and ice
10 were input into PLS-CADD, and the percent utilization data is a direct output from
11 PLS-CADD. Excel was used to chart the results.