

1 Q. Reference: CAN/CSA-C22.3 No. 60826-10, Design Criteria of Overhead Transmission
2 Lines

3 The referenced standard CAN/CSA-C22.3 No. 60826-10 states in Section 7.3.3, on
4 page CSA/15:

5 *“The following default (simplified) values can be used for lattice steel
6 towers in the majority of lines:*

7 *(a) suspension towers: $\phi_R = 0.9$ for intact loading cases and ≤ 1.0 for
8 failure loading cases; and*

9 *(b) angle and dead-end towers: intact $\phi_R = 0.8$ and failed system $\phi_R = 0.9$*

10 *where $\phi_R = \phi_N \phi_S \phi_Q \phi_C$ ”*

11 Were strength (reduction) factors applied in the assessment of whether or not the
12 design of the Labrador Island Link met the CAN/CSA-C22.3 No. 60826-10 standard
13 for 1:150 and 1:500 year return periods? If so, please provide the strength
14 (reduction) factors. If not, why not?

15

16

17 A. Refer to Hydro's response to NP-NLH-038 for strength reduction factors. The same
18 strength reduction factors were applied in all loading scenarios, whether for design
19 or for structure utilization analysis. Strength reduction factors are not related to
20 return period.

21

22 With respect to angle and deadend towers using failed system $\phi_R = 0.9$, the Lower
23 Churchill Project (LCP) used 0.8 instead to ensure the required longitudinal capacity
24 for critical conductor tension related load cases. Angle Towers (C1, C2) were
25 designed for unbalanced loading condition with strength factor 0.8. The generic
26 longitudinal loading value derived from this condition is critical in designing

1 associated longitudinal lattice members. Deadend towers (example D1, D2 & E1)
2 were also designed with terminal condition (maximum loads on one side, and no
3 load on the other) with strength factor 0.8. This approach provides much higher
4 longitudinal capacity to the respective tower members to perform effectively as
5 anti-cascade towers.