## Page 1 of 1

1	Q.	Reference: Review of the Muskrat Falls and Labrador Island HVdc Link and the
2		Isolated Island Options, October 2012 ( <a href="http://powerinourhands.ca/pdf/MHI.pdf">http://powerinourhands.ca/pdf/MHI.pdf</a> )
3		The Manitoba Hydro International Review of the Muskrat Falls and Labrador Island
4		HVdc Link and the Isolated Island Options states at Page 47:
5		"The climatic loadings for each line section are approximately equivalent to the
6		climatic loadings calculated assuming Canadian Standards Association (CSA) 1:500
7		year-return period."
8		Please describe in detail, any changes to the <u>design loading criteria</u> of the Labrador
9		Island Link made between Manitoba Hydro International's Report on Two
10		Generation Expansion Alternatives for the Island Interconnected System in January
11		2012 and Manitoba Hydro International's Review of the Muskrat Falls and Labrador
12		Island HVdc Link and the Isolated Island Options in October 2012.
13		
14		
15	A.	The design criteria used during detailed design of the Labrador-Island Transmission
16		Link were documented in Hydro's response to NP-NLH-004. The criteria have not
17		changed, but it is evident that MHI did not compare the ice loading criteria to the
18		CSA standard during the Muskrat Falls Review in the same manner as they did in the
19		DG3 report.