

1 Q. Reference: Muskrat Falls Review: Exhibit 95: Evaluation of in-cloud icing in the
2 Long Range Mountain Ridge
3 Please provide any studies, besides Exhibit 95 – Evaluation of in-cloud icing in the
4 Long Range Mountain Ridge, that were relied upon for in-cloud or rime icing data in
5 the design of the Labrador Island Link.

6

7

8 A. As described in Hydro's response to NP-NLH-004, rime ice criteria were evaluated
9 using Exhibit 95, filed in the Muskrat Falls Review proceeding. Further to the study
10 results, the actual design criteria were significantly greater than those predicted in
11 the study.