

1 Q. **Reference: Response to the Request for Information NP-NLH-005 (Revision 1, June**
 2 **3-15).**

3

4 In the response to Request for Information NP-NLH-005 (Revision 1, June 3-15),
 5 Hydro has confirmed that it is designing the new 230 kV line to be constructed to
 6 *Hydro's standard design criteria* given below:

7

Zone	Ice (Glaze)	Wind	Combined Wind/Ice
Bay d'Espoir to Piper's Hole	50 mm	100 km/hr	60 km/hr / 25 mm
Piper's Hole to Western Avalon	75 mm	130 km/hr	60 km/hr / 45 mm

8

9 Please confirm that the return periods of the above loads are based on Hydro's
 10 standard design criteria of 1:50 year loads, such as those described in the Muskrat
 11 Falls Review Exhibit 85 – Reliability Study of Transmission Lines on the Avalon and
 12 Connaigre Peninsulas, and are not based on weather data provided in the CAN/CSA-
 13 C22.3 No. 60826-10 standard.

14

15

16 A. The design criteria in the above table represent Hydro's standard design criteria for
 17 meteorological loadings for "normal" and "ice" zones for Newfoundland, as

1 established for the Avalon Peninsula upgrade program in the mid 1990's and
2 subsequently updated to meet the Reliability Based Design Method. Although not
3 based on CAN/CSA C22.3 No. 60826-10, given that they predate the standard by 15
4 years, in order to ensure adequacy in the load cases they are checked against the
5 standard to verify that the loading still meet or exceed the most current version of
6 the standard.