

1 Q. Please confirm that the Teshmont Report contains a probabilistic assessment of
2 reliability based upon anticipated average numbers of failures and average repair
3 time.

4

5

6 A. It is confirmed that the Teshmont Report provides a comparison of the reliability of
7 the IIS before and after the HVdc interconnections using average failure rates and
8 average repair times. Sensitivity scenarios were considered for Holyrood units in
9 addition to the anticipated average statistics (i.e. failure rates and repair times).