

1 Q. Has Hydro identified all critical spares for key generation, transmission, terminal  
2 station and other equipment and are such spares currently available in the  
3 Province? When was the determination and availability of such spares last  
4 reviewed?

5

6

7 A. Hydro has critical spares identified and available at strategic locations throughout  
8 the province. It was last formally reviewed in 2011. In 2012, Hydro commenced an  
9 internal review of the methodology for determining critical spare thresholds.

10 Please also refer to Hydro's response to PUB-NLH-038.