

1 Q. Further to the response to PUB-NLH-018, which states that there is a capacity
2 deficit identified for 2015, what is the status of Hydro's application for approval of a
3 60MW Combustion Turbine? Include in the response the date Hydro anticipates the
4 application will be filed with the Board and the length of time required for a 60 MW
5 Combustion Turbine to be installed and ready for operation.

6

7

8 A. An application concerning the solution to the 2015 capacity deficit is currently being
9 prepared for submission to the Board by March 31, 2014. If the 60 MW (nominal)¹
10 combustion turbine option for installation at Holyrood is the least cost option,
11 assuming approval in June 2014, it can be constructed and brought into service by
12 the end of 2015.

¹ "Nominal" is used to refer to a range of MW which will meet the system needs. The flexibility to consider a range of sizes will allow Hydro to seek the best solution in terms of delivery, cost and capacity.