

1 Q. Please provide the current estimated cost, by voltage level, to replace an air-blast
2 circuit breaker with a new SF6 circuit breaker.

3

4

5 A. The current estimated cost, by voltage level, to replace an air-blast circuit breaker
6 with a new SF6 circuit breaker is provided in the table below.

7

Voltage (kV)	Total Estimated Cost (\$000)
230	780
138	590