

1 Q. Please describe the extent that distribution feeders have automatic circuit reclosers  
2 on the feeders downstream from the substations. Provide the percentage of  
3 reclosers that are SCADA controlled.

4

5

6 A. On the Hydro distribution system, 41 automatic circuit reclosers are located on  
7 feeders downstream from substations. Of these, 3.6% are SCADA controlled.