

1 Q. Further to PUB-NLH-109 what about those consumers of both Newfoundland
2 Power and Newfoundland and Labrador Hydro, who are not being served, should
3 their unserved demand also be added back to determine what the actual Island
4 Peak Load would have been?

5

6

7 A. Whether or not data on unserved demand should be added to the recorded peak to
8 determine what the actual Island Peak Load would have been depends on the
9 context in which the Island Peak Load is to be used. The recorded peak should be
10 entered into the record of historic peak loads. Of course, unserved demand, by its
11 nature, cannot be measured. Therefore, it must be estimated based on causal
12 factors such as weather. This gives the forecaster the information on both numbers
13 to best determine how they fit into and affect future forecasts.