

1 Q. In the data set of historic peak loads that Newfoundland and Labrador Hydro uses  
2 in its load forecasting process, do those peak load data include added corrections  
3 for interruptibles, voltage reductions and unserved demand to determine what the  
4 actual Island Peak Load would have been?

5

6

7 A. Hydro relies on three peak load data sets in its load forecasting process to forecast  
8 Island Peak Load. These three peak load data sets include:

9

- 10 1. Newfoundland Power (NP) peaks;
- 11 2. Hydro's island rural system peaks; and
- 12 3. Hydro's Industrial Customers peaks.

13

14 These historic peak load data sets do not include adjustments for interruptibles,  
15 voltage reductions and unserved demand. Please note that Hydro has a record of  
16 the interrupted industrial loads that occurred at Island peaks and the curtailed  
17 loads at NP's peaks. See also the responses to PUB-NLH-109, PUB-NLH-110, PUB-  
18 NLH-111, PUB-NLH-112 and PUB-NLH-115.