

1 Q. Please describe how Newfoundland and Labrador Hydro exercises its right to  
2 request interruptible customers by SCADA to shed load, by telephone, or by other  
3 contact.

4

5

6 A. Please refer to Hydro's response to PUB-NLH-127. All requests to interrupt  
7 customers are made by telephone.