

1 Q. To what extent does Hydro provide automatic and/or remote controlled
2 sectionalizing of its subtransmission circuits and distribution feeders? In the
3 response include the extent the taps on the feeders are fused and the extent the
4 subtransmission and distribution feeder breakers are SCADA controlled.

5

6

7 A. Hydro has approximately 101 automatic circuit reclosers in the Island
8 Interconnected System. Of these, 20 reclosers are SCADA controlled.

9

10 The majority of Hydro's taps on mainline distribution feeders contain fused
11 disconnects. Some exceptions are:

- 12 • Taps that have a recloser or a sectionalizer providing protection;
- 13 • Taps where three-phase gang switches have been installed; and
- 14 • Older construction where disconnects were not originally installed.

15

16 Hydro does not have any equipment it classifies as subtransmission. Please refer to
17 Hydro's response to PUB-NLH-187 for further explanation.