

1 Q. Please confirm that normally all HVdc cables will be energised and in service.

2

3

4 A. Under normal operation all three HVdc submarine cables crossing the Strait of Belle

5 Isle will be energized and in service. One pole will have two cables operating in

6 parallel while the second pole will have a single cable in operation.