

1 Q. Further to PUB-NLH-248 please state what penalties will be applied if the
2 guaranteed performance is not met.

3

4

5 A. \$ 1,000,000 x (average number of outages per year during the six years of the
6 Performance Assessment Period -5) per pole.