

- 1 Q. Further to PUB-NLH-250 please state what penalties will be applied if the
2 guaranteed performance is not met.
3
4
- 5 A. \$5,000,000 x (guaranteed annual energy availability – measured annual energy
6 availability (forced and scheduled unavailability considered)) which has been
7 measured during the Guaranteed Performance Assessment Period.