

- 1 Q. Further to PUB-NLH-252 please state what penalties will be applied if the
2 guaranteed performance is not met.
3
4
- 5 A. \$5,000,000 x (average number of bipole outages per year during the Performance
6 Assessment Period - 0.1).