

1 Q. Further to the response to PUB-NLH-217, page 5, lines 23-27 confirm that if the  
2 Maritime Link is not available there could be a power shortfall in on the Island  
3 Interconnected system of 300MW, until at least one of the poles has been restored.  
4

5

6 A. Hydro's response to PUB-NLH-217, page 9, lines 19-21 indicates that with the  
7 Maritime Link available (assuming a 300 MW import capability and the availability  
8 of a 60 MW interruptible load arrangement), there would be no shortfall  
9 experienced until the 2025 peak. In the unlikely event that the Maritime Link is not  
10 available at the same time there were to be an unforeseen bipole outage on the  
11 Labrador-Island Link, the amount of shortfall of supply on the Island Interconnected  
12 System will depend on customer demand and generation capability. However, even  
13 in this scenario, it would be 2025 before any shortfall on the Island would reach 300  
14 MW.